N73-11894 CR-128634

CASE FILE

ADVANCED ETC/LSS COMPUTERIZED ANALYTICAL MODELS - CO₂ CONCENTRATION FINAL REPORT

VOLUME II Simulation Manual

MCDONNELL DOUGLAS ASTRONAUTICS COMPANY

MCDONNELL DOUGLAS

CORPORATION



ADVANCED ETC/LSS COMPUTERIZED ANALYTICAL MODELS - CO2 CONCENTRATION FINAL REPORT

VOLUME II Simulation Manual

OCTOBER 13, 1972

MDC-G3799

PREPARED BY:

B. N. TAYLOR and A. V. LOSCUTOFF

APPROVED BY: Janua C. Decond.

Go. K. H. HOUGHTON, M.D.

CHIEF ADVANCE TECHNOLOGY ENGINEER

BIOTECHNOLOGY AND POWER

PREPARED FOR NATIONAL AERONAUTICS AND SPACE ADMINISTRATION. MANNED SPACECRAFT CENTER, HOUSTON, TEXAS UNDER CONTRACT NO. NAS9-12076

MCDONNELL DOUGLAS ASTRONAUTICS COMPANY-WEST

5301 Bolsa Avenue, Huntington Beach, CA 92647

FOREWORD

The study described in this report was prepared by the Biotechnology and Power Department of the Advance Systems and Technology Directorate, McDonnell Douglas Astronautics Company - Western Division, Huntington Beach, California.

J. R. Jaax, Crew Systems Division, National Aeronautics and Space Administration, Manned Spacecraft Center (MSC) was the contract technical monitor. B. N. Taylor was the principal investigator for McDonnell Douglas. A. V. Loscutoff assisted in the preparation of the computer subroutines and simulation models. Volume I of this report is a summary of the work performed. Volume II contains detailed information concerning the preparation and usage of the analytical models.

TABLE OF CONTENTS

		Page
LIST OF FIGURES	3	ii
SUMMARY		1
SECTION 1.0	INTRODUCTION	2
SECTION 2.0	SIMULATION MODELS FOR CO ₂ CONCENTRATION CONCEPTS	
	2.1 Steam Desorbed Resins 2.2 Vacuum Desorbed Solid Amines 2.3 Carbonation Cell 2.4 Hydrogen Depolarized Cell 2.5 Solid Electrolyte 2.6 Liquid Absorption 2.7 Electrodialysis 2.8 Molten Carbonate 2.9 Membrane Diffusion 2.10 Mechanical Freezeout	5 17 27 44 51 61 75 88 98
SECTION 3.0	CONCLUSIONS	124
REFERENCES AND	BIBLIOGRAPHY	131
APPENDIX A	NEW COMPONENT SUBROUTINES	
APPENDIX B	NEW UTILITY OR SPECIAL PURPOSES SUBROUTINES	
APPENDIX C	MODIFIED SUBROUTINES	
APPENDIX D	LISTING OF INPUT DATA FOR SAMPLE PROBLEMS	

FIGURES

		Page
2.1-1	NASA/MDC 90-Day Manned Test Amine Resin - CO ₂ Concentrator System	· 7
2.1-2	NASA/MDC 90-Day Test Amine Resin CO ₂ Concentrator Performance	9
2.1-3	G-189A Simulation of a Typical Steam Desorbed Solid Amine CO ₂ Concentrator	12
2.2-1	Flow Diagram of Bench Scale Gat-O-Sorb Process	18
2.2-2	G-189A Simulation of Vacuum Desorbed Amine Bed	21
2.2-3	Vacuum Pump Characteristics	26
2.3-1	Carbonation Cell CO ₂ Collector	28
2.3-2	Stage 1 Cell - Schematic Representation	29
2.3-3	Anode Gas Mixture as Function of Cathode Gas Mixture for Carbonation Cell	31
2.3-4	Cell Voltage as Function of Cell Current - Stage I	32
2.3-5	Carbon Dioxide Transfer as Function of Cell Current - Stage I	32
2.3-6	Stage II Cell - Schematic Representation	33
2.3-7	Cell Voltage as Function of Cell Current - Stage II	34
2.3-8	G189A Carbonation Cell Connection and Definition	37
2.4-1	Hydrogen Depoloarized Cell	45
2.4-2	Cell Schematic	46
2.4-3	G-189A Simulation Hydrogen Depolarized Cell Concentrator	48
2.5-1	Solid Electrolyte Cell Reactions	52
2.5-2	Solid Electrolyte Schematic	54

FIGURES

		Page
2.5-3	G-189A Simulation of Solid Electrolyte Subsystem	56
2.6-1	Liquid Absorption CO ₂ Concentrator	63
2.6-2	G-189A Simulation of Liquid Absorption CO ₂ Concentrator	66
2.7-1	Electrodialysis CO ₂ Management System	76
2.7-2	CO ₂ Removal Unit	78
2.7-3	G-189A Simulation of Electrodialysis Concentrator	81
2.8-1	Molten Carbonate Cell	89
2.8-2	Schematic of Cell Reactions for Molten Carbonate Cell	89
2.8-3	G-189A Simulation of Molten Carbonate Concept	92
2.9-1	Membrane Module	99
2.9-2	Membrane Diffusion Module	100
2.9-3	G-189A Simulation of Membrane Diffusion Concept	103
2.10-1	Mechanical Freeze-out System, Non-Recoverable CO2	112
2.10-2	Mechanical Freeze-out System, Recoverable CO2	113
2.10-3	G-189A Simulation of Mechanical Freeze-Out	116

SUMMARY

Computer simulations have been prepared for the concepts of CO₂ concentration which have the potential for maintaining a CO₂ partial pressure of 3.0 mmHg, or less, in a spacecraft environment. The simulations were performed using the G-189A Generalized Environmental Control computer program. In preparing the simulations, new subroutines to model the principal functional components for each concept were prepared and integrated into the existing program. Sample problems are presented within this report which demonstrate the methods of simulation and performance characteristics of the individual concepts. Comparison runs for each concept can be made for parametric values of cabin pressure, crew size, cabin air dry and wet bulb temperatures, and mission duration.

The computer simulations have pointed out that, for many of the concepts, additional laboratory testing is required to determine better data for certain subsystems parameters or physical properties. Specific recommendations for each concept are contained in section 3.0 of this report.

The analytical models provide a means of determining subsystem performance for the concepts for a wide range of operating conditions. This should aid in an evaluation of the relative merits of each concept to satisfy various mission requirements.

1.0 INTRODUCTION

The maximum allowable CO₂ partial pressure for future manned space programs has been set at 3.0 mm Hg. This has required an evaluation of all CO₂ management concepts capable of meeting the 3.0 mm Hg or less constraint. Ten concepts which have potential for meeting this requirement are listed below:

- o steam desorbed solid amines
- o vacuum desorbed solid amines
- o carbonation cell
- o hydrogen depolarized cell
- o solid electrolyte
- o liquid absorption
- o electrodialysis
- o molten carbonate
- o membrane diffusion
- o mechanical freezout

The above-mentioned concepts are in various stages of development. The steam desorbed reins concept has been tested in the 90-day manned simulator run. Extensive development work has been performed on the hydrogen depolarized cell concept for use in the Space Station Prototype (SSP) EC/LS being developed for NASA Manned Spacecraft Center (MSC). The molten carbonate concept is an example of a concept for which many design problems must be solved before a viable design is evolved.

In order to assist in the evaluation of the relative merits of each concept, computer subroutines have been developed for simulating the performance characteristics of the concepts.

The subroutines have been integrated into the G-189A Generalized Environmental Control computer program. A brief description of this computer program is contained in Appendix A of this report. Using the program, each concept can thus be evaluated for a wide variety of operational design conditions. The following conditions have been specified as design parameters:

o .	cabin total pressure	10 - 14.7 psia
0	crew size	2 - 12
0	dry bulb temperature	65 - 75°F
0	wet bulb temperature	46 - 57°F
0	O ₂ partial pressure	3.1 to 3.5 psia
0	cabin diluent gas	nitrogen
0	gravity conditions	0 - 1.0g
0	CO ₂ production rate	1.9 to 3.0 lb/man-day

mission time

A generalized rather than specific approach has been used in preparing the simulation of the concepts. A typical concept was modeled by breaking up the subsystem into a series of functional components. These functional components might be an absorbing or desorbing bed, several heat exchangers or dehumidifiers, control valves, fans, etc. Existing G189A subroutines are available for simulating many of the functional components. New subroutines were prepared when required. For those components which have a common function in more than one concept, a single routine was prepared which could be used in simulating both concepts. For example, the same routine is used for simulating the absorption phase of operation for both the steam desorbed and vacuum desorbed resin concepts.

0.5 to 10 years

The subroutines used, order in which they are solved, sources of flow to a component are specified as input data to the G189A program. Any arbitrary, arrangement can be simulated. The program has a considerable amount of flexibility for reflecting subsystem design or operating changes.

The simulation of a CO₂ concentrator using the Gl89A may require incorporation of a considerable amount of additional coding to simulate interfaces between components. This results from the cyclical operation of many of the concepts. Time sequencing valves may change the direction of flow from one component to another. For instance, when absorbing a bed received its flow (air) from one source, but while desorbing the same bed receives its flow (steam) from another source. Thus coding may be necessary to interpolate tables specifying the

cyclical operation of the bed, alter the order of component solution, and change the source of flow. This coding may be incorporated into G-189A subroutine GPØLY or into a special purpose subroutine to simulate the interface function.

Sample problems have been prepared to illustrate the simulation of each concept. Descriptions of the new subroutines prepared are given in the Appendix. Data input requirements and the analytical model used are included in the description.

The methods of simulation described and the new subroutines prepared will allow comparative evaluation of the performance of each concept. In particular, the capacity of a particular design for maintaining a 3.0 mm Hg CO₂ partial pressure may be evaluated. Parametric runs for specified conditions of cabin pressure and volume, crew size, or CO₂ production rate, cabin air dry and wet bulb temperatures, gravity, and mission duration may be made. Alternatively, each concept can be evaluated for assumed values of CO₂ flow rates to the subsystem and comparing the time averaged values for removal rates. The impact of interfaces with other subsystems such as oxygen regeneration or water recovery also can be determined. This should aid in selection of the optimum subsystem and suitable alternatives for a particular space mission.

2.1 STEAM DESORBED RESINS

2.1.1 Process Description

In this CO₂ concentration process, cabin air passes through a granular bed of solid amine particles such as amberlite IR-45 resin. Since amines are weak bases, carbon dioxide (an acid gas) undergoes a weak chemical reaction with the sorbent and is therefore removed from the cabin air.

As more and more carbon dioxide absorbs in the resin, a point will finally be reached when the ${\rm CO}_2$ in the gas stream comes to equilibrium with the ${\rm CO}_2$ absorbed in the resin. At this time, the resin will have picked up all the ${\rm CO}_2$ it is capable of holding and must then be regenerated.

In the steam desorb resin concept, regeneration is accomplished by passing superheated steam through the bed. Trapped air in the void space between particles is first pushed out. After elution of the air, carbon dioxide is the main effluent. When the CO₂ is essentially depleted, steam-breakthrough occurs. Regeneration is then complete.

MSA Research Corporation, References 1.1 and 1.2, conducted fundamental studies on CO₂ sorbents for NASA Langley Research Center. An ion-exchange resin, amberlite IR-45, manufactured by the Rohm and Haas Company proved to be durable and suitable for practical CO₂ removal processes.

Hamilton Standard utilized surplus flight hardware from the MOL program to fabricate a solid-amine carbon dioxide concentrator. The performance of the unit was demonstrated in the 90-day manned test of MDAC, Reference 1.3.

2.1.2 Process Operational Details

CO₂ is removed from cabin air by means of cyclic absorption/desorption in suitable granular amine resins. The chemical nature of the bonding between CO₂ and these resins provides a CO₂ removal method which is feasible for cabin P_{CO₂} levels of 3 mm Hg or less. Dynamic CO₂ absorption and desorption processes, as well as equilibrium CO₂ bed loading conditions, are extremely sensitive to the amount of water present. For example, for IR-45 resin, increases in bed water content up to as high as 40% weight result in corresponding increased absorption efficiencies (Reference 1.1). However, water vapor contents higher than 25% have been shown to cause excessive pressure drop and flooding. With the bed cooler than approximately 140°F the absorption process takes place according to the following relationship:

$$R * NH_2 + CO_2 + H_2O \longrightarrow RNH_3^+ + HCO_3^-$$

For steam desorbed resins, desorption is accomplished by flowing superheated steam into the bed in the axial direction. The steam condenses on the resin, heats the resin and displaces the CO, and air. The process occurs in "chromatographic" fashion. That is, steam, CO2, and air are found in individual zones which travel along the length of the bed. See Reference 1.1. The displaced CO, is reabsorbed immediately ahead of the steam zone and the air is displaced ahead of the CO2-rich zone. This chromatographic feature of the absorption process facilitates separation of CO, from air and steam. Flows of the separate quantities of gas in each of the zones have associated physical properties which can be sensed and used in control schemes for diverting the CO2-rich flow to the CO2 accumulator and also for diverting the air and steam flows back to the cabin via a condensing heat exchanger. Two of these properties which have been used in the steam desorbed resin CO2 concentrator for the LaRC/ MDAC 90-day manned test are gas temperature and flow rate. See Figure 2.1-1. CO, has a higher mass flow rate out of the bed than air does due in part to its higher molecular weight and, therefore, higher density. The increase in




FIGURE 2.1-1 NASA/MDAC 90-DAY MANNED TEST
AMINE RESIN-CO₂ CONCENTRATOR SYSTEM

mass flow rate which occurs as the air zone is depleted and the CO_2 zone elutes from the bed is sensed and a controller actuates a valve which diverts the CO_2 to the CO_2 accumulator. As the CO_2 zone is depleted, an increase in gas temperature at the bed exit plane occurs as steam commences to leave the bed. This temperature is sensed and the control valve is actuated to divert the flow back to the cabin return line. The effluent steam is condensed in the condensing heat exchanger in this line and the resulting condensate is returned to the water boiler. With steam desorbed resins the desorption phase of the process generally occurs at total gas pressures in the vicinity of cabin pressure. The pressure of the CO_2 -rich gas leaving the bed is raised in a compressor to a pressure slightly in excess of CO_2 accumulator pressure. Since accumulator pressures are often in the order of 50 psia or less, the required compressor pressure ratio and associated power are considerably less than they are for CO_2 concentrator methods which utilize vacuum desorption.

Following desorption, the beds are hot and moist. Cabin atmosphere entering a bed during the absorption phase of the process is maintained at a suitable inlet temperature $(65^{\circ}F - 85^{\circ}F)$ and the inlet humidity is maintained above a lower limit ($\sim 35\%$ RH). Initially this entering air is heated by the hot moist bed. Heat is removed from the air in evaporating moisture from the bed. When desirable operating conditions are achieved, the amount of water condensed and partially absorbed in the bed during the desorption phase is exactly balanced by that evaporated during the absorption phase and the water content in the bed during absorption remains high enough to enhance CO_2 absorption.

Figure 2.1-2 shows representative performance data for the steam desorbed resin ${\rm CO}_2$ concentrator used in the LaRC/MDAC 90-day manned test. These data were recorded during "two-bed operation." That is, two of the three available absorption beds are operating and the adsorption and desorption cycles were of equal duration. The lower curve shows the mixed ${\rm P}_{\rm CO}$ downstream of the two absorption beds. As shown, the effluent ${\rm P}_{\rm CO}$ drops rapidly at the start of the absorption phase, reaches a minimum value, and then rises with a plateau characteristic observed partway through the ${\rm P}_{\rm CO}$ rise. This plateau characteristic was also reported in Reference 1.1. Again, in Figure 2.1-2 it is seen that most of the absorption occurs early in the absorption phase. The latter portion of the absorption phase was mainly used in drying the bed prior to the next desorption phase.




FIGURE 2.1-2 NASA/MDAC 90-DAY MANNED TEST
AMINE RESIN CO₂ CONCENTRATOR PERFORMANCE

The upper curve on Figure 2.1-2 shows the P_{CO2} in the accumulator. The negative slope portions of the curve are due to CO2 removal for supply to the Sabatier reactor. The positive slope portions are due to CO2 concentrator desorption. As shown in Figure 2.1-2 when Bed No. 2 is absorbing, Bed No. 3 is desorbing. From the earlier discussion concerning steam desorption, it is apparent that during the initial portion of the desorption phase air in the bed is eluted and flows back to the cabin. The CO2 zone is subsequently eluted and during this portion of the desorption phase flow is directed to the CO2 accumulator. This results in the positive slopes shown for accumulator pressure changes in Figure 2.1-2. Following elution of CO2, steam flows out of the bed and the effluent is again diverted back to the cabin via the condensing heat exchanger. During this portion of the desorption phase, the P_{CO2} in the accumulator again decreases due to the demand of the Sabatier reactor.

2.1.3 Simulation of Concept

The simulation of this concept is performed by dividing the subsystem into functional components, suitably connecting the components, and incorporating interface and control logic into GPØLY. Figure 2.1-3 is a schematic for the G-189A components required for simulation of a typical subsystem. The subroutines used are shown in parenthesis on the figure.

Gas from the cabin is supplied to the subsystem by component 14 (ALTCØM). This flow is circulated by FAN component 4 to bypass valve 5 (SPLIT). The flow not bypassing goes to absorbing bed component 6 (CØSØRP). This component simulates a solid amine's bed which removes CO₂ from the cabin airstream. Since the bed is relatively wet with respect to the cabin air, moisture is picked up by the airstream. This moisture is removed by condensing heat exchanger component 7 (ANYHX). The coolant flow to this component is supplied by component 17 (ALTCØM). The dehumidified air then passes through a charcoal trap, component 8, which removes odors picked up in the amine's bed. The charcoal trap is simulated by subroutine ADSØRB.

While component 6 is removing CO₂ from the cabin airstream, component 16 (CØSØRP) is being purged with superheated steam to drive off CO₂ absorbed previously. Components 6 and 16 operate in a cyclic manner. While 6 is absorbing, 16 is desorbing. Steam to the bed is supplied by steam generator component 15. This component is simulated by a newly prepared subroutine SMGEN. Feed water to this component is pumped by metering pump 19 (PUMP) from water accumulator component 10 (TANKG). Condensate from heat exchanger components 7 and 12 is recirculated to this accumulator tank. Component 20 uses a new subroutine H2OSUM to sum up the flows from these two sources. Makeup water to the accumulator is supplied by feed water tank component 9 (TANKG).

The CO₂-steam mixture from the desorbing resin bed 16 is pumped by compressor 11 (FAN) through condensing heat exchanger component 12 (ANYHX). Coolant for this heat exchanger is supplied by component 18. De-humidified CO₂ from the heat exchanger is pumped to accumulator component 13 (TANKG).




FIGURE 2.1-3 G189A SIMULATION OF A TYPICAL STEAM DESORBED SOLID AMINE CO2 CONCENTRATOR

2.1.4 Sample Problem

Description -

A sample problem was prepared to demonstrate the simulation of the subsystem shown in Figure 2.1-3. The assumed inlet conditions of flow to the subsystem are based on requirements for a six-man EC/LS system. Logic has been incorporated into GPØLY to simulate valve sequencing operations which are required when switching the beds from an absorbing to disorbing mode.

Assumptions -

1. Gas from Cabin (Air)

Flow: 19 scfm = 84.6 lb/hr

Relative Humidity = 48% = .00905 lb dry air

CO₂ partial pressure = 3.0 mmHg

Temperature = 75°F

Pressure = 14.7 psia

Trace contaminates = .02 lb/hr

2. Absorbing/Desorbing Solid Amines Bed

Length = 5.5 inches*
Frontal area = 1.57 ft

Bulk density = 28.8 lb/ft³

Pellet diameter = .00115 ft

Pellet heat capacity (dry) = 0.26 Btu/lb°F

Void fraction = 0.40

Superficial surface area = 3130.ft²/ft³

Heat of sorption for CO₂ = 250.Btu/lb

Heat of sorption for H₂0 = 1400.Btu/lb

Heat transfer coefficient

during absorption : calculated by program during desorption = 3.2 Btu/hr-ft²-oF

^{*} Effective length when dry.

Mass transfer coefficients (CO2)

during absorption = 6.8×10^{-4} lb moles

during desorption = 14.0×10^{-4} lb moles

Mass transfer coefficients (H₂0)

during absorption = 6.8×10^{-6} lb moles

hr-ft²-mmHg

during desorption = 22.0 x 10

Initial conditions

during absorption:

 CO_2 loading = .018 1b CO_2 /1b dry resin

 H_2O loading = 0.22 lb H_2O/lb dry resin

Bed temperatrue = 200°F

during desorption

 CO_2 loading = 0.0310 lb CO_2 / lb dry resin

 H_20 loading = 0.22

Bed temperature = 75°F

Operating conditions

duration of absorption cycle = 20 minutes

duration of desorption cycle = 20 minutes

Blower Characteristics

Heat dissipated into air = 60 watts

Air Condensing Heat Exchanger Characteristics

Coolant flow rate =

200. lb/hr

Coolant inlet temperature =

40.

Estimated overall thermal

between gas and coolant=

50 Btu/hr°F

Heat exchanger time constant =

10 seconds

Coolant: Water

5. Water Makeup Tank Characteristics

Volume = 1.0 ft³

Overall heat transfer conductance

to surroundings

= 1.0 Btu/hr °F

Initial volume =

= 0.5 ft³

Outside surface area

 $= 1.0 \text{ ft}^2$

Pressure

= 14.7 psia

Initial Mass in Tank

= 31.2 1b

6. Water Accumulator

Volume = 0.15 ft^3

Overall heat transfer

conductance to surroundings = 1.0 Btu/hr°F

Initial volume

 $= 0.075 \text{ ft}^3$

Outside surface area

 $= 1.00 \text{ m}^2$

Initial mass in tank

= 4.7 1b

7. Steam Generator (Boiler) Characteristics

Steam generation rate

= 4.00 1b/hr

Temperature

= 220°F

Pressure

= 14.7 psia

8. Desorbing CO₂ Compressor Characteristics

Heat dissipated into gas stream = 10 watts

9. CO₂/Steam Mixture Condensing Heat Exchanger

Characteristics

Coolant Type

= water

Coolant flow rate

= 200 lb/hr

Coolant inlet temperature

= 40°F

Estimated overall thermal conductance between gas

and coolant

= 50 Btu/hr°F

10. 00, Accumulator Characteristics

Volume = 2.0 ft³

Overall heat transfer conductance

to surroundings = 2. Btu/hr-°F

Initial pressure = 14.5 psia

00, use rate = .575 lb/hr

Initial mass in tank = .307 lb

11. Water Metering Pump

Electrical input power = 15 watts

Pressure rise = 14.0 psi

Flow = 4.0 lb/hr

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. Bed length
 - b. Frontal area
 - c. Volumetric flow rate through bed
 - d. Duration of absorption cycle
- 2. When attempting to match predicted results with experimental results for the same bed configuration and conditions, the following parameters should be varified:
 - a. Pellet characteristics (effective diameter, particle density, superficial surface area, void fraction, etc.)
 - b. Absorption isotherm data and heats of sorption.

2.2 VACUUM DESORBED SOLID AMINES

2.2.1 Process Description

This concept uses a solid amine resin bed to absorb CO_2 from a spacecraft atmosphere. The bed is regenerated at suitable time intervals by the combined effects of heat and vacuum. The CO_2 driven off in the bed is pumped to an accumulator for storage or usage by another subsystem. The accumulated gas may be dumped overboard or fed to an oxygen regeneration or propulsion system.

A prototype system using a proprietary resin designated as Gat-O-Sorb is described in reference 2.1. The reported advantages of this system are that no predrying of the gas is necessary prior to carbon dioxide absorption and only moderate regenerative conditions (180°F and 40 mmHg) are necessary. One possible disadvantage of this system is that a considerable amount of water is also carried off by the vacuum pumping system during desorption cycle. Reference 2.1 reported a weight ratio of between 0.1 and 0.51b H₂O/1b CO₂ collected during desorption. In reference 1.2 it was reported that for vacuum desorbed IR-45 solid amine resin, water is desorbed ahead of CO₂. Here a 20% bed water content was necessary to obtain a 2% value of CO₂ bed loading. Thus, up to 10 1b H₂O may be desorbed/1b CO₂. This could pose a significant water removal problem.

Figure 2.2-1 shows a schematic of a prototype Gat-O-Sorb process. The unit was found to remove 0.41 lb CO₂/hr with a total resin weight of 30 lbs. The unit was tested through 91 different operating cycles without indication of absorbent deterioration.

The process shown in Figure 2.2-1 may be described as follows: CO_2 is removed from the process gas in one bed while absorbed CO_2 is being removed in the other bed. Two positions, four port valves are used to alternately reverse the bed functions. A centrifugal blower drives process gas through the absorbing bed, and a vacuum pump purges the desorbing bed. The beds are heated or cooled by tube-and-fin heat exchangers inside each canister




FIGURE 2.2-1 FLOW DIAGRAM OF BENCH SCALE GAT-O-SORB PROCESS

and in direct contact with the adsorbent particles. When absorbing, cool water is circulated through a bed. When desorbing, hot fluid is used.

Below inlet relative humidities of 50%, the absorbent was found to gradually dehydrate and lose its capacity for CO₂ absorption. RH above 50% was found not to be harmful to the process. RH below 50% could be tolerated for exposure times of several hours.

2.2.2 Simulation of Concept

The thermal/vacuum desorbed amines concept for CO₂ removal will be simulated by suitably connecting G-189A components which simulate individual components or functions of the concentrator. Figure 2.2-2 illustrates the G-189A components required for a typical subsystem. The subroutines used for each component are given in parenthesis.

Gas from the cabin is supplied by component 1 (ALTCØM). The gas is circulated to the subsystem by blower component 2 (FAN). The gas flows to component 3 (SPLIT) which controls the amount of gas bypassing the subsystem. Flow then passes through a solid amines resin bed where CO₂ is removed by absorption. Cooling fluid (water) flows from component 5 (ALTCØM) through the bed's integral heat exchanger. The coolant is required for removing the heat of absorption and the thermal energy stored in the bed during the thermal/vacuum desorption cycle. CO₂ free gas flows from the bed to charcoal trap component 7 (ADSORB) and back into the cabin.

While component 6 is absorbing CO₂, component 8 (VACDSP) is being desorbed of CO₂ collected previously. Desorption is affected by the combined effects of heat and vacuum. The heat is supplied by hot water from component 4. Desorbed CO₂ plus water vapor is transferred by vacuum pump component 9 (VACPMP) through condensing heat exchanger component 10 (ANYHX). Water vapor picked up during desorption is removed in this component. The dehumidified gas then flows to accumulator tank component 12 (TANKG) for storage or use by an oxygen regeneration subsystem.

2.2.3 Sample Problem

Description - A sample problem was set up for the subsystem shown in Figure 2.2-2. The inlet conditions selector are based on requirements for CO₂ removal for a six man system. The logic necessary to simulate time dependent operations such as valve sequencing is incorporated in GPØLY.

FIGURE 2.2-2 G189A SIMULATION OF VACUUM DESORBED AMINE BED

Assumptions -

1. Gas from Cabin (Air)

Flow

Dry-CO₂ free constituents = 83.6 lb/hr
CO₂ .507 lb/hr
H₂O vapor .766 lb/hr
84.873 lb/hr

Relative humidity = $50\% \sim .0094$ 1b H₂0/1b dry air CO₂ partial pressure = 3.0 mm Hg Temperature = 75° F Pressure = 760 mm Hg

Absorbing/Desorbing Solid Amines Bed

Length = 5.5 inches*
Frontal area = 1.57 ft

Bulk density = 28.8 lb/ft³

Pellet diameter = .00115 ft

Pellet heat capacity (dry) = 0.26 Btu/lb °F

Void fraction = 0.40

Superficial surface area = 3130 ft²/ft³

Heat of sorption for CO₂ = 250 Btu/lb

Heat of sorption for H₂O = 1400 Btu/lb

Mass transfer coefficients during absorption:

for $CO_2 = 6.8 \times 10^{-4}$ lb moles/hr-ft²-mm Hg for $H_2O = 6.8 \times 10^{-4}$ lb moles/hr-ft²-mm Hg Integral heat exchanger data

thermal capacitance of Hx = 0.208 Btu/°F thermal capacitance of cooling fluid = 1.00 Btu/°F

^{*} Effective length when dry.

Heat transfer coefficients during absorption:

gas to bed = (calculated by program)

gas to heat exchanger core = 0

bed to heat exchanger core = 146.0 Btu/hr-oF

heat exchanger core to bed = 146

Initial Conditions:

during absorption:

CO₂ loading = .018 lb CO₂/lb dry resin

 H_2O loading = 0.22 lb H_2O/lb dry resin

Bed temperature = 180°F

during desorption:

 CO_2 loading = 0.0310 lb CO_2 /lb dry resin

 H_20 loading = 0.22

Bed temperature = 75°F

Operating Conditions

duration of absorption cycle = 20 units

duration of desorption cycle = 20 minutes

Cooling Fluid Requirements (Water)

Flowrate = 270 lb/hr

Inlet Temperature = 55°F

Heating Fluid Requirements (Water)

Flowrate = 270 lb/hr

Inlet Temperature = 200 °F

3. Blower Characteristics

Heat dissipated into air = 60 watts

4. Desorbing Gas Condensing Heat Exchanger

Coolant type = water

Coolant inlet temperature = 40°F

Estimated thermal conductance between gas and coolant = 7.5

Flow rate cooling fluid = 10 lb/hr

5. Vacuum Pump Characteristics

Isentropic compression

$$\eta_{\text{aero}} = 0.40$$

$$\eta_{\text{motor}} = 0.60$$

K = polytropic exponent = 1.304 (CO₂ @ 15°C)

Flow determined from generalized curve for small vacuum pumps (see Figure 2.2-3).

6. CO₂ Accumulator Characteristics

Volume = 2.0 ft^3

Overall heat transfer con-

ductance to surroundings = 2 Btu/hr-°F

Initial pressure = 20 psia

CO₂ use rate = .575 lb/hr

Initial mass = 0.307 lb

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. Bed length
 - b. Frontal area
 - c. Volumetric flow rate through bed
 - d. Duration of absorption cycle
- 2. When attempting to match predicted results with experimental results for the same best configuration and conditions, the following parameters should be varified:
 - a. Pellet characteristics (effective diameter, particle density, superficial surface area, void fraction, etc.)
 - b. Absorption isotherm data and heats of sorption.
 - c. Heat transfer coefficients
 - d. Mass transfer coefficients

3. The performance of the desorbing bed, vacuum pump, and accumulator are highly dependent on one another. When integrating a concentrator subsystem simulation into a larger or complete EC/LS simulation, it is suggested that the bed, vacuum pump, and accumulator be put in a subloop with a smaller computing interval than the overall system computing interval.




FIGURE 2.2-3 VACUUM PUMP CHARACTERISTICS

2.3 CARBONATION CELL

2.3.1 Process Description

The carbonation cell concentrator is an electrochemical device for collecting CO_2 from a cabin atmosphere. The process operates in a continuous rather than cyclic manner. The CO_2 collected is free of diluent gas contamination. Figure 2.3-1 illustrates the major components of a typical carbonation cell collector. Moist air is circulated into the cathode compartment of Stage I. An impressed voltage creates electrolytic reactions at the cell's two electrodes which are separated by an aqueous carbonate electrolyte held within an asbestos matrix. The net effect of the reactions is to liberate O_2 and CO_2 at the cell's anode compartment. Purity ranges between 50 and 70 mole percent. Air depleted in oxygen and with negligible amounts of CO_2 flows from the outlet of the cathode back to the cabin.

The gas freed at the anode is then transferred to Stage II which employs an aqueous acid electrolyte. An impressed voltage and accompanying electrolytic reactions create a liberation of only 0_2 at the anode of this stage. $C0_2$ is concentrated at the cathode of this cell.

The concentrated CO₂ stream from the Stage II cathode passes through a condenser/separator to remove water vapor gained through evaporation in the cells. A compressor is used to force the CO₂ into a storage tank. Details on the operation of the I and II stages of the concentrator, which were abstracted from reference 3.1, are given below:

First Stage (Carbonation Cell) Operation -

Process air flows into the cell cathode compartment where O_2 and CO_2 are absorbed by the cell electrolyte. Oxygen combines with water to form hydroxyl ions while CO_2 reacts with hydroxyl ions to form carbonate (CO_3) or bicarbonate (HCO_3) ions. The \overline{OH} , CO_3 , and HCO_3 ions diffuse through the electrolyte to the anode compartment. These ions react at the anode to liberate CO_2 and CO_2 and CO_3 in the electrochemical reactions at the anode and cathodes.




FIGURE 2.3-1 CARBONATION CELL CO₂ COLLECTOR




FIGURE 2.3-2 STAGE 1 CELL-SCHEMATIC REPRESENTATION

The electrochemical reactions vary significantly with carbon dioxide partial pressure in the cathode gas. For very low CO_2 concentrations, only $\overline{\mathrm{OH}}$ ions are formed and thus only O_2 is liberated at the anode. At very high CO_2 partial pressures, a large number of bicarbonate ions are formed to favor a high CO_2 to oxygen ratio at the anode. At normal operating levels of 0.03 to 1.0% CO_2 , most of the carbon dioxide is liberated through transference by the carbonate ions. The effect of CO_2 cathode partial pressure is illustrated by figure 3.2-3.

Typical performance curves for a cell operating at 10 psia are shown in Figures 2.3-4 and 2.3-5. At a current density of 40 amps/ft² and a cell temperature of 140°, the CO₂ transfer rate is approximately 5cc per ampmin. The anode gas concentration is over 55% CO₂.

Second Stage Operation -

CO₂ level could be boosted to a maximum amount of 80% through use of a second carbonate stage (see Figure 2.3-3). A second stage employing an acid electrolyte was found effective in achieving a CO₂ concentration of almost 100%. Here the active species is the hydrogen ion. Oxygen reacts with this ion at the cell cathode to form water which migrates to the anode. Here the water is decomposed to oxygen and hydrogen ions. Thus no CO₂ is transferred in this stage and a high separation efficiency is achieved. Details on the cell reactions are shown in Figure 2.3-6. Figure 2.3-7 shows the cell terminal voltage as a function of current density. Using a design value of 50 amps/ft² oxygen was found to be transferred at a rate close to the theoretical value of 3.5cc(STP) per amp-min.

2.3.2 Simulation of Concept

The simulation of the carbonation cell CO₂ concentration subsystem is performed by dividing the subsystem into major functional components which are modeled by G-189A component subroutines. Figure 2.3-8 represents a typical subsystem. Process gas flow from the cabin is supplied by component 1(ALTCØM).




FIGURE 2.3-3 ANODE GAS MIXTURE AS FUNCTION OF CATHODE GAS MIXTURE FOR CARBONATION CELL

CATHODE GAS FLOW - 2 X SCO

CATHODE CAVITY PRESSURE - 9.5 - 10" Hg VAC ELECTROLYTE CONCENTRATION (MEAN) - 29.3 WT % K2 CO3




FIGURE 2.3-4 CELL VOLEAGE AS FUNCTION OF CREAT OURRENT - STAGE I




FIGURE 2.3-5. CARBON DIOXIDE TRANSFER AS FUNCTION OF CELL CURRENT - STAGE I




FIGURE 2.3-6 STAGE II CELL-SCHEMATIC REPRESENTATION

ACTIVE ELECTRODE AREA - 0.83 FT² CATHODE GAS FLOW - 1.3 x S₀₂




FIGURE 2.3-7 CELL VOLTAGE AS FUNCTION OF CELL CURRENT - STAGE II

A blower (FAN), component 2, forces process gas through the subsystem. Prior to entering the concentrator, the process gas flows through a humidifier (HUMID), component 3, where water vapor exchange takes place with the process gas leaving the first stage of the concentrator. The humidified process gas then flows to the cathode compartment of the first stage, component 4 (CARCL1), of the subsystem. Process gas leaves the cathode compartment essentially free of CO_2 . An $\mathrm{O}_2/\mathrm{CO}_2$ mixture leaves the anode compartment. The purified process gas leaving the first stage flows back through component 3 (HUMIDT) to condenser/separator component 6(ANYHX) prior to returning to the cabin.

The $\mathrm{CO_2/O_2}$ mixture from the anode compartment of the first stage flows to the cathode side of component 8(CARCL2) which is the second stage of the concentrator. $\mathrm{CO_2}$ is obtained from the cathode side of this stage while $\mathrm{O_2}$ is obtained at the anode side. $\mathrm{CO_2}$ from the cathode side flows to condenser/water separator component 9(ANYHX). The dehumidified $\mathrm{CO_2}$ is pumped by component 20(FAN) to a $\mathrm{CO_2}$ reservoir component 21(TANKG). $\mathrm{O_2}$ collected at the anode side of the second stage flows to condenser/water separator component 10(ANYHX). The dehumidified $\mathrm{O_2}$ is pumped by component 22(FAN) to accumulator component 23(TANKG).

The condensate flows from condenser/water separator components 6, 9, and 10 are summed up by component 16(H2ØSUM). The total condensate flow is pumped by component 17(PUMP) to water storage tank component 18(TANKG). This tank provides makeup feed for the two carbonation cell stages, components 4 and 8. The amount of makeup water required is calculated by GPØLY logic. This water is added to the subsystem at component 5(GASMIX).

2.3.3 Sample Problem

Description -

The sample problem described here was prepared to verify the computational accuracy of the subroutines used for the carbonation cell concept. The subsystem, which is assumed to be sized for six men, is shown schematically in

Figure 2.3-8. Many of the values of input data are based on values reported in Reference 3.2.

Assumptions -

1. The conditions of the cabin air used in defining the data for component l are as follows:

Dry bulb temperature, OF	70.
Wet bulb temperature, OF	60.
Cabin pressure, psi	14.7
Partial Pressure CO2, mm Hg	3.0
Oppressure, psia	3.1
CO ₂ generation rate/removal rate per man	.1 lb/hr-man
Number of men	6

Reference 3.2 was used to provide data for determining the operating conditions, removal efficiency, and power requirements for the 6-man $\rm CO_2$ concentrator subsystem. The removal efficiency of $\rm CO_2$ of gas stream flowing through the concentrator system is $\sim 46\%$, which is used in calculating the input data to component 1.

Total air flow, lb/hr	211.987
Temperature, °F	70.0
Upstream duct outlet pressure, psi	14.7
Component outlet pressure, psi	14.7
Non-condensable flow, 1b/hr	209.697
H ₂ 0 vapor flow, lb/hr	2.29
Non-condensable specific heat, Btu/lb-OF	.24
Non-condensable molecular weight, lb/mole	28.97
Oxygen flow, lb/hr	49.3
Diluent flow (N2), lb/hr	159.13
Carbon dioxide flow, lb/hr	1.267

2. Blower Characteristics

Heat dissipated into process gas, watts

150




FIGURE 2.3-8 G189A CARBONATION CELL COMPONENT CONNECTION AND DEFINITION

3. Humidifier Characteristics

Mass transfer effectiveness = 95% Heat transfer effectiveness = 94%

4. First Stage of Carbonation Cell Characteristics

Heat Loss Data:

Ambient gas temperature (°F)	70.
Thermal conductance between surface and ambient	
(Btu/hr-OF)	.1
Ambient wall temperature (°F)	60.
FA factor for radiation conductance (Ft ²)	2.
Structure temperature for heat short, (OF)	60.
Thermal conductance between module and structure	.1
(Btu/hr- ^o F)	

Cell Parameters:

Transfer rate of CO ₂ (lb/hr-amp-cell)	.00121
Desired module temperature (°F)	140.
Heater turn-off temperature (°F)	138.
Actual temperature of module (OF)	140.
Design current density (amp/Ft ²)	35.
Area of cell (Ft ²)	1.0
Number of cells in the module	15
Voltage per cell	1.17
Relative humidity in exit cathode gasses (decimal fraction	1) .48
Relative humidity in exit anode gasses (decimal fraction)	.95
Weight of water per cell in matrix (lb)	1.5
Weight of C _s CO ₃ per cell in matrix (lb)	1.83
Desired solids concentration in matrix (%)	55.
Actual solids concentrator in matrix (%)	55.
Total pressure of stage (psia)	14.6
Thermal capacitance of stage (Btu/OF)	40.
Heat transfer conductance from coolant to cell	33.
(Btu/hr-OF-Cell)	•

Component 34 provides the coolant flow to the first stage carbonation cell. The flow rate, pressure and temperature of the coolant flowing to the first stage are defined as follows:

Flow rate (lb/hr)	10	0.0
Temperature (°F)	10	0.0
Pressure (psia)	2	0.0

The physical properties of the coolant (water) listed below also apply to coolant provided by components 36, 38, 39 and 40.

Specific heat (Btu/lb-°F)	1.0
Density (lb/ft ³)	62.4
Viscosity (lb/hr-ft)	3.6
Molecular weight (lb/mole)	18.0
Conductivity (Btu/hr-ft-OF)	.325

Makeup water that is added to the first stage carbonation cell is provided by component 18, Water Storage Tank. The amount of makeup water required is computed by subroutine CARCL1 and is used through GPØLY logic to compute the outlet flow from the H₂O supply tank. A similar approach is used in modeling the water flow to the second stage carbonation cell, component 8.

5. Process Gas Condenser/Water Separator Characteristics

Overall UA (Btu/hr-F)	35.
(NTU)Max	5.0
Primary side design outlet temp. (OF)	65.
Tolerance for design temperature (OF)	3.

The coolant to the heat exchanger is provided by component 36. The values of the parameters defining the inlet conditions are:

Flow rate (lb/hr)		 	40.0
Temperature (°F)			45.0
Pressure (psia)	•		20.

The physical properties of the coolant are the same as those defined for component 34.

6. Second Stage of Carbonation Cell Characteristics

Heat Loss Data:

Ambient gas temperature (°F)	70.
Thermal conductance between surface and ambient (Btu/hr-OF)	.1
Radiation wall temperature (°F)	60.
FA factor for radiation conductance (Ft ²)	2.
Structural temperature for heat short (OF)	60.
Conductance between module and structure (Btu/hr-OF)	.1

Cell Parameters:

0 ₂ removal efficiency	.98
Desired module temperature (OF)	172.
Heater turn-off temperature (OF)	174.
Heater turn-on temperature (OF)	170.
Actual temperature of the module (OF)	172.
Design current density (amp/Ft ²)	50.
Number of cells	8.0
Voltage per cell	125.
Relative humidity in exit cathode gas	•35
Relative humidity in exit anode gas	•95
Weight of H ₂ O per cell in matrix (lb)	2.
Weight of H ₂ SO ₄ per cell in matrix (lb)	1.2
Desired H ₂ SO ₄ concentration (%)	50.
Actual H ₂ SO ₄ concentration (%)	50.
Vapor pressure of water over electrolyte (psi)	6.0
Total pressure of stage (psi)	14.7
Thermal capacitance of stage (Btu/OF)	45.
Heat transfer conductance from coolant to cell (Btu/hr-°F)	20.

The coolant flow to component 8 is provided by component 38. The flow rate, pressure, and temperature at the inlet are as follows:

Flow rate (lb/hr)		100.
Temperature (^O F)	·	100.
Pressure, upstream duct (psi)	•	20.
Pressure, component outlet (psi)		20.

The makeup water to the second stage carbonation cell is provided by component 18.

7. CO2/Water Separator Characteristics

Overall UA (Btu/hr-OF)	1.5
NTU (max)	5.
Design outlet temperature (OF)	45.
Tolerance in outlet temperature (OF)	5.

The coolant is provided by component 39. The flow, temperature and pressure are given as follows:

Coolant flow rate (lb/hr)	20	•
Coolant temperature (OF)	40	•
Coolant pressure, component outlet (psi)	20	•
Coolant pressure, upstream duct (psi)	20	•

8. 0₂/Water Separator Characteristics

Overall UA (Btu/hr-F)	3.0
NTU (Max)	6.0
Design primary outlet temperature (OF)	45.
Tolerance for design temperature (OF)	5.0

The coolant flow to the $0_2/H_20$ separator is provided by component 40. The flow rate, temperature, and pressure are:

Coolant flow rate (lb/hr)	10.
Temperature (OF)	40.
Pressure, upstream duct (psi)	20.
Pressure, component (psi)	20.

9. The CO₂ and O₂ Reservoir Characteristics

	Component	Component
	21	23
Ambient gas temperature (°F)	70.	70.
Thermal conductance between surface		
and ambient (Btu/hr-OF)	.05	.05
Ambient wall temperature (OF)	60.	60.
Radiation FA factor (ft ²)	6.	6.
Structure temperature (°F)	60.	60.
Conductance between tank wall		
and structure (Btu/hr-OF)	2.2	2.2
Thermal capacitance of tank (Btu/OF)	2.5	2.5
Conductance between fluid and wall		
(Btu/hr- ^O F)	0.5	0.5
Total gas weight in tank (lb)	.076	.0555
Gas temperature in tank (OF)	80.	80.
Tank volume (ft ³)	1.0	1.0
Tank pressure (psi)	10.0	10.0
Weight of non-condensable (1b)	.076	.0555
Specific heat (Btu/lb-OF)	.205	.217
Molecular weight (lb/mole)	44.0	32.
Weight of CO, in tank (1b)	.076	0.0
Weight of O2 in tank (lb)	0.0	0.555

10. Water Storage Tank Characteristics

Ambient wall temperature (°F)	70.
Conductance between ambient and surface of tank (Btu/hr-OF)	ĩ.
Ambient wall and structure temperature (OF)	60.
Radiation FA factor (ft ²)	6.
Conductance structure to tank (Btu/hr-OF)	.1
Thermal capacitance (Btu/°F)	2.5
H ₂ O weight in tank (lb)	100.
Temperature (°F)	70.
Volume (ft ³)	2.5
Specific heat (Btu/lb)	1.0

The outflow from the water storage tank which is computed by GPØLY1 is set equal to the sum of the water requirements for components 25, 4, and 8.

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired rate, the following parameters may be varied to achieve the desired result:
 - a. number of cells
 - b. desired operating temperatures
 - c. total current
 - d. area of cells
- 2. When attempting to match predicted results with experimental results for the same unit configuration and conditions, the following parameters should be varified:
 - a. CO₂ transfer rate as a function of current density and operating temperature
 - b. Cell voltage and current
 - c. Cell dimensions
 - d. Heat transfer characteristics
 - e. Electrolyte vapor pressure relationship

2.4 HYDROGEN DEPOLARIZED CELL

2.4.1 Concept Description

The hydrogen depolarized cell is an electrolytic process for CO_2 concentration. The concept evolved from the carbonation cell concept. The process differs in that only one stage is required, and that hydrogen is introduced at the anode of the cell. The hydrogen serves to depolarize the cell to shift the chemical equilibrium in the direction of CO_2 formation. The cell acts similar to a fuel cell since hydrogen and oxygen are consumed and electricity is generated. The electricity generated provides the energy required to create the electrolytic reactions which cause the separation of CO_2 from O_2 . A considerable amount of design effort and development testing have been conducted for the concept over the past seven years (1965-1972).

The process has a considerable amount of flexibility in the range of CO_2 partial pressures over which it can operate. The removal rate can be modulated if desired. The unit operates continuously requiring no regeneration. In addition the unit is reported to have a low equivalent weight compared to the other concepts for CO_2 removal (Reference 4.2)

Figure 2.4-1 illustrates the reactions occurring in the cell. CS_2CO_3 electrolyte is used rather than the K_2CO_3 used in the carbonation cell. Moist cabin air is fed to the cathode where oxygen reacts to form $O\overline{H}$ ion. These ion react with CO_2 to form carbonate ions. The air leaving the cathode compartment thus is depleted in both O_2 and CO_2 . The CO_3^- ion migrate in the electrolyte to the anode where they react with water to generate CO_2 . Hydrogen introduced at the anode reacts with $O\overline{H}$ ion to shift the anode reactions in the direction favoring formation of CO_2 .

The CO_2 liberated at the anode is free of O_2 but mixed with H_2 . The cell can operate effectively with percentages of H_2 varying from 20 to 90%. This mixture can be controlled to achieve the mix ratio desired for feed to a Sabatier CO_2 reduction process.

The concept incorporates an integral dehumidifier/humidifier to prevent dry out of the cells. Figure 2.4-2 shows a cross section of a typical cell. Further details on the operation of the cell are given in reference 4.2. Other information is provided in references 4.4, 4.5, 4.8. A detailed analytical model for the cell reactions is described in reference 4.12.




FIGURE 2.4-1 HYDROGEN DEPOLARIZED CELL




FIGURE 2.4-2 CELL SCHEMATIC

Thermal control of the cell temperature is accomplished through evaporation of water into the product streams.

2.4.2 Simulation of Concept

Figure 2.4.3 illustrates the functional components required for simulating the SSP Concentrator (Reference 4.1). The functions of each component are described as follows:

Air from the cabin is drawn through a dehumidifier component 2 (ANYHX). The dehumidifier is necessary to control air relative humidity within specified bounds. This control is necessary to prevent flooding or drying out of the cell electrolyte. The air then is drawn by blower component 3 (FAN) into the cathode compartment of hydrogen depolarized cell component 5 (H2DPØL). Here the CO₂ is scrubbed out by electrochemical reactions. The purified gas leaves the cell, flows through filter component 7 (ADSORB) which removes trace contaminants and returns to the cabin.

Hydrogen flow to the anode compartment is supplied by storage tank component 8 (TANKG). The hydrogen passes through filter component 9 (ADSORB) prior to entering the cell. In the anode compartment, hydrogen reacts with \overline{OH} to generate water. The water reacts with \overline{CO}_3^{-1} ions to regenerate \overline{CO}_2 . \overline{CO}_2 and unreacted \overline{H}_2 flow out of this compartment into storage tank component 10 (TANKG). This tank serves as a source of flow to a Sabatier reactor oxygen regeneration subsystem.

2.4.3 Sample Problem

Description -


A sample problem was prepared for the SSP subsystem previously described in Figure 2.4-3. A six-man sybsystem has been assumed. Data from reference 4.1 was used in preparing the sample problem.

Assumptions -

1. Flow of gas from cabin

Flow

Dry CO₂ free constituents 984. lb/hr CO₂ 5.97 lb/hr Water vapor 9.4 lb/hr



	Relative humidity	= 50%
	CO ₂ partial pressure	= 3.0 mmHg
	Temperature	= 75°F
	Pressure	= 760 mmHg
2.	Dehumidifier Characteristics	
	Type of coolant	= water
	Coolant inlet temperature	= 40°F
	Coolant flow rate	= 150 lb/hr
	Desired devpoint for air	= 40°F
	Heat exchanger effectiveness	= 0.95
3.	Subsystem Blower Characteristics	
	Heat dissipated into process gas	= 20 watts
_		
4.	Hydrogen Depolarized Cell	
	Maximum CO ₂ partial pressure in cabin	= 3.0 mmHg
	Cell temperature at time zero	= 62.0°F
	Lowest air temperature for operation	= 52.0°F
	Maximum air pressure for operation	= 14.7 psia
	Maximum air flow for operation	= 200 ft ³ /min
	Maximum partial pressure of	
	water vapor in air	= 7.925 mmHg
	Cell length	= 0.5 ft
	Total width of all cells	= 54 ft
	Air channel dimensions	= 0.2 inches
	Current collector width	= 0.05 inches
	Electrode spacing	= 25 mils
	Matrix thickness before compression	= 60 mils
	Matrix void volume fraction (dimensionless)	= 0.70
	Total mass of cell stack	= 111. lb
,	Average specific heat of cell stack	= 0.125 Btu/lb°F
	Available sponge volume of matrix	$= 6.1 \text{ ml/st}^2$

5. Hydrogen Storage Tank $= 2.0 \, \text{m}^3$ Volume Overall thermal conductance = 2.0 Btu/hr-°F to surroundings Initial pressure = 20 psia Initial mass = 0.014 1b6. Filter Characteristics Removal efficiency = 0.997. Hydrogen Flow to Subsystem Flow rate = 0.182 lb/hrTemperature = 75°F 8. H₂/CO₂ Accumulator $= 2.0 \, \text{ft}^3$ Volume Overall thermal conductance = $2.0 \text{ Btu/hr-}^{\circ}\text{F}$ to surroundings Initial pressure = 20 psia = 0.014 1bInitial mass of hydrogen

Initial mass of carbon dioxide

= 0.0618 1b

2.5 SOLID ELECTROLYTE

2.5.1 Process Description

Although the solid electrolyte process is conventionally categorized as a $\rm CO_2$ reduction scheme, and therefore not in the same functional category as the previous $\rm CO_2$ management concepts, it has some unique features that warrant discussion.

The solid electrolyte process (see References 5.10 and 5.11) in conjunction with a CO disproportionation reactor results in the reduction of CO_2 to carbon and oxygen. A small amount of water vapor in the CO_2 feed, which enhances the main reaction, is simultaneously electrolyzed to hydrogen and oxygen. Reference (5.12) points out that close coupling of this system with a carbon dioxide concentrator which generates humidified carbon dioxide continuously would have operational advantages. All of the previous writeups on the various CO_2 management concepts implicitly assumed that "dry" CO_2 was the desired product, mainly because the Sabatier or Bosch reactions were envisioned as the next step. The reason for discussing the solid electrolyte process, therefore, is to emphasize that humidified CO_2 might be the desired product from a CO_2 concentrator in some trade-off studies.

The system is composed of cells consisting at a solid electrolyte mixture of 91.25 mole percent zirconia (ZrO_2) and 8.75 mole percent yttria (Y_2O_3) . This solid electrolyte is situated between two platinum electrodes to which the electrolyzing potential is applied. The basic electrochemical separation process which occurs is illustrated in Figure 2.5-1. For a gas stream including carbon dioxide and water vapor the following reactions occur at the cathode:

$$200_{2} + 4e^{-} \longrightarrow 200 + 20^{-}$$
 $H_{2}0 + 2e^{-} \longrightarrow H_{2} + 0^{-}$

At a temperature of $525\text{-}700^{\circ}\text{C}$ ($1000\text{-}1300^{\circ}\text{F}$), the $G^{=}$ ions will be transported across the oxide film by the influence of the potential gradient. The reactions are enhanced by the presence of H_2O in the gas stream. The oxygen ion then migrates under the influence of a potential field through vacancies in the crystal lattice of the solid electrolyte material to the anode, where the oxygen ion is converted to an oxygen atom. The solid electrolyte is essentially impermeable to non-ionic species (in particular it is impermeable to CO) so that pure O_2 is formed at the anode and may be sent to




FIGURE 2.5-1 SOLID ELECTROLYTE CELL REACTIONS

the cabin with no further processing other than cooling. The power consumption in the cell is split between energy required to decompose the CO₂ and the resistance heating of the solid electrolyte material. As the predicted cell efficiency is thought to be good and the operating temperature high, this unit must be well insulated to prevent heat leakage which would decrease unit performance. An auxiliary heater in the cell tube is designed to bring the tube to operating temperature.

The free energy change involved in the decomposition of CO₂ to carbon monoxide and to oxygen is 123 kcal/gram-mole of oxygen. This corresponds to a theoretical power requirement for a cell of 68.8 watts/kg of CO₂ per day.

The mixture of CO and ${\rm CO_2}$ from the cell cathode is passed through a catalytic reactor which converts CO to ${\rm CO_2}$ (returned to the electrolytic cell) and to solid carbon. The free energy change in this reaction is 29 kcal/gram-mole of carbon. This corresponds to a heat dissipation requirement of 45 watts/kg of ${\rm CO_2}$ per day.

A flow diagram of a solid electrolyte system is given in Figure 2.5-2 which shows that after leaving the electrolyte cell, a separator is used to remove hydrogen from the gas stream. Also, a regenerative heat exchanger is used to cool the gas products to approximately 950°F, which is the operating temperature of the catalytic reactor. In the catalytic reactor, the carbon monoxide is dissociated to form carbon and carbon dioxide over a nickel or stainless steel catalyst. When the resultant carbon has built up to a high level, a pressure switch will sense the increasing differential pressure and signal for a change of catalyst bed. The catalytic reaction is exothermic and no heating of this unit is necessary once the system has reached operating temperature. A heat exchanger is used to remove the excess heat of reaction from the gas stream. A blower draws the recycle and process gases through the regenerative heat exchanger and humidifier before returning them to the electrolytic reactor.

2.5.2 Simulation of Concept

Two distinct cell designs have been fabricated and successfully tested. The first as reported in Reference 5.1 uses solid electrolyte discs between which the electrical potential is applied. The second which is reported in Reference 5.2 uses solid electrolyte tubes. Here the potential is applied at electrodes located on the inside and outside surfaces of the tubes. The second cell design differs from the first in that it incorporates a semipermeable palladium membrane for separating hydrogen from the exit products.




FIGURE 2.5-2 SOLID ELECTROLYTE SCHEMATIC

Relatively low concentrations of hydrogen in the inlet to the reactor have been found to increase the rate of carbon formation. Higher concentrations will shift the chemical equilibrium away from carbon formation. The semi-permeable membrane provides a means for regulating the concentration of hydrogen and thus carbon formation.

Figure 2.5-3 illustrates the G-189A components required to simulate the system for the 180 day life test reported in reference 5.2

CO₂ flow to the subsystem is supplied from CO₂ accumulator component 1 (TANKG). The CO₂ stored in this tank is assumed to have been collected by a CO₂ concentration subsystem. The steam desorbed solid amines, hydrogen depolarized cell, or carbonation cell concepts are then potentially suitable for this purpose. CO₂ flow is moved by component 2(FAN) to humidifier component 3 (GASMIX). Here the CO₂ is saturated with water prior to entering the solid electrolyte cells. The saturated CO₂ joins with recycle flow at component 4 (GASMIX) and then passes into the solid electrolyte cell component 5 (SØLELC).

Component 5 represents several parallel modules of solid electrolyte cells. Each module is composed of a number of parallel stacks of electrolysis cells. CO₂ is electrolytically decomposed into O₂ and CO in the cells. Water also is electrolyzed into hydrogen and oxygen. Oxygen collected at the anode of the cells flows to oxygen accumulator tank component 6 (TANKG).

CO and H₂ products and unreacted CO₂ and H₂O reactants flow to hydrogen gas separator component 7 (MEMOD). Hydrogen is separated by selective diffusion through a semi-permeable membrane. Hydrogen separated in this component is moved by vacuum pump component 9 (VACPMP) to hydrogen accumulator component 9 (TANKG).

The primary side gas stream from the hydrogen separator flows to carbon deposition reactor component 10 (CARDP). Here CO is reconverted back into CO, for cycling to the solid electrolyte cells. In a secondary reaction,




FIGURE 2.5-3 G189A SIMULATION OF SOLID ELECTROLYTE SUBSYSTEM

 $\rm H_2$ reacts with $\rm CO_2$ to form $\rm H_2O$ and $\rm CO$. The effluent of this component is circulated by component 11 (FAN) back to combine with the subsystem $\rm CO_2$ feed gas.

2.5.3 Sample Problem

Description -

A sample problem was prepared for the subsystem illustrated in Figure 2.5.3. The unit is sized for a six-man subsystem. Data has been scaled up from data presented in reference 5.2 and 5.13.

Assumptions -

1. CO, from Concentrator Unit

Flow

co2	0.542 lb/hi
Water vapor	0.00001
02	0.00001
N ₂	0.00001
Trace contaminants	0.00001
н ₂	0.00001
co	0.00001

Pressure

Total	pressure	·	נ	4.22	psia

2. Blower characteristics

Heat dissipated into process gas 2.0 watt	neat di	ssipated i	.nto	process	gas .	2.0 watts
---	---------	------------	------	---------	-------	-----------

3. Humidifier

						•		
•	Water	vapor	flow	rate			0.1230	lb/hr

4. Solid Electrolyte Unit

Number of modules 8 Number of stacks/module 18 Number of cells/stack Temperature = 1652°F Thermal conductance between surface of module insulator and ambient gas 2.1 Btu/hr-oF Thermal conductance of insulation .222 Btu/hr-°F Heat dissipated by electrical heater 505. Btu/hr Total current to unit 135 amps Overall current efficiency .810 fraction CO current efficiency .825 fraction Ho current efficiency .175 Cell voltage (1.74 - 1.85) 1.8 volts 0.614 fraction Voltage efficiency Module thermal capacitance 4. Btu/°F 6 cm² Active area/cell 0.55 - 0.6Degree of decomposition 160 ma/cm² Current density

5. Hydrogen Separator

Total membrane area
Thickness of membrane
Permeability

UA to surroundings
UA across membrane
Number of membranes
Frontal area (primary side)
Frontal area (secondary side)
Cell length
Module thermal capacitance
UA cell to module

1.48 ft²
.005 inches
5.18 x 10⁻¹⁴ ft³/hr (inches)
ft² (mm Hg)

.1 Btu/hr-°F 100. Btu/hr-°F 1 0.2 ft² 0.01 ft² 0.662 ft 0.1 Btu/°F 1.0 Btu/°F 6. Carbon Deposition Reactor

CO conversion	.212 (fraction)
H ₂ conversion	0. (fraction)
Heat dissipated by electrical heater	1000. (Btu/hr)
Reactor thermal capacitance	2. (Btu/°F)
Operating temperature	986 (°F)

7. Recycle Blower

Heat dissipated into process gas 60 watts

8. 0₂ Accumulator

Volume	2.0 ft ³
Overall thermal conductance	
to surroundings	2.0 Btu/hr-°F
Initial pressure	14.7 psia
0, use rate	0.5 lb/hr
Initial mass fraction 0	1.0 fraction

9. Vacuum Pump Characteristics

Isentropic compression

nareo	0.40
nmotor	0.60
<pre>K = polytropic exponent</pre>	1.41 (H ₂ @ 15°C)

Flow determined from generalized curve for small vacuum pumps (See Figure 2.2-3)

10. Hydrogen Accumulator

Volume 2.0 ft³

Overall thermal conductance

to surroundings 2.0 Btu/hr-°F

Initial pressure 14.7 psia

Initial mass in tank .31b

11. CO2 accumulator

Volume 2.0 ft³

Overall thermal conductance

to surroundings 2.0 Btu/hr-°F

Initial pressure 14.7 psia

Initial mass in tank .3 1b

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. Number of cells per stack
 - b. Number of stacks per module
 - c. Number of modules per unit
 - d. Cell current
 - e. Cell electrode area
- 2. When attempting to match predicted results with experimental results for the same cell configuration, the following parameters should be varified:
 - a. Overall 0_2 , CO, and H_2 current efficiency
 - b. Power efficiency
 - c. Cell voltage and current
 - d. Cell dimensions
 - e. Heat transfer characteristics
 - f. Reactor conversion

2.6 Liquid Absorption

2.6.1 Process Description

This process uses a liquid solution of potassium or sodium carbonate, or a mixture of both, to absorb CO₂ from the cabin air. When carbon dioxide is absorbed in an aqueous solution of sodium or potassium carbonate, the following reversible reaction occurs:

Heating the bicarbonate solution and reducing the partial pressure of carbon dioxide in the gas stream causes bicarbonate to be reconverted to carbonate and CO_2 .

The amount of carbon dioxide absorbed depends on several factors. These include the fraction of base that is bicarbonate, the normality of the solution, and the partial pressure of carbon dioxide in the gas. The relationship between these variables at equilibrium conditions is given by the following equation (Reference 6.19).

$$P_{\infty_2} = \frac{45f_0^2 \, \text{N}^{1.29}}{\text{S(1-f_0)(302-t)}}$$

for Na₂CO₃/NaHCO₃

$$P_{\infty_2} = \frac{137f_0^2 \, \text{m}^{1.29}}{\text{s}(1-f_0)(365-t)}$$

where:

$$P_{\infty_2}$$
 = partial pressure of CO_2 (mmHg)

$$N = normality of base $(\frac{g \text{ equivalents}}{liter})$$$

- S = solubility of CO_2 in H_2O at one atmosphere $(\frac{g \text{ moles } CO_2}{1 \text{ ter } H_2O})$
- t = temperature (°F)
- f_o = fraction of total base that is
 bicarbonate

A schematic of a CO_2 concentrator subsystem using the liquid absorption concept is shown in Figure 2.6-1. CO_2 laden cabin air is introduced into a contactor where the air stream is mixed with an aqueous carbonate solution to promote absorption of CO_2 . The absorption reaction is favored when the solution is approximately at room temperature. In industrial gas/liquid absorption processes, counter current flow is commonly used. However, it is difficult to envision a counter flow contactor for zero-g operation. Since a suitable zero-g design has not been yet defined, the contactor has been assumed to operate with co-current or parallel flow. A device for gas/liquid separation is located immediately downstream of the contactor to achieve separation of the cabin air stream from the carbonate solution.

A regenerative heat exchanger and external heat source is used to heat the carbonate solution prior to entering a liquid flash vaporizer. Here, CO_2 is desorbed and a portion of the water in the solution is vaporized. The liquid and gas phases leaving the vaporizer are assumed to be in thermodynamic and chemical equilibrium. The liquid phase is recirculated back to the liquid contactor and the gas phase is pumped to a condenser/ separator where CO_2 is separated from water vapor. The CO_2 is then transferred to a CO_2 storage tank.

FIGURE 2.6-1 LIQUID ABSORPTION CO2 CONCENTRATOR

2.6.2 Simulation of Concept

A simulation model of the liquid absorption CO₂ concentrator subsystem was prepared to facilitate evaluation of the concept and to define the subsystem's critical components and parameters such as solution flow, temperature, and pressures. Figure 2.6-2 shows the G-189A components required for a typical subsystem. Inlet air, defined by component 1 (ALTCOM) is forced into the liquid contactor by blower component 2 simulated by subroutine FAN. The liquid contactor, component 3, is simulated by subroutine LIQCON. This subroutine determines the amount of CO₂ absorbed in a parallel flow contactor with the gas and liquid phases leaving in thermal and chemical equilibrium. The effluent from the contactor flows to component 4 (SPLIT) where the CO₂ free cabin air is separated from the carbonate/bicarbonate solution. The air stream is dehumidified in component 5 (ANYHX) prior to being returned to the cabin.

The carbonate/bicarbonate solution flows through regenerative heat exchanger component 7 (ANYHX) and heater component 8 (ALTCØM) to raise the solution temperature to approximately 180°F. The solution then is partially vaporized in flash evaporator component 9 (LQFLSH). CO₂ is desorbed into the gas phase as a result of the partial vaporization. The gas phase which evolves contains CO₂ plus H₂O vapor. The liquid phase, which is in equilibrium with the gas phase, is a mixture of H₂O, carbonate, and bicarbonate.

The gas phase generated in the flash vaporizer is separated from the liquid phase and pumped by compressor component 16 (FAN) to condensing heat exchanger component 10 (ANYHX). Here, H₂0 vapor is separated from the CO₂. The CO₂ then flows to CO₂ reservoir component 12 (TANKG). The liquid phase from the flash vaporizer (component 9) is recirculated by pump component 19 (PUMP) back through the regenerative heat exchanger (component 7). The solution then is chilled in heat exchanger component 15 (ANYHX) prior to returning to the liquid contactor (component 3).

Water vapor condensed and separated in components 5 and 10 is collected by component 13 (H2ØSUM) and transferred to storage tank component 14 (TANKG). Makeup water to the carbonate/bicarbonate loop is supplied by this component. This water enters the loop at component 17 (LIQMIX).




FIGURE 2.6-2 G-189A SIMULATION OF LIQUID ABSORPTION CO CONCENTRATOR

2.6.3 Sample Problem

Description -

A sample problem simulating major components of the liquid absorption CO_2 concentrator subsystem has been prepared for performance analysis and system evaluation. The inlet conditions of the sample problem, shown schematically in Figure 2.6-2, are defined by a dummy component simulating cabin air flow to the system. The data defined by the dummy component include total flow, cabin air temperature and pressure, noncondensable flow, condensable vapor flow, specific heat and molecular weight of the noncondensable flow, oxygen flow, diluent flow (N_2) , and CO_2 flow. The input values to the first component are derived from assumptions defining cabin air conditions and the CO_2 removal rate and efficiency of the subsystem. The inlet conditions and flow rates along with the performance characteristics of the subsystem were used in the derivation of the design parameters of individual components.

Assumptions -

1. The cabin air conditions and system requirements are as follows:

Dry bulb temperature, oF	70.
Wet bulb temperature, oF	60.
Cabin pressure, psi	14.7
Partial pressure CO2, mmHg	3.0
O ₂ pressure, psi	3.1
co ₂ generation/removal rate	
per man lb hr-man	.1
Number of men	6

The total cabin air flow into the system is dependent on the required ${\rm CO}_2$ removal rate, the concentration of ${\rm CO}_2$ in the cabin air, and the ${\rm CO}_2$ removal efficiency of the liquid absorption subsystem. The ${\rm CO}_2$ removal rate and concentration in the cabin air are fixed by the rules used in evaluating the various ${\rm CO}_2$ concentrator subsystems. The ${\rm CO}_2$ removal efficiency is dependent

on the temperature of the aqueous solution flowing into the liquid contactor and the fraction of base that is bicarbonate. Lower bicarbonate fraction results in much higher sybsystem efficiency and, reducing the amount of carbonate solution that is required in CO₂ absorption and the amount of cabin air that is required to be passed through the system. Using the value of .23 for the CO₂ removal efficiency of the liquid contactor, we determine the required volumetric flow through the system to equal 4980 ft³/hr from which derive the input values to component 1.

Total flow, lb/hr	368.283
Temperature, °F	70.
Pressure, upstream duct, psi	14.7
Pressure, component outlet, psi	14.7
Noncondensable flow, lb/hr	364.201
Condensable vapor flow, 1b/hr	4.082
Noncondensable specific heat, Btu/lb-	°F .24
Noncondensable molecular weight	28.97
Oxygen flow, 1b/hr	96.92
Diluent flow (N2), lb/hr	265.08
CO ₂ flow, lb/hr	2.201

- 2. The blower forcing air into the system is simulated by subroutine FAN only to an extent that heat is added to the flowing gas stream. The value for heat added to gas stream by the blower is 50 watts.
- 3. Liquid Contactor characteristics (CO₂ absorption)

 The CO₂ absorption, and thereby removal from the cabin air stream, is accomplished by component 3, liquid contactor.

The component is simulated by the new subroutine LIQCON with the required input being as follows:

CO₂ removal efficiency of the contactor .23

Fraction of base that is bicarbonate in solution entering contactor (mole fraction).37

Normality of the solution entering the contactor 1.0

The inlet flow rates of constituents of the aqueous carbonate solution required to meet the CO₂ removal requirements and the system characteristics are computed on the first system pass when the value of Instruction Option 2 is set to 1. Instruction Option 1 selects type of solution, sodium carbonate/potassium carbonate, that is being used. The sample run assumed that the solution used is potassium carbonate.

4. Liquid/Gas Separation

The separation of the liquid and gas is accomplished by component 4, simulated by subroutine SPLIT. The input data required is as follows:

SPLIT ratios for flows A(6), A(7), A(10),
A(11), and A(12)

SPLIT ratios for flows A(15), A(16), A(17)

1.

5. Heat Exchanger Characteristics (cabin air temperature and humidity control)

The gas stream flowing through the liquid contactor where it is mixed with aqueous solution becomes saturated with vapor. Component 5, simulated by subroutine ANYHX, is used for condensing the cabin air temperature to $60^{\circ}F$ dew point temperature. The only input requirement is the overall UA (Btu/hr- $^{\circ}F$) of the heat exchanger which is set equal to 130.

The secondary flow is provided by component 25 with inlet conditions defined by the following:

Flow rate, lb/hr	150.
Temperature, °F	45.
Pressure, psi	15.

The physical properties of the coolant (water), are listed as follows:

Specific heat, Btu/lb-°F	1.0
Viscosity, lb/hr-ft	3.6
Density, lb/ft ³	62.4
Molecular weight, lb/mole	18.0
Conductivity	•325

is the desired normality of the aqueous solution, set to 1.0. It is used in determining the amount of makeup water that is required to account for vaporization.

The heat loss to surrounding data is as follows:

Ambient gas temperature, °F	70.
Thermal conductance between surface	
and ambient, Btu/hr-°F	• 5
Ambient wall temperature, °F	60.
FA factor for radiation conductance, ft ²	8.0
Structure temperature, oF	60.
Conductance between module and structure	.1
Conductance between module surface and	
insulation	•3

10. The gas from the liquid flash vaporization module is removed by component 16 which is simulated by subroutine FAN. The component is simulated only to an extent that heat is added to the gas stream flowing through. The required input is heat added to gas stream, 10 watts.

11. H₂0/CO₂ Condensing Heat Exchanger Characteristics

The separation of $\rm H_2O/CO_2$ is accomplished by component 10, simulated by subroutine ANYHX. The required input defining the heat exchanger is the overall thermal conductivity, UA= 100. The secondary flow, water, provided by component 30 is defined as follows:

Flow rate, 1b/hr	250.
Temperature, °F	45.
Pressure, psi	10.

12. CO2 Accumulator Tank

Storage of CO₂ gas is accomplished by component 12, simulated by subroutine TANKG. The required inputs are as follows:

The physical properties listed above also apply to coolant flow from components 30 and 35, which provide secondary flow to components 10 and 15, respectively.

6. Flow Return to Cabin

The return of CO₂ depleted cabin gas stream is simulated by subroutine FLOMET. The only input required is the reference temperature for enthalpy which is set at 32°F.

7. Regenerative Heat Exchanger Characteristics

The efficiency of the regenerative heat exchanger determines the power requirements for the system. A heat exchanger of high efficiency results in lower power requirements and a smaller heat exchanger to be used in chilling the aqueous solution. The regenerative heat exchanger is simulated by subroutine ANYHX as component 7. The required input is the parameter defining the size of the heat exchanger, overall thermal conductivity UA. The value of UA, Btu/hr-oF, is 1385.

8. Component 8, simulated by subroutine ALTCOM, heats the aqueous solution to desired temperature prior to lowing it into the liquid flash vaporizer. The input required is the desired outlet temperature, which is set to 185°F.

9. Liquid Flash Vaporization Module Characteristics

The desorption of CO₂ from the aqueous carbonate solution is accomplished by component 9, simulated by subroutine LQFLSH. Probably the most critical input parameter of the component and the subsystem is the nominal CO₂ partial pressure in the exit gas flash vaporization module, set initially to 10 mmHg in this sample run. This parameter determines the percentage of bicarbonate that will decompose evolving CO₂ gas and the fraction of base that is bicarbonate leaving the flash vaporization module. As mentioned in section 3.0, the CO₂ removal efficiency of the liquid contactor is heavily dependent on the fraction of base that is bicarbonate flowing into the contactor, the lower fraction resulting in higher efficiency. The other required input parameter

Ambient Gas Temperature, °F	70.
Thermal Conductance Between Ambient	
Tank, Btu/hr-°F	5.
Ambient Wall Temperature, °F	60.
Radiation FA Skin to Wall, ft ²	6.
Structure Temperature, °F	60.
Conductance between Tank and Structure,	**
Btu/hr-°F	12.
Total Fluid Weight in Tank, 1b	0.5
Fluid Temperature in Tank, °F	70.
Fluid Volume in Tank, ft ³	1.
Fluid Press in Tank, psi	14.7
Weight of Noncondensable in Tank, 1bs	0.5
Noncondensable Specific Heat in Tank,	
Btu/lb-°F	.17
Noncondensable Molecular Weight, lb/mole	44.
Weight of CO ₂ in Tank, lb	0.5

13. The collection of water condensate, condensing in components 5 and 10, is accomplished by component 13 simulated by H2ØSUM. The required inputs are as follows:

Number of components providing condensate	3.
Component number of first component	
providing the condensate	5
Component number of the second component	
providing the condensate	10

14. Water Storage Tank Characteristics

Water supply tank (component 14) which may be used to provide makeup water to the liquid absorption subsystem or to store excess water that might be condensed is simulated by subroutine TANKG. The required inputs are as follows:

Ambient Gas Temperature, °F	·	70.
Conductance Surface Insulation	•	
to Ambient, Btu/hr-°F		5.
Ambient Wall Temperature, °F		60.
Radiation FA Factor, ft ²	. *	6.
Structure Temperature, °F	•	60.
Conductance between Wall and		
Insulation, Btu/hr-°F	•	.05
Total Fluid Weight in Tank, 1b		62.4
Fluid Temperature in Tank, °F		60.
Fluid Volume in Tank, ft ³		1.
Weight of Liquid, 1b		62.4
Maximum Allowable Temperature	÷ .	
Change for SS, °F		5.0

- 15. Component 7, simulated by subroutine LIQMIX, provides a method of adding water from the storage tank to the liquid absorption subsystem. There are no inputs required.
- 16. The aqueous solution is circulated through the system by component 18 simulated by subroutine PUMP. The pump is simulated only to an extent that heat is added to the system. The value of heat added to the system is assumed to be 100 watts.

17. Chiller Characteristics

The chiller (component 15) used in reducing the temperature of aqueous carbonate solution is simulated by subroutine ANYHX. The required input defining the size of the chiller is its overall thermal conductivity UA (Btu/hr-°F)=600.

The secondary flow defined by component 35 is as follows:

Flow rate, lb/hr	-		100.
Temperature, °F			45.
Pressure, psi			10.

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. Flash evaporator pressure and temperature
 - b. Process gas and carbonate solution flow rate
- 2. When attempting to match predicted results with experimental results for the same cell configuration, the following parameters should be varified:
 - a. CO, equilibrium data
 - b. Heat transfer characteristics

2.7 ELECTRODIALYSIS

2.7.1 Process Description:

A sketch of a typical Electrodialysis CO₂ Management System is given in Figure 2.7-1. The most important components are the electrodialysis stacks since it is here that carbon dioxide is removed from air and oxygen is generated from water simultaneously. In general, cabin air is humidified and fed to absorber compartments where the carbon dioxide in the air is electrochemically converted to carbonate ions. Under the influence of an electrical potential, the carbonate ions are transferred out of the absorber into concentrator compartments where they react further to reform carbon dioxide gas. At the electrodes (anodes and cathodes) water is electrolyzed to form oxygen and hydrogen. Thus, if the system were treated as a black box, there are two inlet streams: water and cabin air containing carbon dioxide, and four effluent streams: oxygen, hydrogen, air with a reduced carbon dioxide content, and carbon dioxide (of greater than 99% purity). The basic principles involved in the electrochemical operations are electrodialysis and electrolysis. The description which follows was abstracted from Reference 7.2.

Electrodialysis is a process in which ionized molecules or atoms are transferred through highly selective ion-transfer membranes under the influence of a direct current. If a solution containing positively and negatively charged ions is fed to an electrodialysis cell, the positively charged ions (cations) will be attracted to the positively charged anode. The nature of the ion-transfer membrane between the solution and electrode (anode or cathode) determines whether or not an ion can migrate through it or be retained in the solution.

Anion-transfer membranes will allow anions to pass through them but exclude cations, while cation transfer membranes will allow the passage of cations but not anions. These membranes are highly selective for either anion or cation transfer. It is the selective properties of the anion and cation membranes which allow CO_2 to be removed from the process air in one compartment while CO_2 is concentrated in an adjacent compartment. The two adjacent compartments are termed a cell pair. It is possible in this sort of arrangement to place as many as 500 cell pairs between a single pair of electrodes. The combination of cell pairs and electrodes is referred to as an electrodialysis stack.




FIGURE 2.7-1 ELECTRODIALYSIS CO2 MANAGEMENT SYSTEM

The CO₂ removal unit is comprised of repeating units consisting of four compartments: a carbon dioxide absorber, or scrubber; a concentrator compartment; an anode; and a cathode. The absorber and concentrator compartments can be termed a cell pair, while the anode and cathode compartments represent an electrode pair. The reactions which occur in the various compartments of this configuration are summarized in Figure 2.7-2.

The operation of the CO2 removal unit is as follows:

Liquid (demineralized water is fed to the cathode compartment at a rate at least sufficient to provide for the water lost by electrolysis at the cathode,

$$H_2O + e^- = \frac{1}{2}H_2 + OH^-$$


and by electroendosmosis through the anion membrane into the absorber compartment. In any electrodialysis process as ions migrate across the membranes, water is transferred in the same direction. This water is apparently transferred due to the hydration of the ions as well as the electrical potential created by the movement of the ions through the pores of the membranes. The total water transfer is referred to as endosmotic water.

The liquid flow rate will be in excess of the electrochemical requirements to provide cooling of the stack and a sweep stream for the evolved hydrogen gas. A flow rate of about 8 gallons per hour is recommended in Reference 7.2 for a six-man unit at a cabin pressure of 7 psia.

Cabin air containing carbon dioxide is humidified and fed to the absorber compartment. In this compartment, which contains anion-exchange materials in the OH⁻ form, carbon dioxide is scrubbed from the air according to the following reaction,

$$\frac{1}{2}$$
CO₂ + OH⁻ = $\frac{1}{2}$ CO₃ + $\frac{1}{2}$ H₂O

The anion-exchange material is continually regenerated by the migration of hydroxyl ions from the cathode into the absorber compartment.



CM = CATION PERMSELECTIVE MEMBRANE

AM = ANION PERMSELECTIVE MEMBRANE

CP = MACROPOROUS CATION PERMSELECTIVE PACKING

AP = MACROPOROUS ANION PERMSELECTIVE PACKING

FIGURE 2.7-2 CO REMOVAL UNIT (BASIC REPEATING UNIT SHOWN)

Carbonate ions, excess hydroxyl ions and endosmotic water are transferred from the absorber into the concentrator compartment which contains cation-exchange material in the H⁺ form. The following reactions occur:

$$\frac{1}{2}co_3^{-} + H^{+} = \frac{1}{2}co_2 + \frac{1}{2}H_2^{-}0$$

$$OH^{-} + H^{+} = H_2^{-}0$$

The reformed carbon dioxide gas, along with the endosmotic water, passes out of the compartment under its own pressure.

Liquid (demineralized) water is fed to the anode compartment at a rate at least sufficient to provide for the water lost by electrolysis at the anode,

$$\frac{1}{2}H_{2}O = \frac{1}{4}O_{2} + H^{+} + e^{-}$$

and by endosmosis through the cation membrane into the concentrator compartment. The water flow rate will be substantially in excess of the electrochemical requirements to aid in heat removal from the anode and to provide a sweep stream for the evolved oxygen gas. The hydrogen ions continually migrate into the concentrator compartment, where they serve to regenerate the cation-exchange material.

There is at least some liquid water present in all four streams effluent from the concentrator. This leads to a gravity-independent gas-liquid separation requirement which is readily provided (since no frothing or foaming has been observed) by small state-of-the-art, passive, gas-liquid separators having short holdup times.

The theoretical reactions shown in Figure 2.7-2 assume 100% carbonate ion transfer efficiency and electrode efficiencies. If 100% efficiencies are achieved in all operations in this type of stack, $\rm CO_2$ is absorbed in a 2:1 volumetric (or mole) ratio to $\rm O_2$ production. The electrode reactions operate with about 100% efficiencies, while the membrane transfer process actually has efficiencies greater than 100% (under expected operating conditions).

This is explained by the formation of some monovalent bicarbonate ion (HCO_3^-) in the absorber, which (for the same current flow) would transfer twice as much carbon dioxide as the divalent carbonate ion (CO_3^-) . Thus, the actual volumetric ratio of CO_2 absorption to O_2 production is greater than 2:1.

On the average a man expires 0.85 moles of carbon dioxide for every mole of oxygen inhaled (or a ${\rm CO_2/O_2}$ ratio of 0.85:1). If a membrane transfer efficiency of 120% is assumed for normal concentrator operation, then a ${\rm CO_2/O_2}$ ratio of 2.4:1 is attained. This means that this type of electrodialysis stack does not supply sufficient metabolic oxygen while removing all the metabolic carbon dioxide. The remaining oxygen must be supplied by some other oxygen generation equipment.

It should be mentioned that experimental work has been conducted on electrodialysis stacks containing only one anode and cathode compartment for a multiple number of absorber/concentrator cell pairs. An additional compartment or water cell is added to each absorber/concentrator cell pair to provide the neessary H and OH. By eliminating the anode/cathode compartments with each cell pair, carbon dioxide can be removed from the atmosphere with almost negligible amounts of oxygen generated. However, the power requirements of these stacks have not been much lower than the power requirements of the Carbon Dioxide Scrubber described previously. In addition, between the cabin atmosphere leak rate and the metabolic loss of available oxygen (respiratory quotient of 0.85), there will be a significant oxygen supply requirement no matter what oxygen recovery subsystem is included in the space vehicle design.

2.7.2 Simulation of Concept

Figure 2.7-3 shows the G-189A components required to simulate a typical co_2 electrodialysis subsystem.

Cabin air is circulated through the concentrator by blower component 10 (FAN). The flow then passes through humidifier component 11 (GASMIX) prior to entering the electrodialysis cell module. Regulation of the humidity level in the process gas is necessary to prevent drying out of cell membranes.




FIGURE 2.7-3 G189A SIMULATION OF ELECTRODIALYSIS CONCENTRATOR

Process gas flows into the absorption compartment of the electrodialysis cell component 12 (ELDIAL). Here, CO_2 is removed by absorption and reaction with $\overline{\mathrm{OH}}$ ions. The purified process gas then returns to the cabin or the humidity control subsystem (not shown). The CO_2 removed in the absorption compartment migrates under influence of the cells' electrical field to the concentrator compartment. Here, CO_2 is recovered in a "sweep fluid" provided by component 2. For this sample problem, water is assumed to be the "sweep fluid". The CO_2 picked up by the sweep fluid is separated out in heat exchanger/water separator components 24 and 30 (ANYHX). The CO_2 is compressed by 25 (FAN) and transferred to accumulator component 26 (TANKG).

The \overline{OH} and \overline{H}^+ ions required for the chemical reactions occurring in the absorption and concentrator compartments, respectively, are supplied by water electrolysis reactions in the anode and cathode compartments. An alternate component, 13, is required for storing the outlet flow data for the anode and cathode compartments. Liquid water is circulated to both of these compartments by semi-closed loops. Makeup water to compensate for electrolysis, chemical reaction, and electroendosmosis is provided to those loops by water makeup tank component 4 (TANKG). Flow to this tank is provided by water feed tank component 3 (TANKG).

Flow in the semi-closed cathode loop is circulated by pump component 18 (PUMP). Water entering the cathode compartment is electrolyzed to form H₂ and \overline{OH} ions. The \overline{OH} ions migrate across a semi-permeable membrane into the absorber compartment. The effluent stream from the anode compartment flows to heat exchanger/water separator components 14 and 31 (ANYHX). Hydrogen separated from this stream is pumped by compressor component 15 (FAN) to accumulator component 16 (TANKG). The water separated is combined with makeup water at component 17 (LIQMIX) and recirculated. Cooling fluid to the condenser/water separator is provided by component 9.

The semi-closed water loop for the anode compartment is similar to that for the anode compartment. Water circulated by component 20 (PUMP) is electrolyzed to form 0_2 and H^{+} ions. 0_2 is separated from the anode effluent in heat exchanger/

water separator components 21 and 29 (ANYHX). Makeup water enters the loop at component 19 (LIQMIX). O₂ separated is transferred by component 22 (FAN) to O₂ accumulator component 23 (TANKG).

2.7.3 Sample Problem

Description -

A sample problem was prepared for the subsystem shown in Figure 2.7-3 and described in the previous subsection. The module is sized for a six-man space station. The performance characteristics of the unit were scaled up from results presented in reference 7.1 for a three-man subsystem.

Assumptions -

1. Gas from Cabin (Air)

Flow

Dry CO, free constituents	204.40	lb/hr
∞,	1.237	
H ₂ O wapor	1.40	
Total		
Relative humidity	38%	
CO, partial pressure	3.0 mm	ig
Temperature	75°F	٠
Pressure	760 mmHg	
·		

2. Humidifier

Water flow rate	0.55 lb/hr
Desired relative humidity	50%

3. Sweep Fluid Flow

Fluid	•	water
Flow rate		200 lb/hr
Temperature		75°F

4.	O ₂ Accumulator	
	Volume	2.0 ft ³
	Overall thermal conductance to surroundings	2.0 Btu/hr-°F
	Initial pressure	20.0 psia
	Initial mass fraction	l fraction
5.	CO ₂ Accumulator	
	Volume	2.0 ft ³
	Overall thermal conductance to surroundings	2.0 Btu/hr°F
	Initial pressure	20.0 psia
	Initial mass fraction	l fraction
6.	Water Feed Tank	
	Volume	2 ft³
	Overall thermal conductance to surroundings	2.0 Btu/hr°F
	Initial pressure	14.7 psia
	Initial mass	1.0 fraction
	Estimate flowout of tank	0.658 lb/hr
7.	Water Makeup Tank	
	Volume	0.15 A ³
	Overall thermal conductance to surroundings	2.0 Btu/hr°F
	Initial pressure	14.7 psia
	Initial mass	1.0 fraction
8.	Subsystem Blower Characteristics	
	Heat dissipated into process gas	50 watts
9.	Anode Loop Pump	
	Heat dissipated into circulating fluid	10. Btu/hr
,	Water circulation rate	64 lb/hr

10.	Cathode Loop Pump	
	Heat dissipated into circulating fluid	10. Btu/hr
	Water circulation rate	64 lb/hr
11.	O ₂ Compressor	• :
	Heat dissipated into compressed gas	5.0 watts
12.	H ₂ Compressor	
	Heat dissipated into compressed gas	5.0 watts
13.	CO ₂ Compressor	• •
	Heat dissipated into compressed gas	5.0 watts
14.	0 ₂ /Water Separator	x_{ij}
	O ₂ split ratio	•9999
	H ₂ O split ratio	.0100
15.	CO ₂ / Water Separator	
	O ₂ split ratio	•9999
	H ₂ O split ratio	.0100
16.	H ₂ /Water Separator	
	H ₂ split ratio	•9999
	H ₂ O split ratio	.0100
17.	Anode Loop Heat Exchanger	
*	Cooling fluid type	water
	Inlet temperature	50°F
	Flow rate	64 lb/hr
	Heat exchanger effectiveness	0.90
18.	Cathode Loop Heat Exchanger	
	Cooling fluid type	water
	Inlet temperature	50°F
	Flow rate	64 lb/hr
	Heat exchanger effectiveness	0.90

19. Sweep Fluid Heat Exchanger

Cooling fluid type	water
Inlet temperature	50 °F
Flow rate	150 lb/hr
Heat exchanger effectiveness	0.90

20. Electrodialysis Module Characteristics

No. of stacks/module		2
No. of cell pairs/stack		40
Total stack voltage	40x5.3	212 volts
Current efficiency		128%
Current density		4.6 amps/ft ²
Effective anode area/com	partment	0.72 ft ²
Relative humidity of pro	cess gas effluent	50%
Power efficiency		0.30
Module thermal capacitance		18.0 Btu/°F

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. number of stacks per module
 - b. number of cell units per stack
 - c. current density
 - d. anode area
- 2. When attempting to match predicted results with experimental results for the same cell configuration, the following parameters should be varified:
 - a. current and voltage efficiency
 - b. stack voltage and current
 - c. cell dimension
 - d. heat transfer characteristics

3. In the sample problem, flow code 4 was used for the streams containing gas and water vapor mixtures. Thus H_2O , O_2 , H_2 , and CO_2 are treated as special flows 2, 3, 4, 5 respectively. When integrating the subsystem into a larger simulation containing additional EC/LS subsystems, it may be desirable to incorporate GPØLY logic to provide a suitable interface with components using flow code 3. Thus, O_2 should be transferred to R(10), H_2O to R(6), and CO_2 to R(12).

2.8 MOLTEN CARBONATE

2.8.1 Process Description:

The molten carbonate process is an electrochemical process for reduction of CO_2 absorbed from cabin air. In the basic concept lithium is reduced at the cathode of an electrochemical cell containing a molten lithium carbonate electrolyte. The lithium reacts chemically with carbon dioxide in solution to deposit solid carbon on the cathode surface and to form lithium and oxide ions in the electrolyte. At the anode, the oxide ions are oxidized to gaseous oxygen. Experimental work at Hamilton Standard Division of United Aircraft Corporation has indicated that the electrolysis of pure molten carbonate gives satisfactory results (Reference 8.2). However, its high melting point of 735°C (1,355°F), thus high operating temperatures, requires high temperature materials and associated high heat losses. These conditions also accelerate corrosion of the equipment. A lower melting point composition with similar conversion performance was found to be a eutectic mixture containing 60 percent by volume of lithium chloride and 40 percent Li2CO3. This eutectic mixture has a melting point of 507°C (943°F). The basic concept for the cell is illustrated in Figure 2.8-1.

The molten carbonate process, by accepting air directly from the cabin and reducing its CO₂ to carbon and oxygen, does not require the CO₂ concentration or water electrolysis units needed in other CO₂ management concepts. One of the main design problems of this process concerns the phase separation between the gases and the molten salts, especially in null gravity conditions. Another problem is the removal of carbon deposited on the cathode. Molten carbonate units may use disposable cells that are discarded after a specified quantity of carbon has been deposited on the cathode (Reference 8.2). A porous matrix, made of sintered magnesium oxide, is used as the cathode. When wetted by the melt, a stable interface is formed in the matrix because of capillary surface tensions. The matrix should be dense enough to hold the electrolyte in place under all gravity conditions, yet sufficiently porous to allow ion mobility and an efficient process. A screen (the anode) surrounds the electrolyte and the matrix. The anode screen and cathode matrix are held together by a metal diaphragm which deflects to accommodate the carbon deposited in the matrix.

Cell Details -

Figure 2.8-1 is a schematic of a molten carbonate electrolyte cell. Electrolytic and chemical reactions at the electrodes are shown on the figure. The net electrolytic reaction is

4 Li⁺ + 20 → 4 Li + 0₂




FIGURE 2.8-1 MOLTEN CARBONATE CELL




FIGURE 2.8-2 SCHEMATIC OF CELL REACTIONS FOR MOLTEN CARBONATE CELL

The theoretical cell voltage including CO, partial pressure gradient effects is

E = 1.025 -
$$\frac{RT}{4F}$$
 ln $(\frac{P_{CO_2,C}}{PO_2,a)(PCO_2^2a)}$

This voltage applies to a cell where water vapor reactions have been eliminated by pre-drying the cabin air prior to entering the cell. Actual required cell voltage will be higher due Joule heating losses and electrode overvoltage.

The required electrolysis current assuming 100% current efficiency is given by Faraday's law

$$I = 1100 \frac{\text{amp-hours}}{10}$$

Other reactions will occur in the cell under certain conditions. The cathode region must be shielded to prevent ${\rm CO}_2$ from reacting with deposited carbon to form carbon monoxide (CO) since this gas is toxic if generated in significant amounts. Another possible side reaction is the hydrolysis of LiCl to form HCl. Experimental results indicate that this side reaction may be ignored.

The level of water vapor in the gas feed can have a significant effect on cell reactions. For feeds with high water vapor pressure, the oxide ion (0=) concentration is inversely proportioned to the water vapor pressure. For a feed with little water vapor, the oxide ion concentration is inversely proportional to the carbon dioxide partial pressure. Since the main function of the cell is to decompose CO₂, water vapor partial pressure of the electrolyte must be made equal to the vapor in the process gas.

Water vapor pressure level also has an effect on cell voltage. At a given water vapor level, the potential between the cell electrodes will vary linearly with the logarithm of CO₂ pressure ratio between the electrode. The slope of this relationship was found to change when the level of water vapor in the feed goes from a relatively small amount to a relatively high amount.

Methane and hydrogen contamination also have been detected at the cathode. These gases may form due to side reactions involving water vapor and the carbon deposited

on the cathode. These reactions provide an additional reason for cathode shielding to prevent intermixing of these contaminate gases with the purified gas leaving the cell.

Contamination of oxygen generated at the anode with ${\rm CO}_2$ may occur if there is insufficient ionic diffusion to replenish oxide ions oxidized. Where ionic diffusion is insufficient chemical equilibrium will be shifted to generate ${\rm CO}_2$ and the required oxide ions form ${\rm CO}_3$. This adverse reaction may be eliminated by limiting the current density to a value which allows sufficient ionic diffusion.

Several alternate compositions have been investigated for the melt (Reference 8.2). Melts using sodium, potassium or barrium salts in place of lithium, and lithium fluoride in place of lithium chloride are examples of alternatives studied. Generally, the alternatives yield inferior performance. However, the optimum melt composition probably is not defined at this time.

2.8.2 Simulation of Concept

Figure 2.8-3 illustrates the components and subroutines required for simulating a molten carbonate concept. The concept illustrated shows a silica gel bed for predrying the process gas. While elimination of water is not a requirement, some means is required to regulate inlet gas water vapor partial pressure to match the electrolyte water vapor pressure. A humidifier also could be used to achieve this control.

The cabin air process gas is circulated through the subsystem by blower component 2 (FAN). Air then flows to valve component 8 (SPLIT) where a portion is allowed to bypass the subsystem. Flow then passes through silica gel bed component 3 (ADSORB). Cooling fluid from component 12 is used to remove heat generated by absorption of water vapor. Component 3 and 7 operate in a cyclic fashion with one adsorbing while the other is desorbing. The source of liquid flow to these components changes as the components switch operating modes. After being dried in the silica gel bed, air flows to valve component 13 (SPLIT) which regulates the amount of air flowing to regenerative heat exchanger component 4 (ANYHX). The heat exchanger serves the dual function of preheating process air above the freezing point of the carbonate cell melt and of cooling outlet air sufficiently before return to the cabin.

FIGURE 2.8-3 G189A SIMULATION OF MOLTEN CARBONATE CONCEPT

Automatic controller component 10 (SERVO) is used to control cell temperature by regulating the amount of process gas bypassing the regenerative heat exchanger. Cell internal heat generation will vary with fluctuations in cell current and voltage. These fluctuations arise from regulation of cell operating conditions in response to cabin CO_2 concentration. Another automatic controller, component 9 (SERVO), is used to control cell current. Since CO_2 generation is a function of metabolic activity in the cabin, precise current control is necessary to match CO_2 decomposition with the generation rate. Both controllers have "proportional position" controller action.

Process gas passes into molten carbonate component 5 (MLCARB) where absorption and reduction of CO₂ occurs. The oxygen generated is collected in accumulator component 6 (TANKG) for use by the atmospheric supply subsystem. The purified process air passes back through regenerative heat exchanger component 4 to desorbing silica gel component 7 (ADSORB). Water vapor previously absorbed is driven off by heat supplied by heating fluid from component 12. Having been re-humidified, the purified air stream then returns back to the cabin.

2.8.3 Sample Problem

Description -

A sample problem was prepared simulating the molten carbonate concept illustrated in Figure 2.8-3 and described in the previous subsection. The cell module which is sized for 6 men is assumed to consist of 19 cells connected electrically in parallel. The temperature controller has a set point of 1022 for cell temperature with a throttling range of 950 to 1100°F. The current controller has a set point of 0.35 mm Hg with a throttling range of 25 to 35 amps. This corresponds to a CO₂ 90% removal efficiency for the cell.

Assumptions -

1. Gas from cabin (air)

Flow

Dry - CO, free constituents	81.03 lb/hr
co	.492 lb/hr
H ₂ O vapor	.766 lb/hr
_	82. 288

Relative humidity = $50\% \sim 0.0094$ lb H₂0/lb dry air CO₂ partial pressure = 3.0 mm Hg

Temperature = 75° F

Pressure = 760 mm Hg

2. Adsorbing/Desorbing Silica Gel Bed

Heat exchanger effectiveness	0.85
Average steady state bed loading	.05 lb H ₂ 0/lb dry
Heat of adsorption (water vapor)	1062 + .432 T (°F)
Bed frontal area	1.0 ft ²
Bed length	1.8 ft

bed

Superficial surface area per volume bed	507 ft ² /ft ³
Void fraction of the packed bed	0.4
Specific heat of adsorbent	.22 Btu/lb-°F
Bulk density of adsorbent	45 16/ft ³
Mass transfer coefficient:	
during absorption	.01 lb/hr-ft ² mm Hg
during desorption	
Mass of coolant in heat exchanger	1 16
Initial conditions (absorption)	
H ₂ 0 loading	.05 1b/1b
Bed temperature	75 °F
Adsorbate exit partial pressure	$1.0 \times 10^{-12} \text{ mm Hg}$
Initial conditions (desorption)	
H ₂ 0 loading	0.1 16/16
Bed temperature	75. °F
Adsorbate exit partial pressure	20. mm Hg
Cooling fluid data (absorption)	
Inlet temperature	38°F
Specific heat	1.0 Btu/°F
Viscosity	3.90 lb/ft-hr
Flowrate	100. 15/hr
Fluid: water	
Heating fluid data (desorption)	
Inlet temperature	200 ° F
Specific heat	1.0 Btu/°F
Viscosity	.740 lb/ft-hr
Flowrate	100. lb/hr
Fluid: water	

Blower Characteristics

Heat dissipated into air

60 watts

4. Regenerative Heat Exchanger Characteristics

Effectiveness .97

Design outlet temperature, primary side 550°C (1022°F)

5. Molten Carbonate Cell

UA between surface of insulation 0.5 Btu/hr-°F

and ambient gas

Ambient wall temperature 70°F

Thermal conductance of insulation .5 Btu/hr-°F

Cell current 30.0 amps

Cell voltage 2.35 volts

Cell thermal capacitance 75. Btu/°F

Cell temperature (estimated) 1022, °F

Number of parallel cells 19

6. Oxygen accumulator Tank

Volume 2.0 ft³

Overall thermal conductance to

surroundings 2.0 Btu/hr-°F

Initial pressure 14.7 psia

0₂ use rate 0.5 lb/hr

Initial mass oxygen 1. fraction

7. Current controller

Action: proportional position

Dead band: .01 mm Hg Set Point: 0.35 mm Hg

Throttling range: 25-35 amps

Sensor time constant: 0.1 sec

Maximum speed of FCE: 0.1 sec⁻¹

8. Temperature Controller

Action: proportional position

Dead band: 1°F

Set point: 1022°F (550°C)

Throttling range: 950 to 1100°F Sensor time constant: 0.1 sec

Maximum speed of FCE: 0.1 sec⁻¹

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. number of cells per module
 - b. cell current
 - c. electrode area
- 2. When attempting to match predicted results with experimental results for the same cell configuration, the following parameters should be varified:
 - a, current and power efficiency
 - b. cell dimensions
 - c. heat transfer characteristics
 - d. cell current and voltage

2.9 MEMBRANE DIFFUSION

2.9.1 Process Description:

Concentration by membrane permeation is a mass transfer process accomplished by a partial pressure difference and selective diffusion. The degree of separation is dependent on the difference in transfer rates of the component gases across the membrane. Membranes have been developed that yield a separation of 99% pure CO₂.

The membranes are packaged in multiple layers with intervening backing screens. The supply gas or "feed" gas is forced laterally through every other screen and "sweep" gas for removing outlet CO₂ flow is forced through the alternate screens. The individual parallel passages for feed and sweep gas streams in the multiple layer configuration are manifolded together. Figure 2.9-1 from Reference 9.8 shows a representative multiple layer configuration. Figure 2.9-2 is a schematic representation of the design of a module.

Low pressure steam (15 mm Hg) is used as the sweep gas. The outlet CO_2 is absorbed in the steam. The CO_2 is removed from the water vapor in a condensing heat exchanger and it is subsequently pumped into an accumulator or is evacuated to space. The condensed water is revaporized for use as sweep gas.

The critical parameter is the permeability which has units of:

Increasing the CO₂ pressure differential reduces the mass transfer area and this, in turn, directly reduces the weight and volume of the packaged module. In Reference 9.8 the CO₂ inlet pressure was increased from 7.6 mm Hg to 35.8 mm Hg through compressing the feed flow total pressure from 258 to 760 mm Hg. This procedure is feasible when the cabin pressure is much less than 1 atmosphere. The membranes tested in Reference 9.8 were subjected to pressure differentials of 1 atmosphere or less. Some difficulties in maintaining satisfactory seals, preventing pinholes leaks, and preventing scoring of membranes by the backing screens were experienced at pressure differentials of 1 atmosphere. The bubble point for the membranes was over




FIGURE 2.9-1 MEMBRANE MODULE




FIGURE 2.9-2 MEMBRANE DIFFUSION MODULE

30 psi so 15 psi pressure differential was considered to be safely below the maximum allowable pressure differential. When cabin pressures are high the CO₂ pressure could again be increased by compressing the feed gas providing a membrane can be developed which would successfully withstand the resulting pressure differential. This technique would require that the membrane module be constructed as a pressure vessel. Preliminary calculations have indicated that for total pressures up to 10 atmospheres the weight of the pressure shell is only of the order of 10% of the basic membrane module.

2.9.2 Membrane Description and Cell Details

The degree of separation (CO_2 removal) is dependent on the difference of transfer rates and pressure differential of the constituent gases across the membrane. The rate controlling mechanism is a flow conduction process involving the adsorption and solution of a constituent, diffusion of solute through the barrier under a concentration potential (pressure differential), and desorption and evaporation of solute from the surface. One well known membrane is silicone rubber which combines high CO_2 permeability and high CO_2/O_2 separation factor (ratio of CO_2 permeability to O_2 permeability) of 5.5. However, for a practical CO_2 removal system, this separation factor is inadequate.

Highly effective, immobilized liquid membranes that yield a $\rm CO_2/O_2$ separation of 99 + % were developed. Initially, an immobilized liquid film was made by containing a 1 to 2 mil porous Dacron mat impregnated with saturated $\rm CsHCO_3$ solution backed by silicone rubber membranes. However, it was found that the caustic $\rm CsHCO_3$ solution attacked the silicone rubber causing pinholes to develop, resulting in cross-membrane leaks and a low separation factor. In place of the rubber membrane, a microporous, hydrophobic film manufactured under a trade name "Solvinert" by Millipore Corporation was found to be effective in providing a method for immobilizing the liquid film. The Solvinert film is unaffected by the aqueous salt solutions used and the bubble point of liquid impregnated silicon (the pressure required to blow the liquid through the pores of the film) was in excess of 30 psi.

Since the membrane consists of saturated $CsHCO_3$ solution backed by the Solvinert filters, it is desirable to operate the sweep side of the package with a water vapor sweep stream at a total pressure equal to the equilibrium vapor pressure of the aqueous solution. This enables recovery and reuse of both constituents of CO_2-H_2O sweep stream, a necessity for long term missions. In addition, the air at the feed side should be water saturated to prevent the drying of the feed side of the membrane and pinhole leaks developing.

A CO₂ scrubber using the Solvinert membranes with a projected packaging density of 440 Ft²/Ft³ was developed for the Air Force Flight Dynamics Laboratory. The membranes were packaged in multiple layers with intervening backing screens. The supply gas or "feed" gas is forced laterally every other screen (Figure 2.9-1). A summary of membrane and screen details is given below:

Membranes:

Feed Gas Screens:

Millipore Corporation "Solvinert" films
Microporus, hydrophobic film, pore size 20µ
porosity 70%, thickness .005 in, impregnated
with aqueous CsHCO₃/NaAsO₂ solution:

6.4 M CsHCO₃, 99.9% pure .25 M NaAsO₂

1% to 2% by volume polyethylene glycol

PE 400 polyester monofilament screens, thickness

.013 in., 400 mesh openings, 47% open area

Sweep Gas Screens: PE 1120 polyester monofilament screens, thickness .024 in., 120 mesh openings, 58% open area

2.9.3 Simulation of Concept:

The G-189 simulation of the CO_2 removal system using the membrane diffusion concept is shown schematically in Figure 2.9-3. Inlet air, defined by a dummy component (component 1) is forced to a condensing heat exchanger for humidity control (component 3) by a high pressure fan simulated by subroutine FAN, Component 2, simulating a compressor. As the air passes through the membrane module (component 4), a portion of the CO_2 permeates the membrane to the "sweep" side of the module which is using steam as the sweep gas. The purified air is returned to the cabin. The CO_2 that permeates — through the membranes is pumped along with the sweeping water vapor stream to a condenser-separator, component 6, for $\mathrm{H}_2\mathrm{O}/\mathrm{CO}_2$ separation.




FIGURE 2.9-3 G189A SIMULATION OF MEMBRANE DIFFUSION CONCEPT

The CO_2 is then pumped by component 7, simulated by PUMP, to the CO_2 accumulator which is simulated by subroutine TANKG, component 8.

The condensed water from both condensing heat exchangers, components 3 and 6, is removed and summed by the new subroutine, H2ØSUM, "The Water Summation Subroutine". This subroutine sums condensate flow from up to 5 condensing heat exchangers and determines the mix temperature of total flow.

A method for adding makeup water for this CO₂ removal system is provided by component 10, LIQMIX, by providing for H₂O flow from the water supply subsystem. The makeup water from water supply will be added as required, to the H₂O accumulator, component 11, to maintain a relatively constant H₂O level in the H₂O accumulator. The required rate of addition will be determined by GPOLY logic. Component 12, simulating an H₂O pump, provides constant water flow from the accumulator to the steam generator, component 13. The steam generator is simulated by a new subroutine SMGEN. SMGEN is used to supply superheated steam for use in various EC/LS subsystems such as the CO₂ removal system utilizing the membrane module.

A new subroutine was written to simulate component 4, membrane module. This new subroutine, MEMOD, models the mass and thermal balance of a membrane module which would have gases of different concentrations flowing through the modules two sides.

2. 9.4 Sample Problem

Description -

A sample problem simulating major components of the CO_2 removal system utilizing the membrane diffusion concept has been prepared for the performance analysis of the system. The inlet conditions of the sample problem, shown schematically in Figure 2.9-3, are defined by a dummy component simulating cabin air flow to the system. A compressor is used to pressurize the air to 30psi in order to provide sufficient CO_2 pressure differential to obtain adequate separation. The data defined by the dummy component include total flow, cabin temperature, cabin pressure, non-condensable, condensable vapor flow, entrained liquid flow, non-condensable specific heat, non-condensable molecular weight, oxygen flow, diluent (N_2) flow, and CO_2 flow. The input values to the first component are derived from assumptions defining cabin air conditions. The inlet conditions along with performance of the whole system are used in deriving the design parameters of individual components of the system.

Assumptions -

1. The cabin air conditions are as follows:

Dry bulb temperature	70°F
Wet bulb temperature	60°F
Cabin pressure	14.7 psi
Partial pressure CO2	3.0 mmHg
0 ₂ pressure	3.1 psi
CO ₂ generation/removal rate per men	.1 lb/hr-man
Number of men	6

Reference 9.8 provides data for a "Solvinert" film membrane module, giving CO₂ removal rate of a one man system for the following operating conditions.

Feed flow (Air)			30 liters/min
Temperature		٠	80. °F
Pressure			760 mmHg
CO, pressure			22.8 mmHg

Sweep flow (steam)

Temperature

Pressure

60 liters/min

80°F

26 mmg/Hg

Membrane Area

21 sq-yds.

Computing the removal efficiency of the system from the above data we determine the required volumetric flow (2490 ft³/hr) from which we compute the flows of individual constituents to the system defined as inputs to component #1.

Total flow (lb/hr)	184.64
Temperature (°F)	70.
Upstream duct outlet pressure (PSI)	14.7
Component outlet pressure (PSI)	14.7
Non-condensable flow (lb/hr)	182.60
Condensable vapor flow (lb/hr)	2.041
Non-condensable specific heat (Btu/lb-oF)	.24
Non-condensable molecular weight (lbs/mole)	28.97
Oxygen flow (lbs/hour)	48.96
Diluent (N2) flow (lbs/hour)	138.0
CO ₂ flow (lbs/hr)	1.103

2. The air compressor, simulated by subroutine FAN, pressurizes the air to 30 psi via GPOLY logic. The pressurization process is assumed to be approximately isentropic and with consideration for heat loss to surroundings the outlet temperature is raised accordingly. No other inputs are required for the component.

3. Process Air Condensing Heat Exchanger Characteristics:

Overall UA (BTU/hr-°F)	75.
NTU (Max)	5.0
Design outlet temp, primary side (°F)	80.0
Tolerance for design temp, primary side (°F)	5.

The secondary flow is provided by component #23 with inlet conditions defined by the following.

Flow rate (lb/hr)	60.
Temperature (°F)	38.
Upstream duct pressure (psi)	15.0
Component outlet pressure (psi)	15.0

The physical properties of the coolant (water), are listed as follows:

Specific heat (Btu/lb-°F)	1.0
Viscosity (lb/hr-ft)	3.6
Density (1b/Ft ³)	62.4
Molecular weight (lb/mole)	18.0
Conductivity (Btu/hr-ft-oF)	.325

The physical properties listed above also apply to coolant flow from component 26 which is used to provide secondary flow to component 6.

4. CO2 Concentrator (Membrane Separator) Characteristics

The separation, and thereby removal of CO₂ from cabin air stream is accomplished by component #4, the membrane module. The component is simulated by the new subroutine MEMOD with the required input being as follows:

Number of membranes	940
Heat loss to surrounding data:	
Ambient gas temperature (°F)	70.
Thermal conductance between surface	1.3
and ambient (Btu/hr-°F)	
Ambient wall temp (°F)	60.
FA factor for radiation conductance (Ft2)	6.
Structure temp (°F)	60.
Conductance between module and structure	12.
Steady state data input required	
Membrane area per cell (Ft ²)	2.
Thickness	.005
$\frac{\text{CO}_2}{\text{(Ft}^2) \text{ (mmHg)}}$	1.2 x 10 ⁻⁵
Transient data input	
Frontal area, primary side (Ft ²)	.1
Frontal area, secondary side (Ft ²)	.1
Module length (Ft)	2.
Thermal capacitance of module shell, Btu/oF	12.0

5. CO_2/H_2O Condenser/Water Separator Characteristics

Overall UA (Btu/hr-oF)	460.
NTU (Max)	5.
Primary outlet design temp (°F)	42.
Design outlet temp tolerance (°F)	2.

The secondary flow to the condensing heat exchanger is provided by a dummy component, 26, simulating coolant flow to the heat exchanger. The flow from component 26 is specified as follows:

Flow rate (lb/hour)	270.
Temperature (°F)	35.
Pressure (Psi)	15.

6. CO₂ Accumulator Characteristics

Total fluid weight in tank (lbs)	. •5
Fluid temp in tank (F°)	70.
Fluid volume in tank (Ft3)	1.
Fluid pressure in tank (Psi)	14.7

7. Steam Generator Characteristics.

Flowrate (lb/hr)	6.5
Pressure	1.0
Temperature (°F)	120
Desired degrees of superheat (°F)	20.

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. number of membrane cells
 - b. membrane area per cell
- 2. When attempting to match predicted results with experimental results for the same cell configuration, the following parameters should be varified:
 - a. constituent permeabilities
 - b. cell dimensions
 - c. heat transfer characteristics

2.10 MECHANICAL FREEZOUT

2.10.1 Process Description

This process precipitates out the ${\rm CO}_2$ from cabin air that is passed through a heat exchanger. In its simplest form, cabin air is passed through a heat exchanger which removes thermal energy thus reducing the temperature. At some point, the ${\rm CO}_2$ will begin to precipitate and the noncondensable cabin air which will become relatively free of ${\rm CO}_2$ may then be recycled. In the range of ${\rm CO}_2$ partial pressures encountered, carbon dioxide begins to precipitate at $-125^{\circ}{\rm C}$ (PPCO $_2$ = 5.0 mm Hg, saturated) and its removal will practically be total at $-140^{\circ}{\rm C}$ (PPCO $_2$ = 0.43 mm Hg, sat.). Water is assumed to be completely removed using the silica gel bed upstream of the precipitation of the carbon dioxide.

Several carbon dioxide removal systems utilizing the freezout concept have been proposed; however, only the two more practicable systems will be presented here. The first system, shown in Figure 2.10-1, uses precipitator/sublimator coupled to a very cold space radiator to remove the CO₂; the second system, shown in Figure 2.10-2, requires the use of a refrigeration system. The space radiator and the refrigeration system are necessary in both cases for thermal energy removal to account for the inefficiencies of the regenerative heat exchangers that are being utilized and the heat flux from the surroundings into the system. Both systems use a water condenser for humidity control, and a silica gel bed for predrying the cabin air before passing it through the regenerative heat exchanger. It is imperative that the air be dried prior to its passage into the regenerative heat exchanger to prevent the buildup of frost which would deteriorate its performance.

The CO₂ removal system which utilizes the precipitator sublimator, hereby referred to as the P/S system, will be considered to be an open system. Its operation predicates the simultaneous precipitation and sublimation of CO₂ frost. For sublimation to occur, the CO₂ frost must be exposed to the vacuum of space. In the simultaneous precipitation and sublimation, the heat of

FIGURE 2.10-1 MECHANICAL FREEZE-OUT SYSTEM, NON-RECOVERABLE CO2




FIGURE 2.10-2 MECHANICAL FREEZE-OUT SYSTEM, RECOVERABLE CO2.

precipitation supplies the thermal energy required for the sublimation to space. However, to account for the inefficiency of the regenerative heat exchangers and the heat influx into the ${\rm CO_2}$ removal system due to pipe connectors and supports, a method for removal of thermal energy must be included. Two methods for the removal of thermal energy have been proposed. The first method described in Reference 10.6 through 10.7 uses cryogenic ${\rm O_2}$, ${\rm N_2}$ or ${\rm H_2}$ to remove the heat to make the system operational. The second method employs a low temperature radiator to reject the heat from system to drive the precipitation sublimation process. This method, described in References 10.1, 10.5, and 10.6, relies on the ability to design a radiator that operates at -250°F which presently does not appear feasible.

The Mechanical Freezout System-Recoverable CO₂, shown in Figure 2.10-2, uses a refrigerant to chill the cabin air flowing through the precipitation channel. This type of system minimizes the total vehicle weight penalty at the expense of an increase in required power input. For long-duration space missions, studies have shown (Reference 10-7) that the reversed Brayton-cycle system offers the most desirable method for heat removal. The reversed Brayton cycle system offers the following advantages with respect to the other systems:

Employs a single phase fluid and thereby its operation is simpler and more flexible than the Claude cycle.

The entire expansion occurs in a turbine, thus allowing high temperature operation which is more efficient.

In addition, the system has potential for long-duration maintenancefree operation.

The use of the hotter compressed gas in the refrigerant system to sublime the CO₂, as shown in Figure 2.10-2, affords a method for the recovery of the precipitated CO₂ without the use of deep space vacuum (thermal sublimation). In addition, more positive control of the precipitation and sublimation processes is provided.

2.10.2 Simulation of Concept

The simulation of the mechanical freezout concept is performed by dividing the subsystem into major functional components which may be mathematically modeled by G-189A component subroutines.

Figure 2.10-3 shows the G-189 component connection and definition diagram which was prepared for the analysis of the subsystem. Dummy component 1 (subroutine ALTCOM) is used to define the inlet conditions (flowrate, temperature, humidity, CO₂ partial pressure, constituency, etc.) to the subsystem.

A H₂O condenser, component 2 (ANYHX), is used in comjunction with a silica gel bed, component 3 (ADSØRB), to dry the air sufficiently to prevent H₂O freezeout in the CO₂ precipitating heat exchanger, component 6. Dummy component 12 (ALTCOM) provides the coolant to the condensing heat exchanger at a specified temperature and flowrate. The condensate is pumped by component 17 (PUMP) to a water storage tank, simulated by component 18 (TANKG).

The dehumidified air from the silica gel bed passes through a switched off heater, component 4 (ALTCOM), to regenerative heat exchanger, component 5 (ANYHX). Here the air is pre-cooled prior to entering the CO₂ precipitator. The secondary flow for this component is the effluent from the precipitator heat exchanger.

The precipitator heat exchanger, component 6, is simulated by a modified version of subroutine ANYHX. A new subroutine, CO2CP, has been added to the program to simulate the CO₂ precipitation process in the heat exchanger component. In addition to determining the amount of precipitation, this subroutine determines the effective specific heat of the process air entering and leaving the precipitator. Refrigerant flow to the precipitator is supplied by dummy component 16 (ALTCOM).




FIGURE 2.10-3 G189A SIMULATION OF MECHANICAL FREEZE-OUT 116

Air flow from the precipitator is circulated by fan component 7 (FAN) back through the regenerative heat exchanger to heater component 8 (ALTCØM) and desorbing silica gel bed component 9 (ADSØRB). The heater component provides the thermal energy required to force water vapor desorption in the silica gel bed.

The sublimation of CO_2 is simulated with component 10 (ANYHX). The rate of sublimation is assumed to equal the rate of precipitation in component 6. This rate, which is the difference between the flow of CO_2 in and out of the precipitator, is calculated by GPØLY logic. Dummy component 19 is used to supply CO_2 to the sublimator at a rate equal to the sublimation rate. Component 10 calculates the amount of heat absorbed in sublimating the solid CO_2 . This energy is removed from heating fluid circulating through the sublimator. The heating fluid, which is assumed to be gaseous nitrogen is supplied by component 11. The CO_2 sublimated is pumped by component 14 (PUMP) to CO_2 accumulator component 15 (TANKG).

Because of the cyclic operation of the system, components 3 and 9, 4 and 8, and 6 and 10 alternately switch functions according to a pre-determined time sequence. Logic is incorporated in GPØLY to change the order of solution path, modify sources of flows, and perform other miscellaneous operations when the switch of functions occurs.

2.10.3 Sample Problem

Description -

A sample problem, simulating the major components of the mechanical freezout system, was prepared for the performance analysis of the system and to provide insight to the sizing and power requirements of the system. The inlet conditions of the sample problem are defined by a dummy component simulating cabin air flow to the system shown in Figure 2.10-3. The required inlet conditions include the following: total flow, fluid temperature, upstream duct outlet pressure, component outlet pressure, non-condensable flow, condensable vapor flow, condensable entrained liquid flow, non-condensable specific heat, non-condensable molecular weight, oxygen flow, diluent flow, and CO_2 flow. The assumptions made for determining the inlet conditions and performance characteristics of the individual components of the subsystem are presented below:

Assumptions -

1. The cabin air conditions, which define the data for component #lasre as follows:

Dry bulb temperature	70 ° F
Wet bulb temperature	60°F
Pressure	14.7psi
0 pressure	3.lpsi
Partial pressure CO2	3.5 mmHg
CO2 generation/removal rate per man	.1 lb/hr man
Number of men	6 1

The weight flowrates for O_2 , N_2 , CO_2 , and H_2O through the mechanical freezout system are derived from the required volumetric flow. The volumetric flow is calculated from the following relationship:

$$Q = \frac{W_{c}N \times R_{co_{2}} \times T}{E_{p} \times PPCO_{2}}$$

Q = Required volumetric flowrate, CFH

 R_{CO_2} = Universal gas constant for CO_2 , 35.12 ft/ $^{\circ}$ R

T = Cabin temperature, 530°F

PPCO₂ = Partial pressure of CO₂, 3.0mm Hq

Wc = $\frac{1}{2}$ generation/removal rate per man 1b/hr man = 2.3 $\frac{1}{m}$

N = Number of men

 $E_{\rm p}$ = Precipitation efficiency, 0.9 $\equiv \frac{{\rm C_i - C_o}}{{\rm C_i}}$

The given inlet conditions and the computed volumetric flow were used to calculate the following items:

Total flow	111.6 lb/hr
Temperature	70.0 °F
Upstream duct outlet pressure	14.7psi
Component outlet pressure	14.7psi
Non-condensable flow	110.43 lb/hr
Condensable vapor flow	1.17 lb/hr
Condensable entrained liquid flow	0. lb/hr
Non-condensable specific heat	.24 Btu/lb-°F
Non-condensable molecular weight	28.97 lbs/mole
0 ₂ flow	29.35 lbs/hour
No flow	80.41 lbs/hour
No flow	.66 lbs/hour

2. The required data input for component 2, a condensing gas-liquid heat exchanger are given below:

Overall UA = 93.5 BTU/hr-°F

NTU (MAX) = 3.0

Design outlet temp for primary side = 45°F
Tolerance for primary side outlet temp = ±3°F

The inlet conditions of secondary flow or coolant are as follows:

Flowrate = 270 lb/hr
Temperature = 38 °F
Upstream duct pressure = 15.0 psi
Component outlet pressure = 15.0 psi

The physical properties of the coolant (water), are listed as follows:

Specific heat

Viscosity

Density

Molecular weight

Conductivity

1.0 b/lb-°F

3.6 lb/hr-ft

62.4 lb/ft

18.0 lb/mole

325 Btu/hr-ft-°F

These values apply to flows from components 12, 13, and 21

3. Subroutine ADSORB is used to simulate the silica gel beds, component 3,

for the adsorption of H₂O vapor from the process air. The required inputs for subroutine adsorb are as follows:

.85 (1b H₂0 Heat exchanger effectiveness, & .055 (1b bed Average steady state bed loading Heat of adsorption (water vapor) 1062 + .432T1.0 ft² Adsorption bed frontal area 1.8 ft 507 ft²/ft³ Adsorption bed length Superficial surface area per volume bed Void fraction of the packed bed .4 Specific heat of bed material .22 Btu/lb-oF 45. 1b/ft³ Bulk density of bed material .01 lb/hr-ft2mmHg Mass transfer coefficient 4 lbs Mass of coolant in heat exchanger Init. value adsorbate gas pressure 1.0 X 10-12 mmHg Init. value bed loading (1b adsorbate/1b bed) 1.0 X 10 -12 mmHg Carrier gas outlet temperature 45°F 40°F Adsorbent bed temperature 40°F Liquid coolant outlet temperature

The coolant flow (secondary) for the silica gel beds is provided by component #13. The coolant inlet conditions are as follows:

Flowrate	= 270. lb/hr
Temperature	= 38. °F
Upstream duct outlet pressure	= 15.0 psi
Component outlet pressure	= 15.0 psi

- 4. No inputs are required for component 4, a turned-off heater simulated by a dummy subroutine ALTCOM. Subroutine ALTCOM passes data from component 3 to 5 unchanged.
- 5. Component 5, regenerative heat exchanger, is simulated by subroutine ANYHX.

 It is a gas-gas counterflow heat exchanger that uses the primary temperature as the criterion for sizing. The required V-array data for the regenerative heat exchanger are as follows:

Overall UA (Estimate)

NTU (Max)

Design outlet temperature, primary side

Tolerance for design outlet temp.

210. Btu/hr-°F

5.0

-190. °F

± 3.°F

The secondary flow (coolant) for the regenerative heat exchanger is supplied by the precipitator heat exchanger, component 6. Therefore, initial values of the outlet flow must be made for component 6. The values given as follows:

Total flow	109.1 lbs/hr
Temperature	-220.0 °F
Upstream duct outlet pressure	14.7 psi
Component outlet pressure	14.7 psi
Non-condensable flow	109-1
Non-condensable specific heat	.24 Btu/lb-°F
Non-condensable molecular weight	28.97 lbs/mole
Oxygen flow	29.35 lb/hr
Diluent flow	80.41 lbs/hr

6. The precipitator heat exchanger, component 6, is simulated by the subroutine ANYHX. Dry process air enters the heat exchanger at≈-190°F and is chilled down to -223°F causing the precipitation of CO₂ to occur thus removing it from the gas stream. The required data are as follows:

Overall UA	35 Btu/hr-oF
NTU (Max)	3.0
Design outlet temperature, primary side	-223°F
Tolerance for design temperature	± 3°F

The coolant (Secondary) flow to the precipitator heat exchanger is provided by component 16. The flow inlet conditions are defined as follows:

Total flow	45.0 lbs/hr
Temperature	-280.0 °F
Upstream duct outlet pressure	20 psi
Component outlet pressure	20 psi
Non-condensable flow	45.0 lbs/hr
Non-condensable specific heat	.239 B/1b-°F
Non-condensable molecular weight	28.0 lbs/mole

The physical properties of the refrigerant, (cold nitrogen is assumed) are as follows:

Specific heat	.239 Btu/lb-°F
Viscosity	.036 1b/hr-ft
Density	.16 1b/ Cu ft
Molecular weight	28.0 lb/mole
Conductivity	.007 Btu/hr-ft-°F

7. The blower, component 7, which forces the air through the mechanical freezout system is simulated by subroutine FAN. The component is simulated only to the extent that heat is added to the gas stream. The required V-array input is as follows:

Heat added to gas stream

100 watts

8. The heater component 8, which is used for heating the air for desorption of the silica gel bed is simulated by a dummy component subroutine ALTCOM. The subroutine computes the outlet temperature of the gas stream due to the heat added. The required V-array input is as follows:

Heat load to cooling fluid

1535 Btu/hr

- 9. The desorption of silica gel beds, component 9, is simulated by subroutine ADSORB. This component has the same input data requirements
 as component #3 exclusing parameters that pertain to coolant flow.
- 10. Components 17 and 18 simulate the water pump (PUMP) and water accumulator (TANKG) respectively. The pump receives its flow from a dummy component, component #21, which defines the fluid pressure, flowrate, temperature, and physical properties. The fluid inlet conditions are as follows:

Flowrate	67 lb/hr
Temperature	45.0°F
Upstream duct pressure	14.7 psi
Component outlet pressure	14.7 psi

The pump is simulated only to an extent that heat is added to the fluid stream. The amount of heat added is assumed to be 10% of the electrical input power (20 watts). The condensate reservoir is simulated by subroutine TANKG. The required input data is as follows:

Ambient gas temperature	70°F
Conductance between insulation surface & ambient gas	5. Btu/hr-°F
Ambient wall temperature	60
Thermal radiation FA factor	6.0 Ft ²
Structure temperature	60
Conductance between tank wall and structure	5.0 Btu/hr-°F
Conductance between tank wall and outer surface	.5 Btu/hr-oF
Thermal capacitance and tank shell	2.5 Btu/OF
Maximum allowable temp change per iteration	7 ° F

11. As mentioned in the previous subsection, the rate of sublimation is assumed to equal the rate of precipitation. The amount sublimated is supplied to component 10 as special flow No. 1 from dummy component 19. Since components 10 and 6 alternately switch functions, the data input requirements for 10 and 6 are the same. The assumed conditions for the process heating fluid used to provide thermal energy for the sublimation are summarized below:

Flowrate 45 lb/hr
Inlet temperature -100 °F
Pressure 20. psia

The physical properties for the heating fluid, which is assumed to be gaseous nitrogen, are as follows:

Specific heat

0.239 Btu/lb°F

Molecular weight

28.

Viscosity

0.036 lb/ft-hr

Density

0.16 lb/ft³

Thermal conductivity

0.007 Btu/hr-ft-°F

Special Notes -

- 1. When attempting to match predicted CO₂ removal rate with the desired removal rate, the following parameters may be varied to achieve the desired result:
 - a. precipitator channel coolant flow rate
 - b. process air volumetric flow rate
 - c. precipitator channel heat transfer area
 - d. regenerative heat exchange heat transfer area
- 2. When attempting to match predicted results with experimental results for the same unit configuration, the following parameters should be varified:
 - a. mass transfer coefficients for precipitation and sublimation process
 - b. component characteristic dimensions
 - c. heat transfer characteristics

3.0 CONCLUSIONS AND RECOMMENDATIONS

The subroutines prepared should provide adequate representations of the overall mass and energy balances for the parametric performance of the concepts considered. In preparing the subroutines several areas where additional effort may be warranted are as follows:

- o Determining parametric scaling laws for weight, volume, and power for the ten concepts.
- o Performing laboratory testing of the concepts to fully define subsystem parameters or physical properties.
- o Performing system integration studies for the concepts when coupled with various oxygen regeneration subsystems or complete EC/LS systems.
- o Determining the optimum concept by evaluating the parametric performance of each concept for a wide range of mission, environmental, or operating conditions.
- o Performing reliability and cost analysis studies for the ten concepts.

The above recommendations cover a wide gambit of effort. It is probable that some of the concepts may be eliminated from further consideration and that the major emphasis should be placed on perhaps 4 or 5 of the concepts.

In selecting the optimum subsystem, certain other intangibles must be considered. For instance, the year in which space type hardware could be expected to be available. Problems with contamination, corrosion, impacts on the cabin thermal environment, and safety must be assessed. Also the subsystems compatibility with the spacecraft power system.

In general it can be stated that concurrently with laboratory testing of the concepts, the computer subroutines should be used to model the test conditions. In addition to providing a test of the adequacy of the computer math models, this will allow a better understanding of the test results. It can also be stated that having defined those system parameters which are important to the mathematical models, additional laboratory testing is necessary to verify the values of these parameters. Several specific areas where improvements could be made in the simulation models are presented in the following subsections.

3.1 Steam Desorbed Resins

Additional laboratory testing is necessary to determine CO, and H,0 equilibrium data at temperatures between 180-220°F. This is the temperature range in which ${\rm CO}_2$ is desorbed by steam stripping. The data is required since the rate of mass transfer from the bed to gas is equal to the mass transfer coefficient times the difference between the gas phase partial pressure and the equilibrium partial pressure corresponding to the sorbate bed loading. CO, equilibrium data is required for CO, bed loadings from 0 to 3.5% and $\rm H_20$ bed loadings from 0 to 40%. $\rm H_20$ equilibrium data, which is assumed to be independent of CO2 loading, is required for H2O bed loadings from 0 to 40%. An empirical correlation for overall mass transfer coefficient as a function of operating conditions is also required. Parametric computer runs then should be made to compare subroutine results with test data. The relative importance of interparticle diffusion needs to be assessed. More important, the mechanism for mass transfer should be carefully re-evaluated. Can the mass transfer rate be predicted strictly from the equilibrium data and mass transfer coefficient, or are the effects of chemical reaction kinetics more important? Should the water vapor transfer be calculated on as stoichiometric basis from the amount of CO, desorbed?

Additional testing may be warranted to verify the heats of sorption for ${\rm CO}_2$ and ${\rm H}_2{\rm O}$ on the resin particles. Physical properties for the particles, such as bulk density, void fraction, superficial surface area, specific heat, etc., must be carefully defined. Additional testing also is required for determining the heat transfer characteristics of the bed. In particular, the effective thermal conductivity of the resin material is required. If

the bed contains an integral heat exchanger, the overall thermal conductivity between the heat exchanger/gas or heat exchanger/pellets should be evaluated.

3.2 Vacuum Desorbed Resins

At the present time no equilibrium data is available for Gat-O-Sorb resin which is considered the most promising resin for this concept. Equilibrium data is required for approximately the same set of temperature and bed loadings as for the steam desorbed concept. Data on the physical properties of the resin such as bulk density, superficial surface area, void fraction, etc., also are lacking.

The same general comment made for the steam desorbed resin which called for additional analysis of the mechanism for mass transfer also applies. Additional data also is required for mass transfer coefficients, heat of sorption, and heat transfer characteristics. Since, for this concept, the bed contains an integral heat exchanger, the importance of a careful definition of the heat transfer characteristics should be emphasized.

3.3 Carbonation Cell

The math models for the subroutines used in simulating this concept are relatively unsophisticated. However, additional complexity is most likely not warranted since the concept is generally considered to have been superseded by the hydrogen depolarized cell. Assuming the math models to be adequate, a better definition of cell design characteristics is required for an adequate simulation of the concept. The heat transfer characteristics of a typical cell should be determined. All parameters such as current density and voltage should be correlated as a function of subsystem variables.

Should more sophistication in the math models be desired, an example of where improvements could be made is in the technique for establishing the water transfer rate to the exit streams. Currently the rate is established by fixed input data for relative humidity in the exit streams. A more realistic model could be developed based on the actual transport phenomena

occurring. The math model for predicting water transport rates in the component for humidifying process gas prior to entering the cells also is an example where improvement might be warranted.

3.4 Hydrogen Depolarized Cell

The mathematical model for this subroutine was prepared by Hamilton Standard in conjunction with subsystems development studies for the SSP program.

As such the routine should provide a good representation of the subsystem.

3.5 Solid Electrolyte Cell

A good comparison between subroutine results with test data was obtained for this subsystem. This was possible to a great extent because of the advanced state of development of the concept. Good documentation of subsystem test results also was available (Reference 5.13).

It should be noted that the mathematical model for the solid electrolyte cells is somewhat empirical in nature. That is, the model relies heavily on the experimental data. Overall current efficiency, H₂ or CO current efficiency, cell voltage (or voltage efficiency) are a few of the parameters which are based on experimental results. While theoretical relationships could be developed, they would not be as accurate as the empirical data. In order to insure accurate computer results over a wide range of operating conditions, additional laboratory testing is required to determine correlations for these critical parameters as a function of operating variables.

A more detailed mathematical model for the carbon deposition reactor could be developed by treating the reactor as a classical tubular reactor. Additional experimentation would be required to determine the effects of reactor geometry and catalyzing effects on the kinetics of the reaction. In particular, the catalyzing effects of the reactor steel wall and water vapor in the inlet stream would have to be incorporated into the rate equations. Alternatively correlations could be developed for CO and H₂ conversion efficiencies as a function of operating variables.

3.6 Liquid Absorption

The mathematical models prepared for the simulation of this concept should be adequate for gross system analysis. More complex models are not warranted at this time since the concept is only in a conceptual stage of development. Many problems remain to be solved in designing zero-g hardware.

When the design concept becomes better defined, there are several areas where improvements could be made in the mathematical models. For the liquid contactor, a subroutine could be prepared with a multiple number of bed elements. Transient macroscopic mass and energy balances could be set-up taking into account mass transfer resistances in both the liquid and gas phases.

Another subroutine which might warrant future development would be an air/liquid separator routine. The subroutine would be modeled after zero-g separator devices currently in the state of development. The separation achieved would be predicted from constituent equilibrium relationships and efficiency factors.

The subroutine for the separation of CO₂ from the liquid phase has been modeled as an equilibrium or flash vaporization process. When the design of this device is better defined, the subroutine could be modified to better reflect the operating characteristics of the device.

It is suggested that system analysis studies be performed leading to the development of a space hardware prototype for this subsystem. Improvements to the existing subroutines could be made concurrently with the prototype development.

3.7 Electrodialysis Cells

The subroutine prepared for this concept should provide an adequate simulation of the "E" stack cell configuration described in reference 7.1. For this configuration a considerable amount of oxygen is generated along with the

removal of CO₂. One possible improvement in the routine might be to provide an option for simulating the "F" configuration, which minimizes O₂ production.

The subroutine prepared relies on experimental data for stack voltage, power and current efficiencies. It is suggested that correlations be developed for these parameters as a function of operating variables.

A more sophisticated method for determining the amount of water lost by electro-endosmosis probably is warranted. The current method is based on fixed input values for the humidities in the exit streams. A model based on the physical chemistry of the actual phenomena could be developed and incorporated into the subroutine.

3.8 Molten Carbonate Cells

The subroutine prepared should allow good simulation of molten carbonate cells in which the process air has been pre-dried to prevent water vapor electrolysis and subsequent adverse side reactions. Should future subsystem studies indicate the advisability of developing a cell for combined CO₂ removal and H₂ electrolysis, additional logic would have to be incorporated to simulate the side reactions.

The current subroutine relies on experimental values for power efficiency. Current efficiency is assumed to be 100%. Correlations should be developed for these parameters over a range of operating conditions. While current efficiency should approach 100% for the expected operating conditions, excessive current densities will cause degraded performance.

3.9 Membrane Diffusion

The mathematical model prepared for the diffusion separator should allow a good simulation of this concept. In addition, the subroutine can be used to simulate similar diffusion processes in other subsystems.

The most important parameters, which must be accurately defined, are the permeabilities of the diffusing species. Correlations for permeabilities as a function of system variables should be determined by additional laboratory testing.

3.10 Mechanical Freezeout

No new component subroutines were prepared in order to simulate this concept. A modified version of the heat exchanger subroutine was used to simulate the precipitator and sublimator. The partial pressure of ${\rm CO}_2$ leaving the precipitator is predicted from the equilibrium sublimation curve for ${\rm CO}_2$ and Dalton's law. Mass transfer rates are not considered. The rate of ${\rm CO}_2$ leaving the sublimator is assumed to equal the rate of precipitation. The heat exchanger subroutine calculates the required outlet temperature for the heating fluid necessary to provide the heat of sublimation.

The technique for simulating the precipitation process should provide an adequate simulation. The transient simulation of this process could be improved by preparing a multi-element model with the rate of mass transfer calculated from an overall mass transfer coefficient and the difference between the gas phase partial pressure and the CO₂ equilibrium partial pressure.

The improvements suggested above are even more important for an adequate transient simulation of the sublimator. In order to develop such a model, the design geometry of the precipitator/sublimators must be fully defined. In addition, experimental testing would be required to determine a correlation for mass transfer coefficients as a function of system parameters.

Miscellaneous References

0.1 Contract No. NAS9-12076, Advanced ECT/LSS Computerized Analytical Models, June 28, 1971.

References on Steam Desorbed Resins

- 1.1 Tepper, F.; Vancheri, F.; Samuel, W. and Vdavcak: Development of a Regenerable Carbon Dioxide Removal System. NASA CR-66571 (MSA Research Corporation) Jan 1968.
- 1.2 MSA Research Corporation: Development of System Design Information for Cabron Dioxide Using an Amine Type Sorber. NASA CR-11849, June 1971.
- 1.3 Brose, H. F. and Martin, R. B. Performance of a Solide Amine Carbon Dioxide Concentrator During a 90-Day Manned Test. NASA SP-261, p. 131-144, Nov. 1970.
- 1.4 Jackson, J. K. and Blakely, R. L.: Application of Adsorption Beds to Spacecraft Life Support Systems. DAC Paper No. 4505, presented at SAE Meeting, Los Angeles, Calif. October 1967.
- 1.5 Blakely, R. L. and Taylor, B. N.: Computer Analysis Techniques for Spacecraft Adsorption Beds. DAC Paper 5159, presented at AIChE Meeting at New Orleans, La. March 1969.
- 1.6 Kunii, D. and Suzuki, M.: Particle-to-Fluid Heat and Mass Transfer in Packed Beds of Fine Particles. Int. J. Heat and Mass Transfer, Vol. 10, pp 845-852, 1967.
- 1.7 Treybal, R. E.: Mass-Transfer Operations. McGraw-Hill (1955), pp 453-457.
- 1.8 AiResearch Mfg. Co., Thirty-third Monthly Status Report, August 1, 1971 to August 31, 1971, Contract No. NAS1-8559.
- 1.9 AiResearch Mfg. Co., Thirty-Fourth Monthly Status Report, Sept. 1, 1971, to Sept. 30, 1971, Contract NAS 1-8559.
- 1.10 Jackson, J. K. Heat and Mass Transfer Analysis of Adsorption Beds Used Used in Spacecraft Life Support Systems, 18 Sept 1964, Douglas SM-47721.
- 1.11 Bird, Stewart, and Lightfoot, "Transport Phenomenon", John Wiley, 1960, p. 411.
- 1.12 "Advance ETC/LSS Computerized Analytical Models", 2nd Monthly Progress Report, 16 September 1971, Attachment 1, p. 9 and p. 13.
- 1.13 J. M. Smith, "Chemical Engineering Kinetics", McGraw-Hill Book Co., Inc., 1956, p. 384.

References on Thermal/Vacuum Desorption

- 2.1 Glueckert, A. J., Nuccio, P. P., and Zeff, J. D.: "GAT-O-SORB A Regenerable Sorbent for Carbon Dioxide Control". SAE Paper No. 670844, Aeronautic and Space Engineering and Manufacturing Meeting, Los Angeles, Calif. October 1967 (General American Transportation Corp.).
- 2.2 Glueckert, A. J., Nuccio, P. P., and Zeff, J. D.: GATC Report MRD 1230-4050, Final Technical Report for a Prototype Regenerable Carbon Dioxide Removal System, Contract No. NAS1-2915, MRD Divison General American Transportation Corp., August 1964.

References on Carbonation Cell

- 3.1 Huebscher, R. G. and Babinsky, A.D.: "Electrochemical Concentration and Separation of Carbon Dioxide for Advanced Life Support Systems Carbonation Cell System". SAE Paper No. 690640. National Aeronautic and Space Engineering and Manufacturing Meeting, Los Angeles, Calif., Oct. 1969.
- 3.2 Babinsky, A. D., et al.: Carbon Dioxide Concentration System, NASA CR 72086, July 1966.

References on Hydrogen Depolarized Cells

- 4.1 Brose, H. F.: "Hydrogen Depolarized Cell for a CO₂ Concentrator".

 ASME Paper No. 71-AV-37. SAE/ASME/AIAA. Life Support and Environmental Control Conference (July 1971), San Francisco.
- 4.2 Wynveen, R. A. and Quattrone, P.D.: "Electrochemical Carbon Dioxide Concentrating System". ASME Paper No. 71-AV-21, July 1971.
- 4.3 Kiraly, R. J., Babinsky, A.D. and Power, J. D.: "Aircrew Oxygen System Development, Flight Breadboard System Flight and Environmental Tests". NASA CR-73393 (1970).
- 4.4 Kiraly, R. J., Babinsky, A. D., and Quattrone, P.D.: "On-Board Oxygen Generating System". SAE Paper No. 680716, SAE Meeting, Los Angeles (Oct. 1968).
- 4.5 Quattrone, P. D., Babinsky, A. D., and Wynveen, R. A.: "Carbon Dioxide Control and Oxygen Generation". ASME Paper No. 70-AV/SPT-8, ASME Meeting, Los Angeles (June 1970).

- 4.6 Babinsky, A. D., DeRespiris, D.L., and Derezinski, S. J.: "Carbon Dioxide Concentration System". NASA CR-72086 (1960).
- 4.7 Life Systems, Inc.: "Development of a One-Man, Self-Contained Carbon Dioxide Concentrator". NASA Contract NAS2-6118, Ames Research Center (July 1970).
- 4.8 Huebscher, R. G., and Babinsky, A. P., "Aircrew Oxygen System Development, Carbon Dioxide Concentrator Subsystems Report," NASA CR-73397 (1970).
- 4.9 Kiraly, R. J., et al.: "Aircrew Oxygen System Development, Laboratory Breadboard System Test Report," NASA CR-73396 (1970)
- 4.10 Kiraly, R. J., Babinsky, A. D. and Powell, J. D.: "Aircrew Oxygen System Development, Man-in-the-Loop Test Report". NASA CR-73395 (1970).
- 4.11 Bannerton, N. P., DeRespiris, D. L., and Vogt, J. W.: "Carbonation Cell Materials Compatibility Study" Final Report, NAS3-10930 (May 1968).
- 4.12 Sribnik, F., Dean, W. C., Aylward, J.: "Hydrogen Depolarized Cell/Water Vapor Electrolysis Cell". CO₂ Collection Subsystem Preliminary Design Package, SSP Document No. A35 (HSD Report).
- 4.13 Wynveen, R. A., Suchubert, F. H., J. D. Powell, "One-Man, Self-Contained CO, Concentrating System," NAS2-6118, Life Systems Inc., March 1962.

References on Solid Electrolyte Oxygen Generation

- 5.1 Weissbart, J, Smart, W. H., Wydeven, T.: "Design and Performance of a Solid Electrolyte Oxygen Generator Test Module". ASME Paper No. 71-AV-8. SAE/ASME/AIAA Life Support Meeting, San Francisco, Calif., April 1971.
- 5.2 Elekan, L., Morris, J. P., Wu, C. K., Saunders, C. G.: "180-Day Life Test of Solid Electrolyte System for Oxygen Regeneration", ASME Paper No. 71-AV-32, ibid.
- 5.3 Weissbart, J., Smart, W. H., and Wydeven, T.: "Oxygen Reclamation Using a Solid Oxide Electrolyte". Aerospace Medicine, Vol. 40, No. 136, 1969.
- 5.4 Weissbart, J., and Smart, W. H.: "Development of a CO₂ H₂O Solid Oxide Electrolyte Electrolysis System". Second Annual Report, Contract NAS2-4843, Applied Electrochemistry, Inc., Mountain View, Calif., May 1970.
- 5.5 Weissbart, J., et al.: "Development of a CO₂ H₂O Solid Oxide Electrolyte Electrolysis System". First Annual Report, Contract NAS2-4843, Applied Electrochemistry, Inc., Mountain View, Calif., May 1969.

- 5.6 Weissbart, J., and Smart, W. H.: "Study of Electrolyte Dissociation of CO₂ H₂O Using a Solid Oxide Electrolyte". Second Annual Report, Contract NAS2-2810, Lockheed Missiles and Space Co., Palo Alto.
- 5.7 Weissbart, J., and Smart, W. H.: "Study of Electrolytic Dissociation of CO₂ H₂O Using a Solid Oxide Electrolyte". First Annual Report, Contract NAS2-2810, Lockheed Missiles and Space Co., Palo Alto, Calif. NASA Contractor Report CR-680, Feb. 1967.
- 5.8 Elikan, L. and Morris, J. P.: "Solid Electrolyte System for Oxygen Regeneration". Contract NAS1-7306, Westinghouse Electric Corporation, Pittsburg, Pa. NASA CR-1359, June 1969.
- 5.9 Weissbart, J. and Smart, W. H.: "Development of a CO₂ H₂O Solid Oxide Electrolysis System". Annual Report, 1 April-31 December 1970 (NASA CR-114295).
- 5.10 Chandler, H. W.; Carbon Dioxide Reduction System. Isomet Corp., Contract No. AF33(657)-8066, Report No. AMRL-TDR-64-42, May 1964.
- 5.11 Chandler, H. W. and Howell, L J., A Solid Electrolyte Carbon Dioxide Reduction System. Aerospace Medical Research Laboratories Report, AMRL-TR-67-209. January 1968.
- 5.12 Trade-off Study and Conceptual Design of Regenerative Advanced Integrated Life Support Systems, Hamilton Standard Division of United Aircraft Corp., Report No. NASA CR-1458, January 1970.
- 5.13 Elikan, L. and Morris, J. P.; "Development of a Solid Electrolyte System for Oxygen Regeneration". Contract NAS1-8896, Westinghouse Electric Corp., Pittsburg, Pa.

References on Liquid Absorption

- 6.1 Pigford, R. L., Wall, H. H. III: "Absorption and Desorption of Carbon Dioxide in Carbonate-Bicarbonate Buffer Solutions". AIChE Preprint 63E. Presented at the Sixty-Fourth National Meeting, New Orleans, La. March 1969.
- 6.2 Edsall, J. T.: "Carbon Dioxide, Carbonic Acid, and Bicarbonate Ion: Physical Properties and Kinetics of Interconversion". NASA SP-188, Aug 1968.
- 6.3 Scheurer, P. G., et al.: "An Apparatus for the Investigation of Rapid Reactions. The Kinetics of the Carbonic Acid Dehydration". J. Phys. Chem., Vol 62, pp 809-812 (1958).

- 6.4 Hayduk, W. and Malik, V.K.: "Density, Viscosity, and Carbon Dioxide Solubility and Diffusivity in Aqueous Ethylene Glycol Solutions".

 J. Chem and Eng Data, Vol 16, No. 2, pp 143-146 (1971).
- 6.5 Sharma, M. M. and Danckwerts, P. V.: Catalysis by Brönsted Bases of the Reaction between CO₂ and Water". Trans. Faraday Society, Vol 59, pp 386-395 (1963).
- 6.6 Shedlovsky, T. and Mac Innes, P. A.: "The First Ionization Constant of Carbonic Acid, O to 38°C, from Conductance Measurements". J. Amer. Chem. Soc., Vol 57, pp 1705-1710 (1935).
- 6.7 Rossi-Bernadi, L., and Berger, R. L.: "Rapid Measurement of pH by the Glass Electrode: Kinetics of Dehydration of Carbonic Acid at 25°C and 37°C." J. Biological Chemistry, Vol. 243, No. 6, pp. 1297-1302 (1968).
- 6.8 Gibbons, B. H. and Edsall, J. T.: "Rate of Hydration of Carbon Dioxide and Dehydration of Carbonic Acid at 25°C". J. Biological Chemistry, Vol. 238, No. 10, pp. 3502-3507 (1963).
- 6.9 Munjal, P. and Stewart, P. B.: "Correlation Equation for Solubility of Carbon Dioxide in Water, Seawater, and Seawater Concentrates".

 J. Chem. and Eng. Data, Vol. 16, No. 2, pp. 170-172 (1971).
- 6.10 Dennard, A. E. and Williams, R. J. P.: "The Catalysis of the Reaction between Carbon Dioxide and Water". J. Chem. Soc. (A), pp. 812-816 (1966).
- 6.11 Scriven, L. E. and Pigford, R. L.: "On Phase Equilibrium at the Gas-Liquid Interface During Absorption". A.I.Ch.E. Journal, Vol. 4, pp. 439-444 (1958).
- 6.12 Hammeblain, D. M. and Babb, A. L.: "Kinetic Studies of Carbonation Reactions Using Radioactive Tracers". A.I.Ch.E. Journal, Vol. 4, No. 2, pp 143-152 (1958).
- 6.13 Davidson, J. F. and Cullen, E. J.: "The Determination of Diffusion Coefficients for Sparingly Soluble Gases in Liquids". Trans. Instn. Chem. Engrs. Vol 35, pp 51-60 (1957).
- 6.14 Nysing, R. and Kramers, H.: "Absorption of CO₂ in Carbonate Bicarbonate Buffer Solutions in a Wetted Wall Column". Chem. Eng. Science. Vol. 8, pp 81-889 (1958.)
- 6.15 Pinsent, B. R. W., Pearson, L., and Roughton, F. J. W.: "The Kinetics of Combination of Carbon Dioxide with Hydroxide Ions". Trans. Faraday Soc. Vol 52, pp. 1215-1223 (1956).
- 6.16 Kern, D. M.: "The Hydration of Carbon Dioxide". Journal of Chemical Education. Vol. 37, No. 1, pp 14-23.

- 6.17 Pinsent, B. R. W. and Roughton, F. J. W.: "The Kinetics of Combination of Carbon Dioxide with Water and Hydroxide Ions". Trans. Faraday Society, Vol. 47, pp 263-269 (1951).
- 6.18 Wissburn, K. F., French, D. M., and Patterson, A.:, "The True Ionization Constant of Carbonic Acid in Aqueous Solution from 5 to 45°C". J. Phys. Chem., Vol 58, pp 693-695 (1954)
- 6.19 Perry, R. H., "Chemical Engineers Handbook", 4th Edition, p. 14-11, McGraw-Hill, New York, 1960.
- 6.20 "Trade-Off Study and Conceptual Design of Regenerative Advanced Integrated Life Support Systems (AILSS)", July 1969, Hamilton Standard, p. 190.
- 6.21 "Mars Landing and Reconnaissance Mission Environmental Control and Life Support System Study", Hamilton Standard, 1964, p. 2-30.

References on Electrodialysis

- 7.1 Brown, D. L.: "Investigation of an Electrochemical Device for Carbon Dioxide Absorption and Oxygen Generation". ASD TDR 63-441, May 1963 (Ionics).
- 7.2 Ionics, Inc.: "Carbon Dioxide Removal and Water Electrolysis Subsystems". Sept. 1963 (Proposal document to Douglas describing system operation and performance).
- 7.3 Brown, D. L., et al.: "Performance of an Electrochemical Device for Simultaneous Carbon Dioxide Removal and Oxygen Generation", Chem. Eng. Prog. Symposium Series, No. 63, Vol 62 (1966) (Ionics).
- 7.4 Perry, R. H. et al., "Chemical Engineer's Handbook", 4th Edition p. 17-45 thru 17-48, McGraw-Hill Book Company, Inc., New York, 1963.
- 7.5 Perry, R. H. et al., "Chemical Engineer's Handbook", 4th Edition p. 14-4, McGraw-Hill Book Company, Inc., New York, 1963.
- 7.6 Mason, E. A. T. A. Kirkham, "Design of Electrodialysis Equipment," Chemical Engineering Progress Symposium Series," No. 24, Vol. 55, p 173-189
- 7.7 Pruyn, K. T., J. J. Harrington, J. D. Smith, "Mathematical Model of the Electrodialysis Process," Process Research, Inc., Program No. 17090 FTA, Contract No. 14-12-410, for FWQA, July 1969.

References on Molten Carbonate

- 8.1 Arnoldi, W. E.: "An Electrolytic Process for Carbon Dioxide Separation and Oxygen Reclamation". Atmosphere in Space Cabins and Closed Environments, Meredith Publishing Co., 1966, pp. 76-103.
- 8.2 Stein, P. J.: Research and Development Program for a Combined Carbon Dioxide Removal and Reduction System. Hamilton Standard Division, Contract No. NAS1-4154, Final Report Phase I, October 1965.

References for Membrane Diffusion

- 9.1 "Proposal to Study a Semipermeable Membrane System for Carbon Dioxide Control". DAC Report SM-43398, Sept. 1963. (This report has an excellent summary of the theory of diffusion through membranes.)
- 9.2 Pulfrey, R. E.: "Molecular Flow through Membranes". Ionospheric Research, Scientific Report No. 326, Pennsylvania State University, Nov 1968.
- 9.3 Robb, W. L.: "Thin Silicone Membranes--Their Permeation Froperties and Some Applications". General Electric Report No. 65-C-031.

 October 1965, Schenectady, New York.
- 9.4 Ward, W. J. and Robb, W. L.: Carbon Dioxide-Oxygen Separation:
 Facilitated Transport of Carbon Dioxide across a Liquid Film". Science,
 Vol. 156, No. 3781, pp 1481-1484, June 16, 1967.
- 9.5 Findley, M. E., et al.: 'Mass and Heat Transfer Relations in Evaporation through Porous Membranes". AICh.E Preprint 62A. Symposium on Evaporation New York, Nov. 1967.
- 9.6 Ward, W. J. III: "Immobilized Liquid Membranes for Continuous Carbon Dioxide Removal". AMRL-TR-67-53, Aerospace Medical Research Laboratories, June 1967.
- 9.7 Withey, D. J., Glanfield, E. J., and Dohner, C. V.: "Application of Permselective Composite Techniques for Atmosphere Thermal Control of Emergency and Extravehicular Manned Space Assemblies". AMRL-TR-66-224, Aerospace Medical Research Laboratories, April 1967.
- 9.8 Newlander, C. K., Martin, F. J., "Development of a Permselective Membrane System for Continuous Carbon Dioxide Control", AMRL-TR-70-44, October 1970.

References on Mechanical Freeze-Out

- 10.1 Dulock, V. A.: "Preliminary Heat Rejection Rates and Thermal Radiator Area Requirements for a Freez-Out Life Support System". TRW Systems, Houston Operations in-house report (Nov 1970).
- 10.2 Kroger, D. G. and Rohsenow, W. M. "Condensation Heat Transfer in the Presence of a Non-Condensable Gas". Int. J. Heat & Mass Transfer. Vol. II, pp. 15-26 (1968).
- 10.3 Minkowycz, W. J. and Spanow, E. M.: "Condensation Heat Transfer in the Presence of Non-Condensables, Interfacial Resistance, Superheating, Variable Properties, and Diffusion". Int. J. Heat and Mass Transfer, 9, pp. 1125-1144 (1966).
- 10.4 Sparrow, E. M., Minkowycz, W. J. and Saddy, M.: "Forced Convection Condensation in the Presence of Non-Condensables and Interfacial Resistance". Int. J. Heat and Mass Transfer, 10, pp. 1829-1845 (1967).
- 10.5 Bonneville, J. M.: "A Study of Water and Carbon Dioxide Precipitation Techniques Using Thermal Radiation Principles". AMRL-TR-66-118.

 (Aug 1966) Dynatech.
- 10.6 Maulbetsch, J. S., "An Experimental Investigation and System Design for Humidity and Carbon Dioxide Level Control Using Thermal Radiation", AMRL-TR-68-174 (April 1969) Dynatech.
- 10.7 Schaffer, A: "Analytical Methods for Space Vehicle Atmospheric Control Processes. SS-572-R (1961). AiResearch Manufacturing Company.
- 10.8 International Critical Tables, Volume 5, p. 83, 95, 207, McGraw-Hill, 1929.
- 10.9 ASHRE Guide and Data Book, Vol. I, American Society of Heating,
 Refrigerating and Air-Conditioning Engineers, Inc., New York, 1965/1966,
 p. 342.

APPENDIX A

NEW COMPONENT SUBROUTINES

CARDP

Component Subroutine No. 50 - Carbon Deposition Reactor

1.0 Subroutine Description

The carbon deposition reactor, which is also referred to as a carbon disproportionator, reduces CO to carbon. The reactor is a major component of the solid electrolyte subsystem for regenerating O_2 from CO_2 generated in a spacecraft environment. The reactor converts CO generated in the solid electrolyte cells into CO_2 and carbon. The carbon is deposited on the walls of the reactor while CO_2 is recycled to the solid electrolyte cells.

The following two principal reactions occur in the reactor:

$$2 CO \rightarrow CO_2 + C \tag{1}$$

$$H_2 + CO_2 \rightarrow H_2O + CO$$
 (2)

The second reaction converts hydrogen into water which, in small amounts, catalyzes both CO₂ decomposition in the electrolyzer and carbon monoxide disproportionation in the reactor. The level of hydrogen in the feed is prevented from building up too high by separating out most of the hydrogen prior to entering the reactor. The separation is performed in a semi-permeable membrane separation device. The degree of separation is controlled by regulating the pressure on the vacuum side of the membrane.

Basically, the reactor is a tubular flow reactor with walls constructed of low carbon steel. The steel serves to catalyze the reaction. The reactor has an internal scrapper for removing carbon deposited on the reactor walls. A jar is located at the bottom of the reactor to collect carbon scrapped from the walls. Alternatively, a disposable reactor tube concept could be used.

The reactor operating temperature is in the range of 550°C. The reactor contains a heater element to bring the reactor up to temperature. Since the reactor is exothermic, the heater is not required during quasi-steady state operation if adequate insulation is provided.

2.0 Subroutine Data

2.1 General Notes

- 1. A primary source of flow must be specified to provide an inlet gas flow. The primary side flow code must be 3. The flow constituents in the source of flow must be compatible with those for the component.
- 2. The gaseous feed for the primary side of the component is assumed to be composed primarily of CO_2 , H_2O , CO, and H_2 . H_2 and CO are assumed to enter as special flows 1 and 2, respectively.

2.2 Heat Loss V-Array Data

Reference Location	<u>Description</u> <u>Date</u>	a Type
51	Temperature of reactor (°F)	0
` 52	Effective thermal conductance from the reactor to	
	surroundings (Btu/hr ^O F)	0
53	Total heat loss from reactor to surroundings (Btu/hr)	0
	R(53) = R(56) + R(59) + R(62)	
54	Ambient gas temperature (°F)	I(R)
55	Thermal conductance between surface of reactor insulation	I(R)
	and ambient gas $(\frac{Btu}{hr} - 0_F)$	•
56	Convective heat loss to ambient gas from reactor (Btu/hr)	0
57	Ambient wall temperature (°F)	I(R)
58	Reactor thermal radiation FA from surface of insulation	I(R)
	to ambient wall (ft ²)	
59	Radiation heat loss from reactor to ambient wall (Btu/hr)	0
60	Structure temperature (°F)	I(R)
61	Conductance $(\frac{kA}{\Lambda X})$ between reactor and structure	I(R)
62	Conductive heat loss to the structure (Btu/hr)	0
63	Insulation surface temperature (°F)	0
64	Conductance $(\frac{kA}{\Delta X})$ between module shell and outer surface	I(0)
	of insulation	*

2.3 Steady State V-Array Data

Reference Location	<u>Description</u>	Data Type
65	Heat dissipated in a module by electrical heater (Btu/hr)	1(0)
66	Heat generated by net influx of reactants and products	
	and the heat of reaction (Btu/hr)	0
67	CO conversion (fraction)	I(R)
68	H ₂ conversion (fraction)	I(R)
69	Previous trial value for PHI (Btu/hr)	0
70	Previous trial value for TMOD (OF)	0
71	Convergence tolerance for calculating cell temperature	
	(percent)	I(R)
72	Deposition rate for carbon on walls of reactor (lb/hr)	0

2.4 Transient V-Array Data

Reference Location			Description		Data Type
R(73)	Total reactor	thermal	capacitance	(Btu/°F)	I(R)
R(74)	Initial temper	ature a	t time t(OF)		I(R)

Table 1
CONSTANTS FOR HEAT CAPACITY EQUATIONS

$$C_p = a/T^2 + b/T + c + dT^1 + eT^2 \frac{cal}{g \text{ mole } K}$$

	<u>a</u>	<u>b</u>	<u>c</u>	<u>a</u>	<u>e</u>
0 ₂ (g)	-187700.	0.	8.27	.000258	0.
H ₂ O(g)	0.	0.	8.22	.00015	.00000134
co	-195500.	0.	10.34	.00274	0.
C(graphite)	0.	0.	2.673	.002617	-116900.
Н2	0.	0.	6.62	.00081	0.
co	0.	0.	6.60	.00120	0.

3.0 Analytical Model Description

The equilibrium constant for the conversion of CO to ${\rm CO}_2$ (equation 1) is equal to 36×10^6 at 850° C. Thus from an equilibrium standpoint, the formation of ${\rm CO}_2$ is strongly favored. The reaction would be expected to go essentially to completion. The actual conversion, however, may be considerably less due to the kinetics of the reaction.

From a reactor design standpoint, the reactor could be treated as a classical tubular reactor. Standard techniques are available for analysis of a specified design configuration (reference (1)). The reaction rate constant will be influenced by two catalyzing factors: the low carbon steel walls of the container, and the amount of water vapor present in the reactor. Thus as carbon is deposited on the walls of the reactor, the reaction rate will be effected. Fluctuations in the levels of hydrogen in the feed, which reacts to form water, will also influence the reaction rate.


The actual conversion will be difficult to predict analytically since the geometry of the reactor is not fully defined and because of the complex nature of the reaction rate. Thus an empirical approach will be used based on experimentally determined values for CO and H₂O conversion. Thus

$$M_{CO,o} = M_{CO,i} (1-n_1)$$
 (3)

$$M_{H_{2,0}} = M_{H_{2,1}} (1-n_2)$$
 (4)

The reactor is treated as a single lumped mass for heat transfer analysis. A heat balance is performed taking into account losses to the ambient due to conduction, radiation, and convection; electrical heater power dissipations; the net enthalpy change of products and reactants; and the heat of reaction. Figure 1 illustrates the thermal model used in the subroutine.

The net enthalpy added by the influx and efflux of reactants and products respectively and the heat of chemical reaction is as follows:



Q_H = HEAT DISSIPATED BY ELECTRICAL HEATER (BTU/HR)

Q_R = ENTHALPY CHANGE FOR NET INFLUX OF REACTANTS AND PRODUCTS AND CHEMICAL REACTION (BTU/HR) h rad = RADIATION CONDUCTANCE FROM SURFACE OF INSULATION TO AMBIENT WALL (BTU/HR °F)

h conv = CONVECTION CONDUCTANCE FROM SURFACE OF INSULATION TO AMBIENT WALL (BTU/HR °F)

h stru = CONDUCTANCE FROM REACTOR
TO STRUCTURE (BTU/HR °F)

FIGURE 1 CROSS SECTIONAL VIEW OF REACTOR TUBE SHOWING THERMAL MODEL

$$\Delta H_{T} = \Delta H_{R} - \Delta H_{R} - \Delta H_{1,To} - \Delta H_{2,To}$$
 (5)

ΔH_R = enthalpy change of reactants (Btu/^OF)

 ΔH_{p} = enthalpy change of products (Btu/ $^{\circ}$ F)

 $\Delta H_{1,T_0}$ = heat of reaction (heat absorbed) for decomposition of CO (Btu/hr)

 $\Delta H_{2,T_0}$ = heat of reaction (heat absorbed) for decomposition of H_2 (Btu/hr)

 ΔH_R and ΔH_P are the integrated enthalpy changes for the reactants and products, respectively, from the inlet and outlet temperature to the standard state for the heat of reaction (77°F). The integrated enthalpy change for each species is calculated by the following equation:

$$\Delta H_1 = N_1 \int_{T_0}^{T} (aT^{-2} + bT^{-1} + cT^0 + dT^1 + eT^2) dT$$
 (6)

where:

N, = flow rate of species i (lb/hr)

 ΔH_1 = enthalpy change for constituent i between temperature T and T_o (Btu/hr)

a, b, c, d = experimentally determined coefficients for heat capacity as a function of temperature. The values of these constants for the reactant and product constituents are given in Table 1.

The net heat balance for the reactor temperature is given below:

$$\frac{\mathbf{T}_{\mathbf{RX}}' - \mathbf{T}_{\mathbf{RX}}}{\mathbf{A}^{+}} \mathbf{G} = -\mathbf{Q}_{\mathbf{AM}} + \mathbf{Q}_{\mathbf{e}} + \mathbf{Q}_{\mathbf{H}}$$
 (7)

when:

Q_{AM} = net heat loss to the surroundings by conduction, convection, and radiation (Btu/hr)

Q = electrical energy dissipated by the heater (Btu/hr)

Q_H = net enthalpy added to module by reactants and products
(Btu/hr)

 T_{RX} , T_{RX} = temperature of reactor at time t + Δt and time t

 $G = thermal capacitance of reactor (Btu/<math>^{\circ}F$)

Equation (7) is rewritten in the following form for solution by a trial and error procedure

$$PHI = -\frac{T_{RX}' - T_{RX}}{\Lambda^{+}} G - Q_{AM} + Q_{C} + Q_{H}$$
 (8)

For a trial value of T_{RX} , Q_{AM} is calculated using subroutine QSURR. Equation (8) is solved for PHI. Subroutine ESTDM is then used to determine the value of T_{RX} for which PHI equals 0. Convergence is satisfied when:

$$\left| \frac{PHI}{(\Delta H_R + Q_e)} \right| < \frac{R(80)}{100}. \tag{9}$$

4.0 Lower Level Subroutines and Functions

QSURR

ESTIM

5.0 References

J. Smith, "Chemical Engineering Kinetics," McGraw-Hill Book Co., Inc., New York, 1956, p. 96.

CØSØRP

Component Subroutine No. 36 - Two Constituent Sorption Bed Subroutine

1.0 Subroutine Description

This subroutine may be used to simulate the absorption (or adsorption) and desorption of either CO_2 and $\mathrm{H}_2\mathrm{O}$ or both in a packed resin bed. While the routine was prepared expecially for simulation of an IR-45 solid amine resin bed for absorbing CO_2 from a spacecraft environment, the routine is equally suitable for other sorption beds such as silica gel for adsorbing water vapor or molecular sieves for adsorbing CO_2 . Both transient or steady-state performance may be simulated. Logic is also incorporated to simulate purge, steam and thermal/vacuum desorption.

The logic for simulation of the pseudo-steady state performance of the bed is rather unsophisticated compared to that for the transient simulation. For steady state purge absorption or desorption, bed performance is calculated from either an average removal efficiency or an average value of bed loading. Steady state steam desorption calculations consist chiefly of determining the amount of steam required to desorb a bed with a specified CO₂ loading.

Three routines are used in the transient simulation. One was prepared for simulating absorption and purge desorption. The second reutine was prepared for simulating steam desorption. Here the bed is purged with steam until CO₂ is driven off in a chromatographic fashion. The mass flow rate is not constant throughout the bed for this process and thus different coding was required. The third routine is for thermal/vacuum desorption.

Transient performance in the bed is performed by splitting the bed into as many as 24 elements in the direction of flow. Lumped parameter equations are incorporated for gas, bed, and heat exchanger (if any), and the canister wall for each element within the bed.

Heat and mass transfer rates within beds are calculated from built in equations or may be entered as data by the program user. The mass transfer rate is an overall rate and should include the effects of convective mass transfer or diffusion, absorption or desorption reaction rates, and intraparticle diffusion. The mass transfer processes for both CO_2 and H_2O are assumed to occur independent of each other. Equilibrium H_2O vapor pressure over the bed is assumed to be independent of CO_2 bed loading. The CO_2 equilibrium partial pressure is assumed to vary both with CO_2 and CO_2 and CO_3 and CO_4 bed loading. Equilibrium relationships have been built into the program for CO_2 and CO_3 and CO_4 over CO_4 and CO_4 and CO_4 and CO_5 and CO_5 and CO_5 and CO_6 and $CO_$

The subroutine described herein is used to simulate only one component of a CO₂ or H₂O removal or collection system: the sorption bed. Other components such as heat exchangers, control valves, fans, boilers, etc. must be simulated by other appropriate G-189 subroutines. The logic for tying the whole system together, including that for simulating the cyclical operation of the beds, must be incorporated into GPOLY coding or another special purpose subroutine.

2.0 Subroutine Data

2.1 General Notes

- 1. A primary source flow must be specified to provide an inlet gas flow.
- If the sorption bed has an integral heat exchanger (NSTR(2) = 1 or 2), a secondary source flow must be specified to provide an inlet liquid flow for heating or cooling.
- 3. The primary side flow code must be 2 or 3. If there is a secondary flow, its code must be 0 or 4.
- 4. The flow constituents in the source of flow must be compatible with those for the component.
- 5. Equilibrium relationships for CO₂ and H₂O partial pressure in solid amine (IR-45) absorption beds have been built into the program. The program user may enter alternate data as table data. The table numbers to be used are then specified in steady state K array reference locations 17, 18, 19, 20.
- 6. Either single constituent or two constituent sorption processes may be simulated (see NSTR(1)).

- 7. Isothermal bed calculations may be performed without specifying a heating or cooling fluid by setting NSTR(9) = 1
- 8. Mass transfer calculations may be bypassed if only heat transfer calculations are desired. (NSTR(10)=1)
- 9. When simulating thermal/vacuum desorption with the beds switching periodically from an adsorption to a desorption mode, the number of bed elements specified in K(NK+21) should be set equal to the number of bed elements to be used during the absorption mode. During the desorption mode, the routine automatically assumes one bed element.
- 10. When using the integral heat exchanger option, data should be entered for each of the quantities in R(87) through R(94). Where the effects of these individual quantities are negligible, a small number of the order of 1.0 x 10^{-12} should be entered as data. This will prevent computational problems in the steady state heat balance.

2.2 Instruction Options

- NSTR(1) Specifies sorbing constituents
 - = 0 Sorption of CO, only
 - = 1 Sorption of H₂O only
 - Co-sorption of CO₂, H₂O
 - Co-sorption of CO_2 , H_2O . During desorption, the moles H_2O desorbed are assumed to equal moles CO_2 desorbed. The CO_2 desorbed is calculated in the same manner as with NSTR(1) = 0 or 3.
- NSTR(2) Integral heat exchanger for cooling or heating
 - = 0 Bed has no heat exchanger
 - = 1 Bed has counter flow heat exchanger
 - = 2 Bed has parallel flow heat exchanger
- NSTR(3) Specifies method used during desorption
 - = 1 Steam stripping
 - = 2 Purge gas
 - = 3 Vacuum Desorption

nstr(4)	Heat transfer coefficient between carrier gas and bed
	during sorption
= 0	Use constant value in R(77)
* 1	Calculate from built-in relationship
NSTR(5)	Mass transfer coefficient between carrier gas and bed during sorption
= 0	Use constant value entered in R(82) or R(86)
= 1	Calculate from built-in relationship
NSTR(6)	Heat transfer coefficient between gas and bed during desorption
= 0	Use constant value entered in R(78)
= 1	Calculate from built-in relationship
= 2	Assume outlet gas temperature equals bed temperature
nstr(7)	Mass transfer coefficient between gas and bed during desorption
= 0	Use constant value entered in R(81) or R(85)
= 1	Calculate from built-in relationship
= 2	Assume outlet partial pressure for element equals bed equilibrium pressure for H ₂ O
= 3	Assume outlet partial pressure for element equals bed
	equilibrium pressures for CO ₂ and H ₂ O
NSTR(8)	Heat transfer coefficient between gas and heat exchanger core
= 0	Use constant value entered in R(87)
= 1	Assume equal to that between gas and bed
NSTR(9)	Specifies a special option for simulating isothermal bed operation during sorption
= 2	Hold bed temperature to a constant value specified in RX(06)
NSTR(10)	Specifies a special option which allows simulation of heat transfer but omits mass transfer in the bed
a 1	Perform heat transfer calculations only

NSTR(11)	Heat transfer coefficient between gas and inside wall of
•	bed canister.
= 0	Use constant value in R(92).
= 1	Assume equal to that between gas and bed.
NSTR(12)	Specifies method for performing pseudo-steady state sorption
-	or desorption calculations.
= 0	Use constant value for removal efficiency specified in R(65)
= 1	or R(66). Use average value of bed loading $\frac{1b}{1b}$ sorbate in R(65) or R(66).
NSTR(13)	Instruction for setting initial conditions during transient
·	run. These include: node CO2, H2O, and air exit partial
	pressures; CO2 and H2O bed loading; gas, bed, and heat
- 0	exchanger temperature.
= 0	Input data must be entered for every node.
= 1	Input data is entered only for first node. Corresponding
= 2	values for the other nodes are set equal to this data.
- 2	Same as 1 except that the CO ₂ concentration varies linearly
• •	with distance from the value entered for the first node to
- 3	zero at the last node.
= 3	Same as 1 except that the H ₂ O concentration varies linearly
	with distance from the value entered for the first node to
- .	zero at the last node.
= 4	Same as 1 except that both the CO ₂ and H ₂ O concentration varies
•	linearly with distance from the value entered for the first
	node to zero at the last node.
= 5	Same as 1 except input data for CO, and H,O concentration

2.3 Heat Loss V-Array Data

Reference Location		Description	Data Type
R(51)	Temperature ((OF)	f inside surface of bed canister	0
R(52)	Not used.		

is entered for every node

Reference Location	Description	Data Type
R(53)	Total heat lost from component to environment (Btu/hr)	0
R(54)	Ambient gas temperature (°F)	I(0)
R(55)	UA between ambient gas and insulation surface	·.·
	(Btu/hr-OF)	1(0)
R(56)	Temperature of outside surface of insulation (OF)	0
R(57)	Conductance between inside surface of canister and	
	insulation exterior surface (Btu/hr OF)	1(0)

2.4 Steady State K-Array Data

Reference		
Location	Description	Data Type
16	Bed operating mode	I(R)
= 0	Bed is sorbing	
= 1	Bed is desorbing	
17	H ₂ 0/Resin Equilibrium Isotherm	I(R)
= -N	Use built in relationship for equilibrium H ₂ O partial pressure over resin	
= +N	Table number for bivariant curve for H20	
	equilibrium partial pressure	•
	lst independent variable	
	= H ₂ 0 bed loading lbsorbate lbdry resin	
	2nd independent variable	
	= Bed temperature (°F)	
	dependent variable	
	= partial pressure (mmHg)	
18	CO ₂ /Resin Equilibrium Isotherms	I(R)
= -N	Use built in relationship	4
= +N	Table number for bivariant curve for CO2	
4°	equilibrium partial pressure for H ₂ O bed	•
•	loading specified in R(95)	
	1st independent variable	
	= CO ₂ bed loading lbsurbate lbdry resin	

Reference Location	Description	Data Type
	2nd independent	
	= Bed temperature (OF)	
	dependent variable	
	= partial pressure (mm Hg)	•
19	CO ₂ /Resin Equilibrium Isotherm	
= -N	Use built-in relationship	1(0)
= +N	Table number for HoO bed loading specified	
	in R(96)	
= 0	Table no. specified in K(NK+18) is used	
20	CO ₂ /Resin Equilibrium Isotherm	I(0)
= -N	Use built-in relationship	
= +N	Table number for H ₂ O bed loading specified	
	in R(97)	
= 0	Table no. specified in K(NK+18) is used	

2.5 Steady State V-Array Data

Reference Location	Description	Data Type
65	CO ₂ removal efficiency 1b sorbate removed	
	1b sorbate entering	
	if $NSTR(12) = 0$	I(R)
	or average value of CO ₂ bed loading	if NSTR(1) = 0 or 2
	$\frac{1b_{\text{sorbate}}}{1b_{\text{dry bed}}} \text{if NSTR}(12) = 1$	
66	H ₂ 0 removal efficiency lbsorbate removed	
	lb sorbate entering	
	if $NSTR(12) = 0$	if NSTR(1) = 1 or 2
	or average value of H20 bed loading	
	$\frac{1b_{\text{sorbate}}}{1b_{\text{dry bed}}} \text{ if NSTR(12) = 1}$	
67	Resin particle density (lb/ft3)	I(R)
68	Resin bulk density (lb/ft ³)	*
69	Resin pellet effective diameter (ft)	I(R)
70	Resin void fraction (dimensionless)	
71	Resin superficial surface area (ft ² /ft ³)	I(R)
72	Sphericity (=1.0 for spherical particles)	I(R)
73	Channeling factor (= 1.0 for no channeling)	I(R)
74	Bed inside diameter (ft)	I(0) } *
75	Bed frontal area (ft ²)	I(0))
76	Bed length (ft)	I(R)
77	Overall heat transfer coefficient between	if $NSTR(4) = 0$
	gas and pellets during sorption (Btu/hr-ft2-of	')
78	Overall heat transfer coefficient between	
	gas and pellets during desorption (Btu/hr-ft2	?-°F)
79	Heat of sorption for CO ₂ (Btu/lb)	I(R)
		if NSTR(1) = 0 or 2
80	Binary diffusion coefficient (diffusivity)	I(R)
	for CO ₂ /Air (ft ² /hr)	if NSTR(5) = 1
•		and NSTR(1) = 0 or 2

^{*} Input data required for one of these quantities

Reference Location	Description	Data Type
81	Overall mass transfer coefficient (pellet	I(R)
	to gas) for CO, during desorption	if NSTR(1) 0 or 2
	$\binom{\frac{1b_{moles}}{hr-ft^2-mm}}{hg^2}$	and $NSTR(7) = 0$
82	Overall mass transfer coefficient (pellet	I(R)
	to gas) for CO2 during sorption	if NSTR(1) = 0 or 2
	$\left(\frac{\text{lb moles}}{\text{hr-ft}^2-\text{mm}}\right)$	and NSTR(5) = 0
83	Heat of sorption for H20 (Btu/lb)	I(R)
		if NSTR(1) = 1 or 2
84	Binary diffusion coefficient (diffusivity)	I(R)
	for H ₂ 0/Air (ft ² /hr)	if $NSTR(5) = 1$
		and $NSTR(1) = 1$ or 2
85	Overall mass transfer coefficient (pellet	I(R)
	to gas) for H20 during desorption	if $NSTR(1) = 1$ or 2
	(lb moles hr-ft2- mm Hg)	and NSTR(5) = 0
86	Overall mass transfer coefficient (pellet	I(R)
	to gas) for H20 during sorption	if NSTR(1) = 1 or 2
	$\left(\frac{\text{lb moles}}{\text{hr-ft}^2-\text{mm}}\right)$	and NSTR(5) = 0
87	Overall heat transfer coefficient between	1(0)
	heat exchanger core and gas $\left(\frac{\text{Btu}}{\text{hr-ft}^2} \circ_{\text{F}}\right)$	
88	Heat transfer area between core and gas (ft2)	I(0)
89	Overall heat transfer coefficient between core and bed $\left(\frac{Btu}{hr-ft^2} \circ_F\right)$	1(0)
90	Heat transfer area between core and bed (ft2)	I(0)
91	Heat transfer area between gas and inside	I(0)
	canister wall (ft ²)	
92	Overall heat transfer coefficient between	
	gas and canister wall $\left(\frac{Btu}{hr-ft^2} \circ_F\right)$	
93	Heat transfer coefficient between fluid and	I(0)
	heat exchanger core $\begin{pmatrix} Btu \\ Hr-ft^2 & F \end{pmatrix}$	

Reference Location	Description	Data Type
94	Heat transfer area between fluid and	1(0)
	heat exchanger core (ft ²)	
95	Value of H ₂ O bed loading for <u>lst</u>	I(R)
	bivariant CO ₂ /resin isotherm (1bH ₂ 0)	if KR(17)> 0
·	Value of H ₂ 0 bed loading for lst bivariant CO ₂ /resin isotherm (lbH ₂ 0) bdry resin	and $NSTR(2) = 1$ or 2
96	value of no bed loading for 2nd	I(R)
	bivariant CO ₂ /resin isotherm b ₁ 0	if KR(17)> 0
,	\lambda \frac{1b_{dry resin}}{}	and $NSTR(2) = 1$ or 2
97	Value of H ₂ O bed loading for 3rd bivariant	I(R)
	CO ₂ /resin isotherm (1bH ₂ 0)	if KR(17)>0
	CO ₂ /resin isotherm (1b _{H2} 0) lbdry resin	and $NSTR(2) = 1$ or 2
98	Average bed temperature (°F)	I(R), 0
99	Duration of desorption cycle (hours)	I(R)
		if $NSTR(3) = 1$
		or NSTR(3)=3

2.6 Transient K-Array Data

Reference Location	Description	Data Type
21	Number of bed elements	I(R)
22	Bed operating mode	I(R)
	= 0, sorbing	
	= 1, desorbing	
23	Flag to reverse temperature, pressure,	1(0)
-	bed loading profiles	
	= 0, no	
and the second	= 1 vac	•

2.7 Transient V-Array Data

Reference Location	Description	Data Type
R(100)	Resin pellet specific heat $(\frac{Btu}{lbOF})$	I(R)
R(101)	Thermal capacitance of heat exchanger core (Btu/OF)	1(0)
R(102)	Thermal capacitance of heating or cooling fluid (Btu/OF)	1(0)
R(103)	Multiplying factor, θ , for minimum computing interval (0 < θ > 1.0)	I(R)

2.8 Extra V-Array Data

Extra V array locations must be reserved for storing bed and gas conditions during a transient run. The number of extra locations required equals = 9* number of bed elements. Initial conditions must be entered for the first element. The corresponding conditions for the other elements will be set equal to those of the first element.

Reference	Description	
Location	for Nth Element Dat	a Type
104 + 9(N-1)	Nth element CO2 exit partial pressure (mm Hg)	1(0)
105 + 9(N-1)	Nth element CO ₂ bed loading lbsorbate lbdry resin	I(R)
106 + 9(N-1)	Nth element H20 exit partial pressure (mm Hg)	1(0)
107 + 9(N-1)	Nth element H ₂ 0 bed loading lb sorbate lb dry resin	I(R)
108 + 9(N-1)	Nth element gas outlet temperature (°F)	I(O)
109 + 9(N-1) .	Nth element bed temperature (°F)	I(R)
110 + 9(N-1)	Nth element heat exchanger core temperature (°F)	I(0)
111 + 9(N-1)	Nth element heating/cooling fluid outlet	I(0)
•	temperature (°F)	
112 + 9(N-1)	Nth element air exit pressure (mm Hg)	I(0)

- 3.0 Analytical Model Description
- 3.1 Steady State Simulation
- 3.1.1 Absorption or Purge Description

Two simplifed models are available for simulating mass transfer in a bed.

a. Based on average removal efficiency

$$\dot{\mathbf{w}}_{i,\text{out}} = \mathbf{w}_{i,\text{in}} (1-\eta_i) \tag{1}$$

where:

 $\dot{\mathbf{w}}_{1}$ = flow rate of sorbing constituent (either CO₂, H₂O, or both)

n = removal efficiency for constituent i

b. Based on average bed loading

$$\dot{\mathbf{w}}_{i,\text{out}} = (\dot{\mathbf{w}}_{i,\text{in}} - \dot{\mathbf{w}}_{i,r}) \tag{2}$$

where

$$\dot{\mathbf{w}}_{i,r} = \dot{\mathbf{w}}_{g} \left(\frac{M_{i}}{M_{g}} \frac{P_{i}}{P_{g}} \right) (1 - e^{-\beta}) \times (P_{i,in} - P_{i,b}) = \text{rate of} \qquad (3)$$
sorption of constituent (1b/hr)

w = flow rate of carrier gas (lb/hr)

M, = molecular weight of sorbing constituent (1b/1b mole)

M = molecular weight of carrier gas (lb/lb mole)

P_{i,in} = partial pressure of sorbing constituent entering bed (mm Hg)

$$\beta' \equiv \frac{KA_b M_g P_g}{\tilde{W}_g}$$


K = mass transfer coefficient between gas and bed (lb moles sorbate/ hr-ft²-mm Hg)

 $A_{h} = \text{total surface area for bed material } (ft^{2})$

 P_g = total pressure for carrier gas (mm Hg)


P_{i,b} = equilibrium partial pressure (mm Hg) for sorbing constituent corresponding to sorbate bed loading (lb sorbate/lb dry resin)

This quantity is conventionally plotted as isotherm curves in the form shown in Figure 1.



Sorbate Bed Loading (1b sorbate/1b dry resin)

Heat transfer in the bed is represented by the thermal analogue shown below:



T = ambient temperature (°F)

T_{w 2} = temperature at outside surface of insulation (°F)

T = temperature of inside wall of bed cannister (°F)

T = temperature of process gas entering (°F)

T = temperature of process gas leaving (°F)

T_h = temperature of bed (°F)

T_{hx} = temperature of integral heat exchanger (°F)

T_{p,i} = temperature of heating or cooling fluid entering (°F)

T_{f.o} = temperature of heating or cooling fluid leaving (°F)

$$C_1 = (h_g A_w + h_g A_c + h_g A_b) (\frac{1}{1-e^{-\beta}} - \frac{1}{\beta})/(e^{\beta} -1.)$$

$$c_2 = h_g A_b \left(\frac{1}{\beta} - \frac{e^{-\beta}}{1 - e^{-\beta}} \right)$$

$$C_3 = h_g A_c \left(\frac{1}{\beta} - \frac{e^{-\beta}}{1 - e^{-\beta}}\right)$$

$$C_{i_{1}} = h_{g} A_{b} \left(\frac{1}{1-e^{-\beta}} - \frac{1}{\beta} \right)$$

$$C_5 = h_g A_c \left(\frac{1}{1 - e^{-\beta}} - \frac{1}{\beta} \right)$$

$$c_6 = h_c A_c$$

$$C_7 = h_f A_F$$

$$c_8 = \dot{v}_f c_f$$

$$c_9 = h_I A_I$$

$$C_{10} = h_A A_I$$

$$C_{11} = h_g A_w (\frac{1}{\beta} - \frac{e^{-\beta}}{1 - e^{-\beta}})$$

$$C_{12} = h_g A_w \left(\frac{1}{1-e^{-\beta}} - \frac{1}{\beta} \right)$$

where:

$$h_g A_w = \text{thermal conductance between gas and canister wall (Btu/hr-oF)}$$

$$h_{I} A_{I} = thermal conductance of insulation blanket (Btu/hr-°F)$$

 $h_{\rho} A_{\rho} = \text{thermal conductance between cooling fluid and core (Btu/hr-oF)}$

 $\dot{\mathbf{w}}_{\mathbf{f}} \mathbf{C}_{\mathbf{f}} = \mathbf{flow} \mathbf{rate} \mathbf{x} \mathbf{heat} \mathbf{capacity} \mathbf{for} \mathbf{cooling} \mathbf{fluid} (\mathbf{Btu/hr}^{-o}\mathbf{F})$

h A = thermal conductance between heat exchanger core and bed (Btu/hr-oF)

h_a A_I = thermal conductance between outside surface of insulation and ambient gas (Btu/hr-*F)

Q_{sb} = heat of sorption of constituent (Btu/hr)

For both methods of simulations steady state performance, the bed is treated as a single element in the direction of flow. The network shown in Figure 2 was transformed into an equivalent thermal analogue which allows solution of the temperatures without iterations.

3.1.2 Steam Desorption

The amount of heat required to desorb a bed with an initial ${\rm CO}_2$ bed loading ${\rm X_g}$ (lb ${\rm CO}_2$ /lb bed) is given by the following equation:

$$Q = 0.26 W_p (211 - 75.) + 1. X_w W_p (211. - 75.) + Q_{amb} + X_s W_p Q_s$$
 (4)

where:

Q = total heat required for desorption (Btu/hr)

Q = total heat lost by convection and radiation to environment (Btu/hr)

 W_D = weight of dry resin in bed (1b)

X = average value of water bed loading (lb H20/lb dry resin)

 $x_s = CO_2$ bed loading at start of desorption cycle (1b CO_2 /1b dry resin)

 Q_s = heat of desorption of CO_2 (Btu/lb)

The amount of superheated steam required to provide this heat is given by

$$WSTEAM = Q/L_{p}$$
 (5)

L_v = latent heat of evaporation for steam (Btu/lb)

The CO₂ desorbed is given by the following relationship:

$$R(12) = \frac{X_8 W_p}{T}$$
 (6)

where

 τ = duration of desorption cycle (hours)

The amount of water vapor being concurrently desorbed along with the CO₂ is calculated as follows:

$$R(06) = R(12)X(\frac{PW}{PS})X(\frac{18.}{144.})$$
 (7)

where:

PS and PW equal the equilibrium partial pressures of ${\rm CO_2}$ and ${\rm H_2O}$, respectively, corresponding to the average value of bed loading ${\rm X_g}$, and ${\rm X_g}$.

3.1.3 Thermal/Vacuum Desorption

The rate of CO, desorption is calculated as follows:

$$R(12) = \frac{X_{\text{B}} W}{T}$$
 (6)

The rate of H₂O desorption is calculated by the following relationship:

$$R(06) = R(12)X(\frac{PW}{PS})X(\frac{18.}{44.})$$
 (7)

 X_{g} , W_{p} , τ , PW, and PS previously defined

The total heat required for the desorption process is calculated as follows:

$$A = R(12) \times Q_S + R(06) \times Q_W + Q_{AMB}$$
 (8)

where:

Q_W = heat of sorption of H₂O (Btu/lb)

Q_S, Q_{AMB} defined previously

The temperature change for the process heating fluid is as follows:

$$R(21) = B(02) - \frac{Q}{(WC_{p})_{B}}$$
 (9)

where:

 $(WC_p)_B = flow rate x specific heat for heating fluid (Btu/<math>^{\circ}$ F)

The outlet pressure for the desorbing gas is assumed to equal to the sum of the equilibrium partial pressure of H₂O and CO₂ corresponding to the average values of bed loading at a bed temperature of 180°F.

3.2 Transient Simulation

3.2.1 Absorption or Purge Desorption

The computer logic for the transient absorption routine is patterned after the mathematical model developed in Reference 1. The same equations described in Section 3.1.1, part b, for the steady state absorption are applied in the transient model. However, the bed is divided into up to 24 elements in the direction of flow.

Heat and mass transfer coefficients between gas and pellets may be entered as data into the program by the program user or built in relationships may be used. For heat transfer the following equations may be used:

$$\frac{h D}{k} = \frac{\phi s}{6 (1-\epsilon)} Pe \qquad (10) \qquad \text{Reference 2}$$

for P_e > 10

$$\frac{h D_p}{k} = j_H C_p G P_r^{-.666}$$
 (11) Reference 3

$$j_{H} = 0.61 \text{ Re}^{-.41}$$

$$Re = \frac{G}{A_{v} M_{f} \phi_{s}} \psi$$

h = convective heat transfer coefficient (Btu/hr-ft²-oF)

D_p = pellet diameter (ft)

 $k = gas thermal conductivity (Btu-ft/ft^2-hr-or)$

 ϕ_{q} = particle shape factor or sphericity

 ε = void fraction

P = Peclet number for heat transfer

 $C_p = gas heat capacity (Btu/lb-°F)$

G = bed mass velocity (lb/ft²-hr)

P = gas Prandtl number

 $A_{v} = \text{superficial surface area } (ft^{2}/ft^{3})$

M_p = gas viscosity (lb/ft-hr)

Analogous equations may be used for the rate of mass transfer. These equations should be used only when experimental data is unavailable. These equations ignore reaction rates and intraparticle diffusion which may be important for certain sorption operations. A technique for "backing out" mass transfer coefficients from experimental "break thru" curves is given in reference 4.

The rate of mass transfer in sorption beds depends on the sorbate equilibrium partial pressure corresponding to the sorbate bed loading. For a solid amine ${\rm CO}_2$ absorption bed, co-sorption phenomena must be taken into account since ${\rm H}_2{\rm O}$ and ${\rm CO}_2$ are simultaneously being absorbed or desorbed during a bed cycle. Thus, for this routine, equations have been built into the routine which allow prediction of the mass transfer for both constituents.

The program has options which allow equilibrium partial pressure isotherm curves to be entered in tabular form as input data. The subroutine also has built in functional relationships which may be used. These relationships apply only to H₂O and CO₂ in equilibrium with IR-45 solid amine resin and are based on a limited amount of experimental data. For H₂O vapor the equilibrium partial pressure has been found to be independent of CO₂ bed loading. Available data has been correlated as follows:

$$P_{H_2O} = .0996972 + 0.246341 X_{W}$$

$$+ 68.7792 X_{W}^{2} - 700.607 X_{W}^{3}$$

$$+ 262548 X_{W}^{4} - 3409.82 X_{W}^{5}$$
(12)

and

$$P_{H_2O, T}^* = P_{H_2O, T}$$
 $SAT = \begin{bmatrix} P_{H_2O, 77} \\ P_{H_2O, 77} \end{bmatrix}$ $\frac{537}{T}$ (13)

where:

PH20,T = equilibrium vapor pressure over IR-45 with water loading Xw at temp. T (psia)

 X_{v} = water bed loading (1b H₂0/lb dry resin)

P_{H2}0,77 = equilibrium vapor pressure over IR-45 with water loading X at temp 77°F

PH20, T = the saturation pressure of water at temperature T (psia)

For ${\rm CO}_2$ the equilibrium partial pressure has been found to depend on the ${\rm H}_2{\rm O}$ bed loading as well as ${\rm CO}_2$ bed loading:

$${}^{P}_{CO_{2,77}}^{*} = \left[\frac{0.587}{\ln (.24 + 16.7 \text{ X}_{w}) - \ln (100 \text{ X}_{s})} \right]^{2} \frac{14.7}{760}$$
 (14)

and

$${}^{P}_{CO_{2,T}}^{*} = {}^{P}_{CO_{2,T}}^{SAT} \begin{bmatrix} {}^{P}_{CO_{2,77}} \\ {}^{P}_{CO_{2,77}} \end{bmatrix}^{539/T}$$
(15)

Functions have been built into the program for H₂O and CO₂ saturation pressure as a function of temperature.

The simulation of the heat transfer in the bed is similar to that desired for the steady state module. In the transient model, each element has a thermal analogue similar to Figure 2. Lumped thermal capacitances are included for the bed, heat exchanger, and cooling fluid nodes. Temperatures for these nodes are solved by standard forward difference techniques.

3.2.2 Steam Desorption

In the steam desorption of resins, desorption is accomplished by flowing superheated steam into the bed in the axial direction. The steam condenses on the resin, heats the resin and drives off ${\rm CO}_2$. The process occurs in "chromatographic" fashion. The displaced ${\rm CO}_2$ is reabsorbed immediately ahead of the steam zone and air is displaced ahead of the ${\rm CO}_2$ -rich zone.

The computer logic required in this subroutine differs considerably from that for the absorption (or purge desorption) routine because of the "chromatographic" nature of the desorption process. The mass flow rate of the carrier gas (in this case steam) is not constant throughout the bed.

= 2 = Steam

= 3 = Air

M, = mass flow of constituents leaving element (lb/hr)

H, = enthalpy of constituents entering element (Btu/lb)

H, = enthalpy of constituents leaving element (Btu/lb)

 $h_{\mathbf{u}} A_{\mathbf{v}} = \text{thermal conductance between gas and wall of canister } (Btu/hr-°F)$

 $h_b A_b = thermal conductance between gas and bed (Btu-hr-<math>{}^{o}F$)

dm, = mass of constituent absorbed in element (lb/hr)

$$T = (T_1 + T_2)/2.$$

T₁ = temperature of gas entering element (°F)

T_o = temperature of gas leaving element (°F)


T = temperature of canister wall (°F)

T_b = temperature of bed (°F)

T_c = temperature of heat exchanger core (°F)

In order to prevent mathematical and computational difficulties, a small amount of air is introduced along with the steam. This flow is assumed to remain constant throughout the bed. The same equations used for the absorption routine then can be used (equations (2) and (3)) for predicting the mass transfer rates. The following additional assumptions were made in formulating the mathematical model for the routine.

- 1. The void volume in each element is not considered in the mass transfer equation for each element.
 - 2. Pressure drop in the bed due to friction is neglected.
 - 3. The same relationships used in the absorption routine are used in predicting heat and mass transfer rates and gas equilibrium partial pressures.
 - 4. Gaseous heat transfer is modeled by an enthalpy balance illustrated by Figure 3.



3.2.3 Thermal Vacuum/Desorption

In order to overcome the small allowable stability time computing interval associated with a multi-element model, the desorbing bed is treated as a single element. Since pressure gradients through the bed are relatively small, the single element model is sufficient for most analyses. The same model breakdown for the element is used as was shown in Figure 2. The following additional assumptions were used in preparing the analytical model.

- 1. Flow rate out of the bed is calculated by the vacuum pump component subroutine. The flow calculated is dependent both on bed pressure and the accumulator pressure into which the desorbing gas is being pumped. Thus, a minimum of at least three component subroutines is required for simulating a desorbing bed: the desorbing bed (CØSØRP), the vacuum pump (VACPMP), and the accumulator (TANKG). In addition, pipe (PIPE) or duct (DUCT) components may be inserted to simulate heat losses to the ambient.
- 2. The desorbing gas, which consists of a mixture of CO₂ and H₂O, has a pressure equal to the sum of the equilibrium partial pressures corresponding to the bed loadings for CO₂ and H₂O.
- 3. Mass concentration gradients within the pellet are negligible.
- 4. The rate of change of bed loading for sorbate i is given by the following relationship.

$$\frac{X_{A,i} - X_{A,i}}{\Delta \Theta} KV = -Q_{Z} P_{2,i}$$
 (16)

where:

 Q_{γ} = total volumetric flow rate leaving the bed (ft³/hr)

p_{2.1} = equilibrium partial pressure of sorbate i

V = total bed volume (ft³)

 $\Delta\theta$ = calculation interval (hours)

 $X_{A,i}$ = average bed loading for constituent i at time t $(\frac{1b \text{ sorbate}}{1b \text{ dry resin}})$

 $X_{A,i}$ = average bed loading for constituent i at time t + $\Delta\theta$ ($\frac{1b \text{ sorbate}}{1b \text{ dry resin}}$)

$$K = (k_i E + (1-E) \frac{\rho i RT}{Mi})$$

and

 $k_i = \frac{dp}{dx} = \text{slope of equilibrium curve for constituent i } (\frac{mm \, Hg}{1b \, \text{sorbate/lb dry resin}})$

E = bed void fraction

pi = particular density (lb/ft³)

R = universal gas constant = 555. $\frac{\text{(mm Hg) (ft}^3)}{\text{(1b moles - }^{\circ}R)}$

T = bed temperature (OR)

Mi = molecular weight of sorbate i

5. Pressure drop within the bed for the desorbing gas is calculated by the Blake-Kozeny relationship:

$$\Delta P = \frac{V_0 150\mu(1-E)^2 L}{D_p^2 E^3 g_c}$$
 (17)

where:

V = superficial velocity (ft/hr)

ΔP = pressure drop (lb/ft²)

L = one-half total length of bed (ft)

 μ = viscosity of gas mixture (lb/ft-hr)

$$= \frac{\sum_{\mathbf{y_i}} \mu_{\mathbf{i}}(\mathbf{M_i})^{1/2}}{\sum_{\mathbf{y_i}(\mathbf{M_i})^{1/2}}}$$

y, = mole fraction of sorbate i in gas phase

 $D_p = particle diameter (ft)$

g_i = conversion factor for lb_m to lb_f

=
$$41.8 \times 10^{7} (ft/hr^2) (lb_m/lb_f)$$

- 6. The same basic heat transfer model is used for calculating bed temperature as shown in Figure 2. An exception is that the gas temperature is assumed to equal the bed temperature.
- 4.0 Lower Level Subroutines and Functions

VALUE

PØLYFT

VLH2Ø

VLCØ2

HF

HG

CØABS

SDESRP

SSSØR

VACDSP

W

5.0 References

- 1. Blakely, R. L. and Taylor, B. N., "Computer Analysis Techniques for Space-craft Adsorption Beds," DAC Paper 5159, presented at AIChE Meeting at New Orleans, Louisiana, March 1969.
- 2. Kunii, D. and Suzuki, M., "Particle-to-Fluid Heat and Mass Transfer in Packed Beds of Fine Particles," International Journal Heat and Mass Transfer, Vol. 10, pages 845-852, 1967.
- 3. Bird, Stewart, and Lightfoot, "Transport Phenomenon," John Wiley & Sons, Inc., 1960, page 411.
- 4. Jackson, J. K., "Heat and Mass Transfer Analysis of Adsorption Beds Used in Spacecraft Life Support Systems," Douglas Report SM-47721, 18 September 1964, page 20.

H2ØSUM

Component Subroutine No. 12 - Water Summation

1.0 Subroutine Description

This subroutine is used to sum up the flows of condensate from 1 to 5 condensing heat exchangers. The subroutine also determines the mix temperature of the condensate flows. The total flow and temperature for the primary side of this component are set equal to these quantities.

2.0 Subroutine Data

2.1 General Notes

- 1. No source, either primary or secondary, is specified in K(NK+2) or K(NK+5).
- 2. The number of flows to be summed is entered in K(NK+16). The components which are the sources of condensate are entered in K(NK+17) through K(NK+21). A positive value is entered for the component number if the condensate is from the primary side of the component. A negative value is entered for the component number if from the secondary side.
- 3. The pressure of the water leaving $H2\emptyset SUM$ is set equal to the value entered in R(3).

2.2 Steady State K-Array Data

Reference Location	Description	Data Type
16	Number of flows to be summed (1 to 5)	I(R)
17	First component which is a source of condensate flow	I(R)
18	Second component which is a source of condensate flow	1(0)
19	Third component which is a source of condensate flow	I(O)
20	Fourth component which is a source of condensate flow	1(0)
21	Fifth component which is a source of condensate flow	1(0)

3.0 Analytical Model

The total flow and temperature are calculated as follows:

$$R(01) = \sum_{i=1}^{5} \dot{w}_{i}$$

$$R(02) = \frac{\sum_{i=1}^{5} \dot{w}_{i} T_{i}}{R(01)}$$

where:

W_i = total flow of condensate from source i

T, = temperature of condensate flow from source i

4.0 Lower Level Subroutines Required

٧V

KK

5.0 References

None.

ELDIAL

Component Subroutine No. 53 - CO₂ Electrodialysis

1.0 Subroutine Description

The performance of a ${\rm CO}_2$ electrodialysis module may be simualted with this subroutine. In this process, ${\rm CO}_2$ is electrochemically separated from cabin air. The ${\rm CO}_2$ separated may be stored or sent to an oxygen regeneration subsystem.

The electrodialysis module consists of stacks of repeating cell units of the type illustrated in Figure 1. Cabin air enters the absorber compartment where CO, is "scrubbed" out. The absorbed CO, is converted to CO, by reaction with OH ions generated by electrolysis in the cathode compartment of the stack. An anion transfer membrane between these compartments allows the OH to permeate into the absorber compartment. Because of the negative charge on the cathode, no co_3^{-} will permeate into the anode compartment. However, because of the positive charge on the anode, the CO2 ions will be drawn into the concentrator compartment. Another anion transfer membrane is used here to allow only co_3 ions to be transferred. In the concentrator compartment, CO a reacts with H to reform CO2. The H ions are generated by electrolysis in the anode compartment of the stack. A cation transfer membrane is employed between the cathode and concentrator compartments to allow transfer of only the H ions. The H ions are caused to migrate because of the negative charge at the cathode.

The above description does not discuss water permeation across the membranes. Water permeation does occur and is referred to as electroendosmosis. Water molecules may be thought of as being dragged along with the migrating ions.

The subroutine prepared considers the electrodialysis module to be comprised of a number of stacks containing a multiple number of cell units of the type shown in Figure 1. The multiple compartments of each stack are assumed to be situated between a single pair of electrodes.




FIGURE 1 CARBON DIOXIDE SCRUBBER (SCHEMATIC OF BASIC REPEATING UNIT)

For heat transfer purposes, each cell module is treated as a single lumped mass. Temperature gradients between compartments are ignored.

Because of the complex nature of the electroendosmosis phenomena, water transfer across the membranes will be set by input values for the relative humidity of the exit streams. That is, enough water will be transferred across the membranes to satisfy the relative humidity requirement. Values for relative humidity should be based on experimental results for a typical module.

The subroutine has an option which allows a sweep stream to be used in the concentrator compartment. Either gas or liquid streams may be specified.

2.0 Subroutine Data

2.1 General Notes

- 1. A primary source of flow must be specified to provide the process gas flow. The primary side flow code must be 2 or 3. The flow constituents in the source of flow must be compatible with those for the component.
- 2. As a program option, a secondary source of flow may be specified for "sweep" flow to the concentrator compartments. If the sweep flow is liquid, a flow code of 4 must be specified for the secondary side of the component. Special flow No. 2 will be assumed to be the sweep flow, and special flow No. 5 the collected $^{\text{CO}}_2$. If the sweep flow is gaseous, a flow code of 2 or 3 must be specified. The collected $^{\text{CO}}_2$ will be in R(31). If there is no sweep flow, a flow code of 2 or 3 must be specified. The collected $^{\text{CO}}_2$ again will be in R(31).
- 3. The electrodialysis unit has two additional inlet streams which provide water for electrolysis in the anode and cathode compartments. An "alternate" component must be specified for storing the outlet conditions for these two streams. The primary side for the alternate component is assumed to be the stream leaving the anode compartment of the module. Similarly, the secondary

side for the alternate component is assumed to be the stream leaving the cathode compartment. This alternate component should not be put in the solution path. Figure 2 illustrates the flow streams to the component and alternate component.

- 4. A flow code of 4 must be specified for the primary side of the alternate component. Using this option, the total flow out will be the sum of special flows 2 through 6. Special flow 2 is assumed to be liquid water. Special flow 3 is assumed to be oxygen generated by electrolysis. Special flows 4 thru 6 equal 0.
- 5. The flow code for the secondary side of the alternate component also must be 4. Special flow 2 is liquid water and special flow 4 hydrogen. Special flows 3, 5, 6 equal 0.
- 6. The components which supply sources of flow to the primary and secondary side of the alternate component are assumed to provide pure liquid water.


2.2 Instruction Options

NSTR(1): Specifies a sweep fluid for the concentrator compartment.

- = 0 no sweep fluid
- = 1 sweep fluid is a gas
- = 2 sweep fluid is a liquid

NSTR(2): Specifies method for determining current efficiency

- = 0 current efficiency is a constant value entered in R(68)
- = 1 interpolates table data for current efficiency (fraction) as a function of CO₂ feed rate (lb/hr-ft²) and current density (amps/ft²).



IN ALL LIQUID STREAMS:

SPECIAL FLUID 2 = LIQUID WATER

3 = OXYGEN

4 = HYDROGEN

5 = CARBON DIOXIDE

2.3 Heat Loss V-Array Data

Reference		•
Location	Description	Data Type
51	Temperature of module(°F)	. 0
52	Effective thermal conductance from the module	0
	to surroundings (Btu/hr °F)	
53	Total heat loss from module to surroundings (Btu/hr)	0
	R(53) = R(56) + R(59) + R(62)	·
54	Ambient gas temperature (°F)	I(R)
55	Thermal conductance between surface of module	I(R)
•	insulation and ambient gas $(\frac{Btu}{hr})$	
56	Convective heat loss to ambient gas from module	0
	(Btu/hr)	
57	Ambient wall temperature (°F)	I(R)
58	Reactor thermal radiation #A from surface of	I(R)
	insulation to ambient wall (ft ²)	
59	Radiative heat loss from module to ambient	0
	wall (Btu/hr)	••
60	Structure temperature (°F)	I(R)
61	Conductance $\frac{kA}{NX}$ between module and structure	I(O)
62	Conductive heat loss to the structure (Btu/hr)	0
63	Insulation surface temperature (°F)	0 .
64	Conductance $\frac{kA}{\Delta X}$ between module shell and outer	I(0)
	surface of insulation	,

2.4 Steady State K-Array Data

Reference Location	<u>Description</u>	Data Type
16	Component number for alternate component	I(R)
17	Number of stacks per module	I(R)
18	Number of absorber/concentrator or anode/cathode	I(R)
	compartment cell pairs	
19	Table number for current efficiency (fraction) as a	I(0)
	function of ${\rm CO}_2$ feed rate (1bCO ₂ /hr-ft ²) and current	
	density (amps/ft ²)	

2.5 Steady State V-Array Data

Reference Location		Data M
Location	Description	Data Type
65	Net heat generated in module (Btu/hr)	0
66	Current density (amps/ft ²)	_I (R)
67	Area per anode (ft ²)	I(R)
68	Current efficiency (based on 00_3) (fraction)	I(R)
69	Relative humidity of process air stream leaving	I(R)
	absorber compartment (percent)	•
70	Relative humidity of sweep gas leaving concentrator	I(R) if
	compartment (percent)	NSTR(1)#2
71	Stack voltage (volts)	I(R)
72	Power efficiency (fraction)	I(R)
73	Previous trial value for PHI (Btu/hr)*	. 0
74	Previous trial value for T _{MOD} (°F)*	0
75	Convergence tolerance for calculating cell	I(R)
	temperature (percent)	
76	Water lost by electrolysis (lb/hr)	0
77	Water added to process air by chemical	0
	reaction (lb/hr)	
78	Water added to process air by endosmosis (1b/hr)	0
79	Water added to sweep fluid by chemical reaction	. 0
	(1b/hr)	
80	Water added to sweep fluid (if a gas)	0
	by endosmosis (1b/hr)	
81	Total water lost by electrolysis, chemical	0
	reaction, and endosmosis	
82	Makeup water required for anode compartment (1b/hr)	0
83	Makeup water required for cathode compartment (lb/hr)	0

2.6 Transient V-Array Data

Referen		Data Type
84	Total module thermal capacitance (Btu/°F)	I(R)
85	Initial temperature of module at time t (°F)	I(R)

^{*} These quantities are used in the trial and error method used for determining module temperature. The technique is described in Section 3.0.

TABLE 1

CARBON DIOXIDE ABSORBER REACTIONS

Basis: Passage of 1 Faraday of electricity between electrodes = e

Component

Reaction Taking Place

Cathode Cell:

$$H_2^0 + e^- \longrightarrow OH^- + 1/2 H_2$$

Anion Transfer Membrane:

OH (cathode)
$$\frac{\text{membrane}}{\text{ion}}$$
 OH (absorber)

transport

Absorber Cell:

$$OH^{-} + 1/2 CO_{2} \longrightarrow 1/2 CO_{3}^{-} + 1/2 H_{2}^{0}$$

Anion Transfer Membrane:

$$1/2 \text{ CO}_3$$
 (absorber) $\xrightarrow{\text{membrane}}$ $1/2 \text{ CO}_3$ (concentrator)

transport

Concentrator Cell:

$$H^+ + 1/2 co_3^- \longrightarrow 1/2 co_2 + 1/2 H_2^0$$

Cation Transfer Membrane:

$$H^+$$
 (concentrator) $\frac{Membrane}{ion}$ H^+ (anode)

transport

Anode Cell:

$$1/2 \text{ H}_2\text{O} \longrightarrow \text{H}^+ + 1/4 \text{ O}_2 + \text{e}^-$$

Overall Reactions:

$$1/2$$
 CO₂ (absorber) \longrightarrow $1/2$ CO₂ (concentrator)

$$e^{-}$$
 (anode) $\xrightarrow{\text{external}} e^{-}$ (cathode)

$$1/2 \text{ H}_2\text{0} \text{ (electrodes)} \longrightarrow 1/2 \text{ H}_2 \text{ (cathode)}$$

$$+ 1/4 0_2$$
 (anode)

$$H_2^0$$
 (electrodes) \longrightarrow 1/2 H_2^0 (absorber)

3.0 Analytical Model Description

Table 1 illustrates the chemical and electrochemical reactions occurring in a CO₂ electrodialysis module of the type shown schematically in Figure 1. While Figure 1 shows only a single unit of absorber/concentrator and anode/cathode compartment cell pairs, the discussion which follows applies to any arbitrary number of repeating units.

 ${\rm CO}_2$ is converted to ${\rm CO}_3^{\infty}$ ions in the absorption compartments by reaction with $\overline{\rm OH}$ ions. The ${\rm CO}_3^{\infty}$ ions react with H ions in the concentrator compartments to reform ${\rm CO}_2$. For the type of electrodialysis cell simulated in this routine, all of the H and $\overline{\rm OH}$ involved in these reactions are formed as the result of electrolysis reactions in the anode and cathode compartments. Thus, the ${\rm CO}_2$ removed in the cells can be calculated from the amount of water electrolyzed. The amount of water electrolyzed can be determined by Faraday's law.

$$\dot{m}_{H_20} = \frac{N}{(96,500)(2)} \frac{\text{g moles } H_20}{\text{amp-sec}}$$
 (1)

From the equations shown in Table 1, one g mole of ${\rm CO}_2$ will be absorbed for every g mole ${\rm H}_2{\rm O}$ alectrolyzed. Thus,

$$g = \frac{Q\Delta C}{100 \text{ aN}} = \frac{31 \text{ i e}}{Z} \qquad \frac{\text{ft}^2/\text{hr CO}_2 \text{ absorbed}}{\text{ft}^2 \text{ of transfer area}} \tag{2}$$

where:

- Q = volumetric flow rate of air flowing through the module (ft³/hr)
- $C = concentration of <math>CO_2$ in air stream, vol %
- a = transfer area per anode (ft²/cell)
- N = total number of pairs of absorber/
 concentrator or anode/cathode compartments
- i = applied current density (amps/ft²)
- e = current efficiency (percent)
 - = 96,500 $\frac{\text{amp-sec}}{\text{g equivalent}}$
- Z = g equivalents/g mole CO2

The equations shown in Table 1 indicated that for every 1/2 mole H₂0 electrolyzed an additional mole of H₂0 is lost by migration of H⁺ and OH ions to the concentrator and absorber compartments. In addition to this amount, water is lost by the phenomena of electroend-osmosis. The rate of transfer of water by this mechanism is determined by inputing values for the relative humidity of the streams leaving the absorber/concentrator compartments. This sets the amount of water in the exit streams. The amounts of water formed by electrochemical reactions in these compartments can be calculated by the stoichiometry of the reactions. Thus, the amount of water transferred by electroend-osmosis is calculated by the net difference between the water leaving and entering the compartment and water formed by chemical reaction.

For transient heat transfer calculations, the module is treated as a single lumped mass. Thus, the exit streams for each of the four compartments are all assumed to be at one temperature. A heat balance is performed taking into account losses to the ambient due to conduction, radiation, and convection; heat absorbed by the electrolysis reaction and inefficiency in the electrochemical reactions; and the net enthalpy change for the reactants and products. Figure 2 illustrates the thermal module used for this subroutine.

The transient heat balance used on a module is given below:

$$\frac{T_{MOD} - T_{MOD}}{\Delta \Theta} G = -Q_{AM} + Q_{e} + \Sigma (m\overline{C}_{p})_{R} (T_{1} - T_{R})$$

$$-\Sigma (m\overline{C}_{p})_{P} (T_{o} - T_{R}) - \Delta H_{R}$$
(3)

where:

Q_{AM} = heat lost from module to ambient by radiation, convection and convection (Btu/hr)

Q_e = heat generated in module by inefficiency in electrochemical conversion process (Btu/hr)

 $\Sigma (mC_p)_R T_i = \text{enthalpy of reactants entering module} Btu/hr)$

 $\Sigma(\overline{mC_p})_p T_o = \text{enthalpy of products leaving module (Btu/hr)}$

G = module thermal capacitance (Btu/°F)

 $\Delta\theta$ = time interval (hours)

 ^{T}MOD , ^{T}MOD = temperature of module at time t + $\Delta\Theta$ and time t, respectively (°F)

 T_R = temperature at standard state, 25°C (77°F)

The amount of heat generated in the module by inefficiency in the electrochemical conversion process is calculated as follows:

$$Q_e = IE (1-n) \times 3.41$$
 (4)

where:

I = total current passing through module (amps)

E = total stack voltage (volts)

 η = power efficiency (fraction)

The heat balance shown in equation (3) is solved by a trial and error iteration procedure. In this procedure (3) is re-written as follows:

$$PHI = -\frac{T_{MOD} - T_{MOD}}{\Delta \Theta} G - Q_{AM} + Q_{e}$$
 (5)

+
$$\Sigma (\overline{mC_p})_R (T_i - T_R) - \Sigma (\overline{mC_p})_P (T_o - T_R) - \Delta H_R$$

For a trial value of $T_{\mbox{MOD}}$, $Q_{\mbox{AM}}$ is calculated by subroutine QSURR. Equation (5) is solved for PHI. Subroutine ESTIM is then used to determine the value of $T_{\mbox{MOD}}$ for which PHI equals zero. Convergence is satisfied when

$$\left| \frac{PHI}{Q_e + \Sigma (mC_p)_R (T_i - T_R)} \right| < \frac{R(75)}{100.}$$
 (6)

4.0 Lower Level Subroutines and Functions

QSURR

ESTIM

5.0 References:

- Brown, D. L. "Investigation of an Electrochemical Device for Carbon Dioxide Absorption and Oxygen Generation". ASD TDR 63-441, May 1963 (Ionics)
- Brown, D. L. et al.: "Performance of an Electrochemical Device for Simultaneous Carbon Dioxide Removal and Oxygen Generation", Chem. Engr. Progress Symposium Series, No. 63, Vol 62 (1966), p. 50.

H2DPØL

Component Subroutine No. 32 - Hydrogen Depolarized Cell

1.0 Subroutine Description

This subroutine is used to simulate a hydrogen depolarized cell for ${\rm CO}_2$ concentration. The cell operates as a fuel cell consuming hydrogen and oxygen to produce water and electricity. Along with this process ${\rm CO}_2$ is removed from a cabin air stream passing through the cathode compartment of the cell. The ${\rm CO}_2$ is removed by absorption and chemical reaction in a ${\rm Cs}_2$ ${\rm CO}_3$ electrolyte. The ${\rm CO}_2$ is reformed in the anode compartment by reaction of ${\rm CO}_3^-$ ions with water. ${\rm CO}_2$ is swept out along with unreacted hydrogen which flows through the compartment. The hydrogen gas depolarizes the electrode causing a shift in the chemical equilibrium in a direction favorable to reformation of the ${\rm CO}_2$.

Figure 1 illustrates the principal electro-chemical reactions occurring in the cell. As can be seen from the figure, purified air flows out of the cathode compartment. A $\rm CO_2/H_2$ mixture plus water vapor flows out of the anode compartment. By careful regulation of operating conditions, effective $\rm CO_2$ collection can be accomplished while providing a suitable feed to a Sabatier reactor. Hence, $\rm H_2$ and $\rm CO_2$ react to form $\rm CH_4$ and $\rm H_2O$. The $\rm H_2O$ can then be electrolyzed to reform oxygen.

This subroutine is a slightly modified version of a subroutine prepared by Hamilton Standard for simulation of the unit prepared for the SSP program. A complete documentation of this routine is given in reference 1.

2.0 SUBROUTINE DATA

2.1 General Notes

1. A flow code of 2 or 3 must be specified for the primary side of this component. The inlet flow to the primary side is assumed to be the air stream which is to be stripped of CO₂.




FIGURE 1. HYDROGEN DEPOLARIZED CELL

- 2. A flow code of 3 must be specified for the secondary side of this component. The inlet flow to the secondary side is assumed to be hydrogen plus some water vapor. Hydrogen enters as special flow no. 1.
- 3. The subroutine contains logic which will determine the desired condition of the electrolyte in order to meet system constraints on inlet CO₂ partial pressure, process flow rate, total pressure, operating temperatures, and dew point. The electrolyte condition is then defined in terms of the following:
 - o Partial pressure H₂0 in electrolyte
 - o Weight of H₂0 in electrolyte
 - o Maximum allowable electrolyte specific volume
 - o Minimum allowable electrolyte specific volume
 - o Maximum allowable electrolyte volume

The computer logic for determining the electrolyte condition will be performed once at the beginning of each new transient case. For CHANGE cases not starting from zero time, the logic will be performed if an integer instruction in K (NK+22) is set greater than zero. After the logic is performed, the instruction will be automatically set to zero.

2.2 Steady-State K Array Data

Reference Location	Description	Data Type
16	Table number for partial pressure water vapor (mmHg)	
	<pre>lst independent variable = electrolyte concentration (wt %)</pre>	
	2nd independent variable = temperature (°F)	

Reference Location	Description Data Type
17	Table number for electrolyte concentration (wt %)
	lst independent variable = temperature (°F)
	2nd independent variable = partial pressure water vapor (mm Hg)
18	Table number of electrolyte specific conductance (ohm-cm) ⁻¹
	lst independent variable = temperature (°F)
	<pre>2nd independent variable = electrolyte con- centration (wt %)</pre>
19	Table number for electrolyte concentration (wt %) versus electrolyte molarity (g moles/liter)
20	Table number for electrolyte molarity (g moles/liter) versus electrolyte concentration (wt %)
21	Table number for electrolyte specific volume (cm ³ /gram electrolyte) versus electrolyte concentration (wt %)
22	Table number for Reynold's factor () versus friction factor ().
23	Integer instruction to determine initial condition of electrolyte on first pass of a transient run
	0 no
	l yes

2.3 Steady State and Transient V Array Data

Reference Location	Description	Data Type
65	Maximum cabin CO ₂ partial pressure (mm Hg)	I(R)
66	Cell temperature at time zero (°F)	I(R)

D . A		
Reference Location	Description	Data Type
67	Lowest air temperature for operation (°F)	I(R)
68	Maximum air pressure for operation (psi)	I(R)
69	Maximum air flow rate for operation (cfm)	I(R)
70	Maximum air water vapor partial pressure for	÷ ,
	operation	I(R)
71	Cell length (ft)	I(R)
72	Total width of all cells (ft)	I(R)
73	Air channel dimension (in)	I(R)
74	Current collector width (in)	I(R)
75	Electrode spacing (mils)	I(R)
76	Matrix thickness before compression (mils)	I(R)
77	Matrix void volume fraction	I(R)
78	Total mass of cell stack (lb)	I(R)
79	Average Cp of cell stack (Btu/lb-oF)	I(R)
80	Available sponge vol. per ft ² of matrix	
•	area (ml/ft ²)	I(R)
81	Maximum electrolyte specific volume (cm ³ /gram)	0
82	Minimum electrolyte specific volume (cm ³ /gram)	. 0
83	Total mass H20 in electrolyte at time zero (lb)	0
84	Partial pressure of water vapor in electrolyte at	
	time zero (mm Hg)	0
85	Average cell temperature (°F)	0
86	Current efficiency for CO ₂ processing (fraction)	. 0
87	Total current (amps)	0

Reference Location	Description	Data Type
88	Power output from cell (watts)	0
89	Rate of H ₂ consumption (lb/hr)	0
90	Rate of O2 consumption (lb/hr)	0
91	Average electrolyte concentration (wt %)	0
92	Specific volume of electrolyte (cm ³ /gram)	0 .
93	Air side pressure drop across cell (psi)	0
94	H ₂ partial pressure in cell (mm Hg)	0
95	CO ₂ partial pressure in cell (mm Hg)	0
96	H ₂ 0 partial pressure in cell (mm Hg)	0
97	Volume flow rate of gas to Sabatier reactor (cfm)	0
98	Partial pressure of CO ₂ in outlet air stream (mm Hg)	0
99	Partial pressure of H ₂ 0 in outlet air stream (mm Hg)	0
100	Cell current (amps)	0
101	Cell voltage (volts)	O .
102	Heat generated in cell stack (Btu/hr)	0
103	Air side Reynolds number	0
104	Average heat transfer coefficient cell to process gas (Btu/hr ft ² -oF)	0
105	Bed temperature (°F)	0
106	Partial pressure of H ₂ O in bed (mm Hg)	0
107	Catholyte concentration (wt %)	0
108	Electrolyte conductivity (ohm cm) -1	0
109	Dimensionless number used in calculation of electrolyte	
	concentration (dimensionless)	0

Reference Location	<u>Description</u>	Data Type
110	Cell voltage (volts)	0
111	Total heat generated in cell stack (Btu/hr)	0
112	Air flow Reynolds number (dimensionless)	0
113	Average heat transfer coefficient cell to process gas (Btu/hr-ft ² -oF)	0
114	Electrolyte conductivity (ohm cm) ⁻¹	0
115	Catholyte concentration (wt %)	0
116	Electrolyte concentration (moles/liter)	0
117	Available sponge volume (cm ³ or ml)	0
118	Matrix factor (dimensionless)	0
119	Maximum electrolyte volume (cm ³)	0.
120	Minimum electrolyte volume (cm ³)	0
121	Total H ₂ O in electrolyte at time t (lb)	0
122	Partial pressure H ₂ O in electrolyte at time t (mm Hg)	0
123	Total CS ₂ CO ₃ in cell stack (lb)	0
124	Average friction factor (dim.)	0
125	Reciprocal of (area) * (modified heat transfer	
	coefficient) (hr °F/Btu)	0
126	(Area) * (mass transport coefficient) (lb/hr mm Hg)	0
127	Variable used in calculation of electrolyte concen-	
	tration (dimensionless)	0
128	CO ₂ removal rate (lb/hr)	0
129	An indicator for the operating mode of the unit	0
	0. unit is off	

1. unit is on

3.0 ANALYTICAL MODEL DESCRIPTION

A complete description of the mathematical model used for subroutine is given in reference 1.

4.0 LOWER LEVEL SUBROUTINES AND FUNCTIONS

VALUE

PRØP

FLØSUM

SK

5.0 REFERENCES

1. "Hydrogen Depolarized Cell CO₂ concentrator Computer Program Simulation", William J. Ayotte, September 10, 1971. NASA MSC Document

LIQCON

Component Subroutine No. 52 - Liquid Contactor

1.0 Subroutine Description

This subroutine simulates the liquid contactor of a liquid absorption CO_2 concentrator subsystem. In the contactor, a cabin air stream is mixed with an aqueous carbonate solution to promote absorption of CO_2 from the gas phase into the aqueous liquid phase. Either a potassium or sodium cabronate/bi-carbonate solution may be used for the liquid phase. The absorption of CO_2 is promoted by chemical reaction of the absorbed CO_2 with the carbonate solution to form bi-carbonate. The absorption reaction is favored when the temperature is approximately room temperature. Desorption or reversal of the chemical reaction can be achieved by heating the solution to approximately $180^\circ\mathrm{F}$.

A suitable zero-g design has not been defined at this time. Counter-current flow is commonly used in industrial gas/liquid absorption processes. However, it is difficult to envision a counter flow contactor for zero-g operation. For this reason, the contactor has been assumed to be designed for co-current or parallel operation.

Reference 1 has suggested ceramic saddle packing for promoting contact of the gas/liquid phases. A detailed transient simulation of this type of component would involve setting up macroscopic mass and energy balances for bed elements in the direction of the flow. In order to predict the mass transfer rate, mass transfer coefficients for both the liquid and gas phases would be required. Since a suitable contactor design is undefined at this time, a detailed analytical model of the nature described above is not warranted. However, by assuming parallel flow and that the bed is long enough for the gas and liquid phases to be in equilibrium, a suitable math model can be prepared. This provided the basis for the subroutine prepared.

Figure 1 shows the inlet and outlet streams for the contactor. Since the contactor is assumed to be operating under zero-g conditions, the outlet stream is assumed to be a mechanical mixture of gas and entrained liquid. An additional device for gas/liquid separation is assumed to be located downstream of the contactor.

2.0 Subroutine Data

2.1 General Notes

- 1. A flow code of 3 must be specified for the primary side of the component.
- 2. The source of primary flow to the component must have a flow code of 2 or 3. The source of secondary flow must have a flow code of 4.
- 3. For the secondary flow, special flow number 2 is assumed to be liquid water. Special flow 3 is carbonate and special flow 4 is bi-carbonate. The total flow is the sum of special flows 2, 3, and 4.
- 4. For the primary flow leaving the component, special flow number 2 is entrained water, special flow 3 carbonate, and special flow 4 is bi-carbonate. R(07) is set equal to zero. The gas phase is assumed to be saturated with water vapor. R(06) is set equal to this flow. The flows of remaining constituents of the gas phase are inserted in R(10) through (13).
- 5. The gas flow entering the liquid contactor should have a high relative humidity to prevent evaporative losses in the contactor.

2.2 Instruction Options

NSTR(1): Specifies type of base in liquid

- = 0 Potassium carbonate/bi-carbonate
- = 1 Sodium carbonate/bi-carbonate




FIGURE 1 LIQUID CONTACTOR FOR CO₂ ABSORPTION

NSTR(2): Specifies an option for determining the liquid flowrate required.

- = 0 Do not determine required liquid flowrate
- = 1 Determine liquid flowrate required to meet CO₂ removal efficiency specified in R(65)

2.3 Steady State V-Array Data

Reference Location	Description	Data Type
R(65)	The CO ₂ removal efficiency of the liquid	•
	contactor (fraction)	
R(66)	CO ₂ removal rate from cabin air stream (lb/hr)	
R(77)	Fraction of base that is bicarbonate in liquid	I(R) if
	entering contactor (weight fraction)	NSTR(2)=0 otherwise, 0
R(68)	The normality of the base flowing into the contactor gram equivalents liter of solution	
R(69)	Equilibrium partial pressure of CO ₂ leaving the contactor (mmHg)	0
R(70)	Fraction of base that is bicarbonate in liquid	0
	leaving the contactor (weight fraction)	•
R(71)	Mass of water evaporated into the gas phase (1b/hr)	0

3.0 Analytical Model Description

The CO₂ removal rate is predicted for parallel flow of gas and liquid phases in a packed absorption bed. The bed is assumed to be sufficiently long for the gas and liquid phases to be in equilibrium. The equilibrium relationship for the gas and liquid at the exit of the contactor is given in reference 2 as follows:

for potassium carbonate:

$$P_{CO_2,o} = \frac{45 \int_0^2 N^{1.29}}{S(1-f_0)(302-t)}$$
 (1,a)

for sodium carbonate:

$$P_{\text{CO}_2}$$
, $o = \frac{137 \text{ f}_0^2 \text{ N}^{1.29}}{\text{S}(1-f_0)(365-t)}$ (1,b)

where:

P_{CO₂,o} = partial pressure of CO₂ in exit gas leaving contactor (mmHg)

t = temperature of liquid or gas (°F)

fo = fraction of total base that is

bicarbonate in liquid leaving the

contactor (lb of base (i.e., sodium) as bi-carbonate
total lb of base (i.e., sodium)

S = solubility of CO₂ in H₂O at one atmosphere (gram moles CO₂/liter H₂O

 $N = normality of base <math>(\frac{gram equivalents}{liter})$

A least squares fit of data from reference 2 was obtained for solubility versus temperature.

$$S = A_1 + A_2t + A_3t^2 + A_4t^3 + A_5t^4$$
 (2)

where:

A. = .14202

 $A_2 = -.276085 \times 10^{-2}$

 $A_3 = .2461856 \times 10^{-4}$

 $A_4 = -.104096 \times 10^{-6}$

 $A_5 = .1659179 \times 10^{-9}$

CO, reacts with carbonate solution according to the following reaction:

$$K_2 co_3 + co_2 + H_2 0 \longrightarrow 2KHCO_3$$
 (3)

This relationship was used to derive a mass balance equation for transfer between the gas and liquid phases. This relationship is presented below:

$$2 G \left[\frac{{}^{P}CO_{2}, i}{{}^{P}T - {}^{P}CO_{2}, i} - \frac{{}^{P}CO_{2}, o}{{}^{P}T - {}^{P}CO_{2}, o} \right] = L'N (f_{o} - f_{i}) \times \frac{MW}{1000}.$$
 (4)

where:

G = total flowrate of gas (lb moles/hr)

L' = total flowrate of solution (lb moles/hr)

fo, fi = fraction of total base that is bicarbonate in solution leaving and entering, respectively (weight fraction)

PCO2,0, PCO2,i = partial pressure of CO2 leaving and

entering, respectively (mmHg)

 $P_{T} = total pressure (mmHg)$

MW = molecular weight of water

Equations (2) and (4) are combined to form a quadratic equation which is solved by the standard equation for solution of quadratic equations. The solution yields values for the two unknowns, $P_{\text{CO}_2,0}$ and f_0 .

An overall thermal balance is performed including the net enthalpy addition due to gas and liquid entering and leaving the contactor, and heat absorbed by vaporization of water into the gas phase. The heat of chemical reaction is considered to be negligible.

4.0 Lower Level Subroutines and Functions

PSAT

5.0 References:

- 1. "Mars Landing and Reconnaissance Mission Environmental Control and Life Support System Study", Hamilton Standard, 1964, p 2-30.
- 2. Perry, R. H., "Chemical Engineer's Handbook", 4th Edition, p 14-10 McGraw-Hill, New York (1960).

LQFLSH

Component Subroutine No. 56 - Liquid Flash Vaporizer

1.0 Subroutine Description

This subroutine simulates the flash vaporizer component of a liquid absorption ${\rm CO}_2$ concentrator subsystem. The component is assumed to be connected to a vacuum pump which maintains a pressure low enough to cause partial vaporization of the aqueous carbonate/bicarbonate solution entering. Along with the vaporization process, bicarbonate decomposes into carbonate and ${\rm CO}_2$. Thus, a gas phase mixture of ${\rm H}_2{\rm O}$ and ${\rm CO}_2$ and a liquid mixture of aqueous carbonate/bicarbonate is created. A suitable device is assumed to be available for achieving separation of the two phases.

The subroutine assumes that the exiting gas and liquid phases are in thermodynamic and chemical equilibrium. The vaporization process is assumed to occur at the inlet temperature. The subroutine calculates the amount of heat that must be supplied to maintain this temperature. Effective CO₂ separation can be achieved with a temperature of approximately 180°F.

Figure 1 shows the inlet and outlet stream for the liquid flash vaporizer. The separation of liquid and gas is assumed to occur within the component.

2.0 Subroutine Data

2.1 General Notes

- 1. A flow code of 4 must be specified for the primary source of the component.
- 2. There is no secondary source.
- 3. The primary outlet flow uses a flow code of 4. Special flow number 2 is assumed to be water. Special flow 3 is carbonate and special flow 4 is bicarbonate. The total flow leaving the liquid vaporizer is the sum of special flows 2, 3, and 4.




FIGURE 1. LIQUID FLASH VAPORIZER FOR CO2 DESORPTION

4. The temperatures of the solution and the gas leaving LQFLSH are equal to the temperature of the solution entering.

2.2 Instruction Options

NSTR(1): Specifies type of base in liquid

- = 0 Potassium carbonate/bicarbonate
- = 1 Sodium carbonate/bicarbonate

2.3 Heat Loss V-Array Data

Reference Location	Description	Date Type
51	Average flash vaporizer housing temperature (°F)	0
52	Effective summed conductance to ambient (Btu/hr-°F)	0
53	Component total ambient heat loss (Btu/hr)	. 0
54	Ambient gas temperature (°F)	I(R)
55	Thermal conductance between surface of insulation	146.0
	and ambient gas (Btu/hr-°F)	I(R)
56	Convective heat loss to ambient gas (Btu/hr)	0
57	Ambient radiation wall temperature (°F)	I(R)
58	Thermal radiation A factor from surface of	
	insulation to ambient wall (Ft ²)	I(R)
. 59	Radiative heat loss to ambient wall (Btu/hr)	. 0
60	Structure temperature for heat shorts (°F)	I(R)
61	Thermal conductance between flash vaporization	•
	module and structure (Btu/hr-oF)	.(R)
62	Conductive heat loss to structure (Btu/hr)	0
63	Insulation surface temperature	. 0
64	Conductance between module and outer surface	I(R)
	of insulation (Btu/Hr- $^{\circ}$ F). (If R(64) = 0, there	•
	is no insulation)	•

2.4 Steady State V-Array Data

Reference Location	Description	Data Type
R(65)	The nominal CO2 partial pressure in the exit gas	
	flash vaporization module (mmHg)	I(R)
R(66)	Decomposition rate of the bicarbonate yielding	
	CO2, H20 and carbonate (lb/hr)	0
R(67)	Fraction of base that is bicarbonate flowing into	
	the liquid flash vaporizer (weight fraction)	0
R(68)	Desired normality of the base leaving the	:
	liquid flash vaporizer (g equivalents/liter)	I(R)
R(70)	Fraction of base that is bicarbonate leaving the	
	module (weight fraction)	0
R(71)	Total heat required to maintain temperature	* 1
	at inlet condition (Btu/hr)	0
R(72)	Amount of makeup water required to maintain	+ 1 - I
	the normality of carbonate solution specified	
	in R(68) (1b/hr)	0

3.0 Analytical Model Description

When hot, aqueous carbonate/bicarbonate solution is introduced into a low pressure vessel, CO₂ gas will be liberated and a portion of the water vaporized. The gas and liquid phases are assumed to leave the vessel in thermodynamic and chemical equilibrium. The subroutine uses an iterative procedure to determine the total gas and liquid flows and molar concentrations for equilibrium conditions. The method used is outlined as follows:

1. The CO₂ partial pressure in the exit gas is assumed to be controlled to a specified value by means of a vacuum pumping system. The fraction bicarbonate in a solution in equilibrium at this pressure is given by the following relationships:

for potassium carbonate/bicarbonate:

$$P_{\infty_2,o} = \frac{{}^{2} N^{1.29}}{S(1-f_0) (302-t)}$$
 (1,a)

for sodium carbonate/bicarbonate:

$$P_{\infty_2,o} = \frac{135 \, f_o^2 \, N^{1.29}}{s(1-f_o) \, (365-t)} \tag{1,b}$$

where:

PCO₂,o = partial pressure of CO₂ in gas phase leaving vaporizer (mmHg)

t = temperature of liquid and gas
phases leaving vaporizer (F)

f = fraction bicarbonate in liquid
 stream leaving

lb of base (i.e., sodium) as bicarbonate
total lb of base (i.e., sodium)

N = normality of base in stream
leaving g equivalents
liter

S = solubility of CO_2 in H_2O at one atmosphere $\frac{\text{g moles } CO^2}{\text{liter } H_2O}$

Data from reference 1 was used to obtain a polynominal relationship for S

$$S = A_1 + A_2 t + A_3 t^2 + A_4 t^3 + A_5 t^4$$
 (2)

where:

$$A_1 = .14202$$

$$A_2 = -.276085 \times 10^{-2}$$

$$A_3 = .2461856 \times 10^{-4}$$

$$A_h = -.104096 \times 10^{-6}$$

$$A_5 = .1659179 \times 10^{-9}$$

2. Assuming the liquid normality remains constant, the fraction bicarbonate in the exit stream can be determined by equations (1,a) or (1,b). Knowing the inlet and outlet fraction bicarbonate and the total amount of base entering, the amount of bicarbonate reacting, and CO₂ generated, can be determined by the reactions chemical mass balance equations

$$2 H \omega_3^- \iff \omega_3^- + H_2 0 + \omega_2$$
 (3)

The mole fractions of each constituent in the liquid phase can then be calculated.

- 3. Using Henry's law, the equilibrium partial pressure for water vapor is determined. This is added to the CO₂ partial pressure to obtain the total pressure. The mole fraction of each constituent in the gas phase is then determined by the ideal gas law.
- 4. Knowing the molar flow rate of CO_2 (from eq. 3) and the mole fraction CO_2 and H_2O in the gas phase, the molar flow rate of H_2O in the exit gas can be determined by Dalton's law.

5. A new estimate for the normality of the exit solution is made and the above procedure is repeated until convergence is obtained within an acceptable tolerance.

After determining the outlet flows for the flash vaporization, the subroutine determines the amount of makeup water required to achieve the desired normality specified in R(68). The amount of process heat that must be supplied to maintain the outlet temperature equal to the inlet temperature is also determined. This heating is assumed to be supplied by a heating coil inside the vaporizer.

4.0 Lower Level Subroutines and Functions

PSAT

QSURR

HG

5.0 References

 Perry, R. H., "Chemical Engineers' Handbook", 4th Edition, p 14-10, McGraw-Hill, New York (1960).

MEMOD

Component Subroutine No. 55 - Membrane Module Subroutine

1.0 Subroutine Description

This subroutine simulates the transport across membranes (membrane permeation) of selected gasses such as ${\rm CO_2,N_2,\ O_2}$ and ${\rm H_2O}$. Membrane permeation is a concentration process accomplished by selective diffusion of a specified gas due to a partial pressure gradient.

The membrane module consists of membranes packaged in multiple layers with intervening backing screens. The supply gas or feed gas is forced laterally through every other screen and the "sweep gas" used for the removal of diffusing constituent is forced through the alternate screens. The critical parameter for determining the diffusion rate of a gas through a membrane is its permeability which is defined as follows:

Concurrently with the mass transfer of gasses that occurs, thermal energy is also transferred through the membrane and through the module housing. Since the thickness of the membrane is small, the thermal conductance through the membrane is very large in comparison to the heat transfer coefficient of both sides of the membrane. Thus, only the convective heat transfer coefficients are considered in evaluating the heat flow through the membrane. This subroutine models the heat flow to the housing and from housing to the surroundings by working with only one housing temperature which is assumed to be the average temperature.

The subroutine is generalized in that there are no restrictions on type of feed or sweep gases. In addition to having the capability of simulating diffusion of species mentioned above, the program also can simulate the diffusion of one special flow species. Thus such processes such as hydrogen separation through a semi-permeable membrane may be simulated.

While the mathematical model described in Section 3.0 is described in terms of rectangularly shaped cells, any regular shaped cell can be handled. For instance a cell consisting of concentric cylinder with feed gas flowing in the inner cylinder

and sweep gas in the annular can be simulated.

Figure 1 illustrates a gas separation module with multiple number of rectangular shaped cells. This configuration is simulated by specifying the characteristic dimensions of a membrane cell and the number of membrane cells. The characteristic dimensions required are the cell frontal areas and the length, the area of membrane separating the cell pair, and the thickness of the membrane.

A cell with a vacuum on one side, rather than sweep gas, may also be simulated. Here a dummy flow must be supplied to the side with the vacuum which will always be the secondary side. Actually, this is the flow out of the cell as determined by a vacuum pump. A special option (NSTR(1)=1) must be flagged to instruct the program that no flow is entering the secondary side of the cell.

2.0 Subroutine Data

2.1 General Notes

- 1. Only flow codes 1,2, or 3 are allowed by the subroutine. The program deals with diffusion of gases through a membrane.
- 2. A certain level of non-condensable flow must always be specified in both sides of the module.
- 3. This subroutine can compute diffusion rate of 6 gas species simultaneously, provided that the permeability factors of each component gases are input. Excluding the permeability factors for any component gases is equivalent to setting the value to zero.


2.2 Instruction Options

NSTR(1): Secondary side is connected to a vacuum pump

- = 0 Secondary side is not connected to a vacuum pump
- = 1 Secondary side is connected to a vacuum. The diffused gas is removed by using a vacuum pump. A dummy secondary flow must be provided which is actually the flow out of the cell. This flow should be calculated using the vacuum pump subroutine (VACPMP)

2.3 Steady State K-Array Data

Reference Location	Description	Data Type
16	Total number of membrane cells in the module, NMEM. (If the number is not input the value is assumed to be one). Figure 1 illustrates	I(R)
•	the definition of membrane cells.	



MEMBRANE CELL EXAMPLE:

- 6 MEMBRANES
- 3 STEAM CELLS
- 3 AIR CELLS, 2 HALFS + 2 FULL MEMBRANE CELLS = MEMBRANES = 6

2.4 Heat Loss V-array Data

Reference Location	Description	Data Type
51	Avg. Temperature of the housing wall (°F)	0
52	Effective thermal conductance from the module wall	0
53	Total heat loss to surroundings (Btu/hr)	0
	R(53) = R(56) + R(59) + R(62)	
54	Ambient gas temprature (°F)	I(R)
55	Thermal conductance (UA) between surface of insulation	ı I(R)
	and ambient gas (Btu/hr-oF)	
56	Convective heat loss to ambient gas (Btu/hr)	0
57	Ambient wall temperature (°F)	I(R)
58	FA between ambient wall and surface of insulation(Ft ²)	I(R)
59	Radiative heat loss to ambient wall (Btu/hr)	0
60	Structure temperature (°F)	I(R)
61	Conductance (KA/X) between module and structure	I(R)
	(Btu/hr-°F)	
62	Conductive heat loss to structure (Btu/hr)	. 0
63	Insulation surface temperature (°F)	. 0
64	Conductance (KA/X) between the module housing and	I(R)
	outer surface of insulation Btu/hr-oF)	٠.
•	(If R(64)=0, there is no insulation)	

2.5 Steady State V-Array Data

Reference Location	Description	Data Type
65	Membrane area for a cell. Total area for the module is obtained by multiplying number of cells with the membrane area. (Ft ²)	I(R)
66	Membrane thickness. (inches)	I(R)
67	Oxygen permeability through the membrane (Ft ³ /hr (STP)) (inches) (Ft ²) (mmHg)	7(7) 48 4)
68	Diluent (normally nitrogen) permeability through the membrane (Ft ³ /hr (STP)) (inches) (Ft ²) (mmHg)	I(R), if the value is not input then diffusion

Reference Location	<u>Description</u>	Data Type
69	Carbon dioxide permeability through the membrane	of this
	(Ft ³ /hr (STP)) (inches)	species is
	(Ft ²) (mmHg)	not con-
70	Trace contaminant permeability through the	sidered
	membrane $\frac{(\text{Ft}^3/\text{hr (STP)}) \text{ (inches)}}{(\text{Ft}^2) \text{ (mmHg)}}$	
71	Special flow #1 permeability through the membrane	
•	$\frac{(\text{Ft}^3/\text{hr (STP)}) \text{ (inches})}{(\text{Ft}^2) \text{ (mmHg)}}$	· .
72	Water vapor permeability through the membrane	
	(Ft ³ /hr (STP)) (inches) (Ft ²) (mmHg)	
73	Oxygen concentration of effluent gas stream, primary	0
	side. (mole fraction)	
74	Diluent (N2) concentration of effluent gas stream,	0
***	primary side. (mole fraction)	
75	Carbon dioxide concentration of effluent gas stream,	0
	primary side (mole fraction)	
76	Trace contaminant concentration of effluent gas	0
,	stream, primary side. (mole fraction)	
77	Special flow #1 concentration of effluent gas stream,	. 0
	primary side. (mole fraction)	
78	Water vapor concentration of effluent gas stream,	0
•	primary side. (mole fraction)	
79	Oxygen concentration of effluent gas stream, secondary	0
	side. (mole fraction)	•
80	Diluent concentration of effluent gas stream,	.0
	secondary side. (mole fraction)	
81	Carbon dioxide concentration of effluent gas stream,	0
	secondary side. (mole fraction)	
82	Trace contaminant concentration of effluent gas stream	, 0
٠.	secondary side. (mole fraction)	
83	Special flow #1 concentration of effluent gas stream,	0
	secondary side. (mole fraction)	
84	Water vapor concentration of effluent gas stream,	0
	secondary side. (mole fraction)	
85	Oxygen permeation rate through the membrane (lb/hr)	0
86	Diluent permeation rate through the membrane (1b/hr)	0

Reference Location	<u>Description</u>	Data Type
87	CO ₂ permeation rate through the membrane (lb/hr)	0
88	Trace contaminant permeation rate through the membrane. (lb/hr)	0
89	Special flow #1 permeation rate through the membrane (lb/hr)	. 0
90	Water vapor permeation rate through the membrane (lb/hr)	0
91	Thermal conductance (total) between cell gas and module wall, primary side, (Btu/hr-of.)	I(R)
92	Thermal conductance (total) between cell gas and module wall, secondary side, (Btu/hr-°F)	I(R)
93	Effective thermal conductance through a membrane (summed) (Btu/hr-oF)	I(R)
94	Effective specific heat of effluent gas, primary side (Btu/lb-°F)	0
95	Effective specific heat of effluent gas, secondary side (Btu/lb-oF)	0
96-100	Locations not used	

2.6 Transient V-Array Data

All of the transient V-array data that is of I(R) type must be input for transient solution; otherwise steady state solution will be used.

Reference Location	Description	Data Type
101	Volume of module (total), primary side,(Ft3-)	0
102	Volume of module (total), secondary side, (Ft3)	O
103	Module Length, (Ft.)	I(R)
104	Frontal Area (Free flow area) of a cell primary side (Ft ²)	I(R)
105	Frontal Area (Free flow area) of a cell, secondary side (Ft ²)	I(R)

Reference Location	Description	Data Type
106	Thermal capacitance of module shell (Btu/°F)	I(R)
107	Multiplying factor used in computing stability line	I(R)
	increment in forward difference solution of temper-	
	atures and concentrations $(0 < \Delta \theta < 1.0)$	
108	Minimum allowable computing interval (Seconds)	I(R)

3.0 Analytical Model Description

The analytical model description presented in the following describes a membrane cell with heat and mass flowing through/to cell sides A and B.

3.1 Mass Balance

The equation of continuity for gas flowing through a system for constant density, R_{A} and diffusivity D_{AB} is given as follows:

Bulk Flow Term

$$\frac{\partial C_A}{\partial t} + \sqrt{x} \frac{\partial C_A}{\partial x} + \sqrt{y} \frac{\partial C_A}{\partial y^2} + \frac{\partial^2 C_A}{\partial z^2} = 0$$
Diffusion term

$$\frac{\partial C_A}{\partial t} + \sqrt{x} \frac{\partial C_A}{\partial x^2} + \frac{\partial^2 C_A}{\partial y^2} + \frac{\partial^2 C_A}{\partial z^2} + \frac{\partial^2 C_A}{\partial z^2} + \frac{\partial^2 C_A}{\partial z^2} = 0$$


where:


 $C_A = Concentration (\frac{1b}{ft3})$

 $V_i = Velocity (\frac{Ft}{Sec})$

x,y,z = Length dimensions (ft)

D_{AB} = Diffusivity (ft²/hr)





TOP VIEW

3.1 (Cont)

Assumptions:

- No chemical reaction, i.e. $R_A = 0$
- Bulk flow in x direction only, Vy and Vz = 0.
- 3. Diffusion in y direction only, the diffusion in x direction is negligible, as compared to bulk flow to merit consideration.

Taking into account the forementioned assumptions, equation 1 reduces to

$$\frac{9F}{9C^{a}} = -\sqrt{\lambda} \frac{3\lambda}{9C^{a}} + B^{a}B \frac{9A_{3}}{9_{3}C^{a}}$$
 (5)

The partial differential in the above equations may be approximated as follows:

$$\frac{\partial C_{\mathbf{a}}}{\partial t}\Big|_{\mathbf{x}+\mathbf{D}\mathbf{X}^{2}} = \frac{C_{\mathbf{A}+\mathbf{a}t}-C_{\mathbf{A}t}}{\Delta t}\Big|_{\mathbf{x}+\mathbf{D}\mathbf{X}^{2}} \tag{3}$$

The bulk transfer term:

$$\partial_{x} \frac{\partial C_{x}}{\partial x}\Big|_{x} = \partial_{x} \frac{C_{xx+xx+2}-C_{xx+xx+2}}{\triangle x}\Big|_{x}$$
 (4)

and the diffusion term:

$$\frac{\partial AB}{\partial y^2} \left| \frac{\partial^2 CA}{\partial y} \right|_{y+\Delta y/2} = \frac{\partial CA}{\partial y} \left|_{y+\Delta y/2} \frac{\partial CA}{\partial y} \right|_{y-\Delta y/2} \\
= \frac{D_{AB}}{\Delta y} \left\{ \frac{(C_{Ay+\Delta y/2} - C_{Ay}) - (C_{Ay} - C_{Ay-\Delta y/2})}{\Delta y} \right\}$$
1 letting Ca = C, and rewriting equation 2 using 3, 4, and 5

$$\frac{C_{t+\Delta t} - C_t}{\Delta t} = \frac{\sqrt{\chi (C_{X-\Delta X/2} - C_{X+\Delta X/2})}}{\Delta \chi}$$

$$+ \frac{9_{AB}}{\Delta y} \left\{ (C_{y+\Delta y/2} - C_y) + (C_{y-\Delta y/2} - C_y) \right\}$$
(6)

for a membrane module cell equation 6 may be written for each diffusing constituent:

$$\frac{C_{o}'-C_{o}}{\Delta t} \qquad V = Q \left(C_{i}-C_{o}\right) + \frac{D_{AB}'}{\Delta y} A(C^*-C_{o}) \qquad (7)$$

where:

 $Q = Total volumetric flowrate (Ft^3/hr)$

C_i = Concentration of constituent entering cell (lb/Ft³)

Co = Concentration of constituent leaving the cell, also the concentration in the cell (lb/Ft³)

 C^* = Concentration of constituent on the other side of the membrane (1b/Ft³)

 D_{AR} = Effective diffusivity of gas

 $A = Membrane area (Ft^2)$

Since the resistance to diffusion in the gas phase is negligible compared to the diffusional resistance of the membrane, the effective diffusivity defined above is equal to the permeability of the membrane.

For transient analysis, equation (7) is applied to all diffusing species on both sides of the membrane. For steady state conditions, the equation reduces to the following:

for side A
$$O = Q_A(C_1, A-C_0, A) + D'_{AB}(C_0, B-C_0, A)$$
 (8)

for side B
$$0 = Q_B (C_{i,B} - Co_{B}) + D'_{AB} A (Co_{A} - Co_{B})$$
 (9)


Equations 8 and 9 are solved simultaneously for Co, and Co,

The transient solution requires a test which determines if the minimum computed time interval is smaller than the minimum allowed computing interval. The stability time increment is computed for each gas species diffusing through the membrane. A steady state solution is used for those with minimum computing interval less than the specified minimum allowable time increment.

3.2 Thermal Balance

Heat transferred through the membrane and heat losses to the surroundings, radiation, convection and conduction are modeled. A schematic drawing of a membrane module is shown in Figure 2. Figure 3 shows the transient lumped parameter nodal network.

PARAMETERS THAT ARE "A" SUBSCRIPTED PERTAIN TO PRIMARY SIDE OF THE MODULE WHILE "B" SUBSCRIPTED PARAMETERS REFER TO THE SECONDARY SIDE OF THE MODULE.



$$q_{INS} = UA_{INS} (T_H - T_{INS}) = q_{conv} + q_{rad}$$

$$q_{surr} = q_{cond} + q_{conv} + q_{rad}$$

$$q_{surr} = hA_A (T_H - T_A) + hA_B (T_H - T_B)$$

$$q_{AB} = hA_M (T_B - T_A)$$


FIGURE 2 THERMAL MODEL FOR MEMBRANE MODULE

R(53) = Total heat loss to surroundings = R(56) + R(59) + R(62)

R(59) = Radiative heat loss to ambient wall = FA $(T_{INS}^{\mu} - T_{W}^{\mu})$, = FA = R(58)

R(56) = Convective heat loss to ambient gas = $C_8(T_{INS} - T_S) = UA_{conv}(T_{INS} - T_g) = R(55)(T_{INS} - T_g)$

 $R(62) = Conductive heat loss to structure = C_6(T_H - T_S) = \frac{KA}{X}(T_H - T_S) = R(61)(T_H - T_S)$



 T_H = Module Housing Temperature, R(51)

 T_{INS} = Temperature of the insulation, R(63)

 T_{u} = Ambient wall temperature, R(57)

T_S = Structure temperature, R(60)

T_A = Fluid temperature in module, also effluent, primary, R(1)

 T_R = Fluid temperature in module, also effluent, secondary, R(20)

Tfi,A - Primary inlet temperature, A(1)

T_{fi} B Secondary inlet temperature, B(1)

 T_g = Ambient gas temperature, R(54)

mCp = Thermal capacitance of the module housing R(106)

FIGURE 3 LUMPED PARAMETER NODAL NETWORK

The thermal model, as shown in Figure 3, does not take into account the mass transfer through the membrane and does not analyze the rate of energy change of individual gas species. In addition, only the capacitance of the module shell is considered for predicting thermal balance during transient solution.

From Figure 3 we can obtain the following relationships

$$c_1 (T_{fi,A} - T_A) - c_3 (T_A - T_B) - c_4 (T_A - T_H) = 0$$
 (10)

and

$$C_2 (T_{fi,B} - T_B) - C_3 (T_B - T_A) - C_5 (T_B - T_H) = 0$$
 (11)

where:

 $C_1 = (w C_p)_A$, flow conductance fluid, secondary side, (Btu/hr-°F)

 $C_2 = (w C_p)_B$, flow conductance fluid, secondary side, (Btu/hr-°F)

 $C_3 = R(110)$, thermal conductance through the membrane, (Btu/hr- $^{\circ}$ F)

 C_{\downarrow} = R(108), conductance between internal fluid and module wall, primary side, (Btu/hr^oF)

C₅ = R(109), conductance between internal fluid and module wall, secondary side,(Btu/hr⁻F.)

Equations (10) and (11) can be solved simultaneously once the wall temperature $T_{\rm H}$ is established. An iteration procedure utilizing subroutine QSURR is used to solve the above equations. First the heat loss from the inside of the module to the surface is calculated using equations (10) and (11) for an estimated value of $T_{\rm H}$. Using the same estimated value for $T_{\rm H}$, the heat loss from the surface to

surroundings is determined using subroutine QSURR. Subroutine ESTIM then is used to estimate a better value for $T_{\rm H}$. Iterations are continued until convergence is reached.

For transit calculations, the iteration procedure is not required. Here the wall temperature is calculated using the following:

$$\frac{T_{H}' - T_{H}}{\Delta t} mc_{P} = c_{4} (T_{A} - T_{H}) + c_{5} (T_{B} - T_{H}) - q surr$$
 (12)

where:

m C_p = thermal capacitance of the tank shell (Btu/°F)

q surr = heat loss to surroundings, computed by QSURR(Btu/hr)

 $T_{H'}$, T_{H} = housing temperature at time t + \triangle t and t respectively (°F) \triangle t = compute time interval (hr)

Subroutine MEMOD also accounts for possible condensation of water vapor that may occur in either cell sides, A or B, by computing the effective specific heat. The scheme used by this subroutine is similar to the scheme used by subroutine EFFCP. Details of the procedure are outlined in the EFFCP writeup.

4.0 Lower Level Subroutines and Functions Required

HF (T)

HG (T)

ESTIM (X,Y1,Y11,Y2,Y22,A,NSTR(1))

QSURR

PSAT(T)

TSAT(T)

5.0 References

Subroutine EFFCP of Program G189 Manual

MLCARB

Component Subroutine No. 54 - Molten Carbonate Cell

1.0 Subroutine Description

This subroutine is used to simulate the thermodynamic, chemical, and electrochemical processes in a molten carbonate cell. The molten carbonate cell is used for the absorption of CO_2 from cabin air and subsequent conversion to O_2 and C . The device thus is a direct oxygen regeneration subsystem which does not require another subsystem for CO_2 concentration (removal). The chemical and electrochemical reactions occur in a liquified entectic mixture (melt) of LiCl and $\mathrm{Li}_2\mathrm{O}$. The process must be operated at a relatively high temperature (550°C) to prevent solidification of the melt.

The mass transfer in the molten state is treated from a quasi-steady state viewpoint. That is, transient diffusional effects are not considered. The cell is treated as a single lumped mass as far as the transient thermal balance is concerned. Heat transfer to the ambient and the enthalpy change for the reaction are included in the temperature balance. Temperature control is achieved primarily by insulation of the housing. The subroutine also allows a miscellaneous heat source to simulate electrical heaters for use in temperature control.

The subroutine makes no assumptions regarding the design concept for the cell. Thus, no assumptions are made concerning the means used for gas/liquid separation.

Many system design parameters for this concept have not been fully defined at this juncture. The composition of the melt, operating temperature, electrode materials and a few of the items which may change before a viable system is evolved. The question of the advisibility of a "dry" or "wet" melt is also unresolved. That is, should the inlet gas be predried to eliminate side reactions involving water vapor? Alternatively, what humidity

level should the inlet gas be controlled to for optimum operation. For the subroutine prepared here, the inlet gas is assumed to be dried to a level when water vapor reactions are negligible. Certain additional assumptions were made.

- 1. The melt is an eutectic mixture of LiCl and Li₂0. Melting point for the mixture is 509°C. Composition is 70% LiCl and 30% Li₂0.
- 2. Side reactions involving formation of H_2 and CH_4 are ignored.
- 3. The cathode region is assumed to be shielded to prevent mixing of CO₂ and carbon deposited on the electrode. This will prevent formation of CO which would contaminate the purified air leaving the cell.
- 4. The anode current density is assumed to be low enough for adequate ionic diffusion. Thus adverse side reactions are prevented which would allow CO₂ contamination of the oxygen generated at the anode.
- 5. The process is assumed to have 100% current or Faradaic efficiency. Inefficiency due to cell overvoltage and Joule heating are taken into account. The difference between the applied voltage and the theoretical cell voltage times the current results in heat being dissipated in the module. All this heat is assumed to be dissipated in the melt.

2.0 Subroutine Data

2.1 General Notes

- 1. A primary source flow must be specified to provide an inlet gas flow. The primary side flow code must be 2 or 3. The flow constituents in the source of flow must be compatible with those for the component.
- The module is assumed to be composed of a number of cells connected in parallel. The number of cells is specified in K(NK+16).
- 3. A flow code of 2 or 3 must be specified for the secondary side of this component. The secondary flow out of this component will be composed of the oxygen gas generated in the cell.

2.2 Instruction Options

NSTR(1): Specifies method for determining cell voltage

- = 0 Cell voltage is calculated from theoretical cell voltage and power efficiency specified in R(69)
- Cell voltage is determined by interpolating a table of values of cell voltage versus current density (amps/ft²) and cell temperature (°F)

NSTR(2): Specifies method for determining cell current

- = 0 Cell current is a constant value input in R(67)
- Cell current required to remove all CO₂ in inlet gas stream is calculated by subroutine

2.3 Heat Loss V-Array Data

Reference Location	Description	Data Type
51	Temperature of module shell (°F)	0
52	Effective thermal conductance from module shell	0
	to surroundings (Btu/hr °F)	
53	Total heat loss to surroundings (Btu/hr)	0
	R(53) = R(56) + R(59) + R(62)	
54	Ambient gas temperature (°F)	I(R)
55	Thermal conductance between surface of insulation	I(R)
	and ambient gas (Btu/hr-°F)	
56	Convective heat loss to ambient gas (Btu/hr)	# 0 /
57	Ambient wall temperature (°F)	I(R)
58	Thermal radiation FA from surface of insulation	I(R)
	to ambient wall (ft ²)	
59	Radiative heat loss to ambient wall (Btu/hr)	. 0
60	Structure temperature (°F)	I(R)
61	Conductance (kA/ Δ X) between module shell and	I(R)
	structure (Btu/hr)	· ,

		•
Reference	Description Description	Data Type
62	Conductance heat loss to the structure (Btu/hr)	0
63	Insulation surface temperature (°F)	0
64	Conductance (KA/AX) between module shell and outer	1(0)
	surface of insulation (Btu/hr-°F)	•
2.4 Ste	ady State K-Array Data	
Reference Location	e <u>Description</u>	Data Type
16	No. of parallel cells per module	I (R)
17	Table number of cell voltage versus current	1(0)
	density (amps/ft ²) and temperature (°F)	
2.5 Ste	ady State V-Array Data	
Reference Location	Description	Data Type
65	Heat dissipated by electrical heater (Btu/hr)	I(0)
66	Heat dissipated in module due to cell	0
	inefficiency (Btu/hr)	
67	Cell current (amps)	I(R) if NSTR(2)=0
68	Cell voltage (volts)	0
69	Power efficiency, n (decimal fraction) Ecell Etheor	I(R) if NSTR(1)=1
	Tcell Theor	
70	Electrode area (ft ²) per cell	I(R) if NSTR(1)=1
71	Current density (amps/ft ²)	. 0
72	Convergence tolerance for calculating cell	I(R)
,	temperature (percent)	
73	Total CO ₂ conversion rate (lb/hr)	0
74	Previous trial value for PHI (Btu/hr)*	0

^{*}These quantities are used in the trial and error method used for determining cell temperature. The technique used is described in Section 3.0.

Reference Location		Description	Data Type
75	Previous trial value	to T _{cell} (°F)*	0
76	Rate of formation of	**	0

2.6 Transient V-Array Data

Location	Description	Data Type
R(77)	Total module thermal capacitance for shell and melt (Btu/°F) (If zero, a steady state solution is used.)	I(0)
R(78)	Cell initial temperature (°F) at time t	I(R)

3.0 Analytical Model Description

The basic chemical and electrochemical reactions occurring at the electrodes of a molten carbonate cell are given below:

at the cathode:

and
$$4Li + CO_2 \longrightarrow 20^{-} + 4Li^{+} + C$$
 (2)

or, a net reaction of

$$co_2 + 4e - > 20^2 + C$$
 (3)

at the anode:

$$20^{-} \longrightarrow 0_2 + 4e$$
 (4)

The net reaction for the complete cell is

$$\omega_2 \longrightarrow c + o_2 \tag{5}$$

Using Faraday's law and assuming 100% Faradaic (current) efficiency, the ∞_2 decomposition rate is

$$W_{CO_2} = I/1100$$
 1b CO_2/hr (6)

^{*}These quantities are used in the trial and error method used for determining cell temperature. The technique used is described in Section 3.0.

The cell voltage (neglecting side reactions) is

E = 1.025 -
$$\frac{RT}{4F}$$
 In $\frac{{}^{P}CO_{2}, c}{{}^{P}O_{2}, a}{}^{Q}$ (7)

where

F = 96,500 coulombs

R = 8.312 international joules/°K-g mole

T = Cell temperature, °F

 P ∞_{2} ,c = partial pressure of ∞_{2} at cathode (mmHg)

P_{CO₂,a} = partial pressure of CO₂ at anode (mmHg)

PO2, a = partial pressure of O2 at anode (mmHg)

at 550°C and assuming inlet gas partial pressure of 152 and 3.8 mmHg, respectively, for 0_2 and CO_2 , the cell voltage can be shown (reference 1) to equal

$$E = 1.465 \text{ volts} \tag{8}$$

The actual cell voltage required has been found to be in the range of 1.6 to 2.0 volts. The subroutine has an option for entering tabular data for cell voltage as a function of current density and cell temperature. Alternatively, the cell voltage can be calculated from the cell efficiency.

$$E_{cell} = \frac{1.025}{\eta}$$
 (9)

For heat transfer purposes, the module shell and melt are treated as a single lumped mass. Provisions are made for heat losses to the surroundings by conduction to a structure node, and convection and

radiation to the ambient. A miscellaneous heat source simulating the input of an electrical heater may be specified. The amount of module insulation is specified by the program user. A schematic for the module thermal model is shown in Figure 1.

The net enthalpy added by the influx and efflux of reactants and products, respectively, and the heat absorbed by chemical reaction also is included in the cell heat balance. Since the enthalpy change is independent of the thermodynamic path chosen, the net enthalpy added to the melt is as follows:

$$\Delta H_{T} = \left(\overline{NC_{P}}\right)_{R} \left(T_{in} - T_{o}\right) - \left(NC_{P}\right)_{P} \left(T_{out} - T_{o}\right) - \Delta H_{T_{o}} \left(DCO_{2}\right)$$
 (10)

where:

(NC_p)
R = average hourly heat capacity of reactants (Btu/°F-hr)

 $\left(\overline{NC_p}\right)_p$ = average hourly heat capacity of products (Btu/°F-hr)

 ΔH_{T_0} = heat of reaction (heat absorbed) at 77°F

= 94,052 x 1.8 (Btu/lb mole ∞_2)

 $DCO_2 = CO_2$ reacted (1b mole/hr)

T = base temperature for reaction = 77°F

T₁ = inlet temperature of reactants (°F)

Tout = outlet temperature of products (°F)

Rather than using the average specific heats as indicated above, the subroutine uses the integrated enthalpy change for each reactant or product constituent.

$$\Delta H_{i} = N_{i} \int_{T_{0}}^{T} (aT^{-2} + bT^{-1} + cT^{0} + dT^{1} + eT^{2}) dT$$
 (11)

where:

N, = flow rate of constituent (lb moles/hr)

ΔH_i = enthalpy change for constituent i between temperature T and T_o (Btu/hr)

a,b,c,d = experimentally determined coefficients
for heat capacity as a function of
 temperature. The value of the
 constants for the major gas con stituents in the cell are given
 in Table I.

The heat balance for the module temperature is given below:

$$\frac{T_{cell} - T_{cell}}{\Delta \tau} G = -QLØSS + P + QE + \Delta H_{T}$$
 (12)

where:

QLØSS = net heat loss to the surroundings by conduction, convection, and radiation (Btu/hr)

P = electrical energy dissipated in the cell due to inefficiency and joule heating = (E_{cell} - 1.025) x I x 3.41 (Btu/hr

QE = electrical energy dissipated by heaters (Btu/hr)

$$C_p = -187700. T^{-2} + 8.27 + .000258T \frac{cal}{g \text{ mole }^{0}K}$$

$$C_{p} = 6.50 + 0.00100T$$
 $C_{p} = 8.22 + 0.00015T + 0.00000134T$

$$co_2$$
 $c_P = -195500.T^{-2} + 10.34 + 0.00274T^{1}$




FIGURE 1 THERMAL MODEL FOR MOLTEN CARBONATE CELL

G = lumped thermal capacitance
 of cell (Btu/°F)

Tcell , Tcell = temperature of cell at time t + Δτ and time t, respectively (°F)

 $\Delta \tau = computing time increment (hours)$

Equation (12) is rewritten in the following form for solution by a trial and error technique.

$$PHI = -\frac{T_{cell} - T_{cell}}{\Delta \tau} G - QLØSS + P + QE + \Delta H_{T}$$
 (13)

For a trial value of T_{cell}', QLØSS is calculated using subroutine QSURR. Equation (13) is solved for PHI. Subroutine ESTIM is then used to determine the value of T_{cell}' for which PHI equals O. Convergence is satisfied when:

$$\frac{PHI}{(P + QE + (NC_P)_R^{(T_{in})}} < \frac{R(72)}{100}.$$

4.0 Lower Level Subroutines and Functions

QSURR

ESTIM

5.0 References

- 1. Arnoldi, W. E.: "An Electrolytic Process for Carbon Dioxide
 Separation and Oxygen Reclamation." Atmosphere in Space Cabins
 and Closed Environments, Meredith Publishing Co., 1966, pp. 76-103.
- Stein, P. J.: Research and Development Program for a Combined Carbon Dioxide Removal and Reduction System. Hamilton Standard Division, Contract No. NAS1-4154, Final Report - Phase I. Oct 1965.

SMGEN

Component Subroutine No. 27 - Steam Generator

1.0 Subroutine Description

The steam generator subroutine is used to supply superheated steam for use in various EC/LS subsystems. Options are available either to calculate the required heat input to meet a specified steam generation rate or to calculate the steam generation rate for a specified value of heat input. An option is available to simulate boilers with thermal energy being supplied by electrical current, a miscellaneous heat source such as a radioisotope, or a process heating fluid.

2.0 Subroutine Data

2.1 General Notes

- 1. The flow code for the primary side of this component is 1, 2, or 3. The component which provides the source of primary flow must have a flow code of 0 or 4.
- 2. The flow code for the secondary side of this component is 0 or 4.

 The component which provides the source of this secondary flow must also have a flow code of 0 or 4.
- 3. A primary flow source must be specified regardless of the instruction options (NSTR's) selected. The source will provide the inlet temperature and pressure for the water being vaporized. Outlet pressure of vapor is set equal to this value.
- 4. A secondary flow source must be specified only if the heat source for the generator is process heating fluid.
- 5. The generator is assumed to be perfectly insulated. Heat losses from the unit may be simulated with pipe or duct components up or downstream of the component.

2.2 Instruction Options

NSTR(1): Type of generator

- = 0 Heat is supplied by electrical heating or other miscellaneous heat source
- = 1 Heat is supplied by process heating fluid

NSTR(2): Method for performing calculations

- Calculate steam generation rate for a specified process heating fluid flow rate, miscellaneous heat generation rate (or electrical energy dissipation), and liquid feed rate
- Calculate heating fluid requirements or miscellaneous heat generation rate (or electrical energy dissipation) required to vaporize liquid water entering generator as primary flow (A(01)).

NSTR(3): Method for calculating heat exchanger performance

- = 0 Effectiveness is input
- = 1 Overall thermal conductance is input. Effectiveness is calculated assuming η = 1 e^{-NTU}

where

$$NTU = \frac{UA}{(WC_p)}$$

UA = overall thermal conductance, $\frac{Btu}{hr}$ or

2.3 Steady State V-Array Data

Reference Location	Description	Data Type
65	Not used	0
66	Desired degrees of superheat (°F)	I(R) if NSTR(2)=1

Reference Location	Description	Data Type
<u> Location</u>	Description.	Data Type
67	Temperature of saturated steam (°F)	0
68	Energy supplied by electrical or other	I(R) if
	miscellaneous heat source (watts	NSTR(2)=0 and
		NSTR(1)=0
69	Heat exchanger effectiveness	I(R) 1f
		NSTR(1)=1 and
		NSTR(3)=0
70	Overall thermal conductance between steam	I(R) 1f
	(and water) and process heating fluid (Btu/hr °F)	NSTR(1)=1 and
	/	NSTR(3)=1

3.0 Analytical Model Description

a. Required steam generation rate specified

$$Q = W_a \left(h_{g,o} - h_{1,i}\right)$$

where:

Q = required heat (Btu/hr)

h_{1,i} = enthalpy of liquid entering generator (Btu/lb)

h = enthalpy of superheated steam leaving (Btu/lb)

 $W_a = steam generation rate (lb/hr)$

$$\mathbf{h}_{1,i} = \mathrm{HF}(\mathbf{T}_1)$$

$$h_{g,o} = HG(T_2)$$

where:

 $T_1 = temperature of liquid water entering generator (°F)$

 T_2 = saturation temperature plus degrees superheat [R(66)]

HF and HG are built-in functions to determine enthalpy of liquid and vapor respectively.

for generator with electrical or miscellaneous heat source

$$R(68) = Q/3.41$$
 (watts)

for generator with heat supplied by process heating fluid, the flow is estimated as

$$W_b = {}^{Q}/c_{PB} \left(T_3 - T_4\right)$$

where:

W_h = required flowrate of heating fluid (lb/hr)

C_{pR} = specific heat of heating fluid (Btu/lb°F)

T₃ = temperature of heating fluid entering
 generator (°F)

T₄ = temperature of saturated steam (°F)

 b. Miscellaneous heating rate or process heating fluid flow rate specified. If miscellaneous heating (or electrical energy dissipation)

$$Q = R(68)$$

if heat supplied by process heating fluid

$$Q = \eta W_b C_{PB} \left(T_3 - T_1 \right)$$

where:

η = heat exchanger effectiveness

(1) if
$$Q > W_a \left(h_{s,o} - h_{1,i}\right)$$

$$T_{out} = T_{sat} = \frac{Q - W_a \left(h_{s,o} - h_{1,i}\right)}{W_a C_{pA}}$$

where:

Q = specified heating rate (Btu/hr)

W = steam generation rate (lb/hr)

 $h_{s,o}$ = enthalpy of saturated steam (Btu/1b)

h_{1,i} = enthalpy of liquid water entering generator (Btu/lb)

 C_{p_A} = specific heat of steam (Btu/1b°F)

T = temperature of steam leaving (°F)

T = temperature of saturated steam (°F)

(2) if
$$Q < W_a \left(h_{g,o} - h_{1,i} \right)$$

$$h_{t,o} = \frac{Q}{W_a} + h_{1,i}$$

$$T_{out} = T_1 + \frac{Q}{(W_a) (C_{pW})} \quad \text{if } h_{t,o} < h_{1,o}$$

where:

T₁ = temperature of liquid water entering generator (°F)

 C_{PW} = specific heat if liquid water $\left(\frac{Btu}{lb}\right) = 1.0$

 $h_{1,o} = \text{enthalpy of liquid water at}$ saturation temperature $\left(\frac{Btu}{1b}\right)$

ht,o = enthalpy of mixture of vapor and liquid leaving generator(Btu/lb) or

$$T_{out} = T_{sat}$$
 if $h_{t,o} > h_{1,o}$

for this condition

$$W_1 = (1-x)W_a = \text{liquid water leaving (lb/hr)}$$

$$W_v = XW_a = vapor leaving (1b/hr)$$

$$X = \frac{h_{t,o} - h_{1,o}}{h_{g,o} - h_{1,o}} = \text{fraction vapor in stream}$$
leaving generator

4.0 Lower Level Subroutines Required

HG

TSAT

HF

5.0 References

None

SØLEL

Component Subroutine No. 51 - Solid Electrolyte Cells

1.0 Subroutine Description

This subroutine is used to simulate the reduction of ${\rm CO_2}$ to ${\rm O_2}$ in a solid electrolyte cell unit. This method of ${\rm CO_2}$ reduction differs from other potential concepts in that the feed gas need not be dry. ${\rm CO_2}$ and ${\rm H_2O}$ are both electrochemically decomposed.

The physical geometry of a unit is described in general terms. That is, the unit is assumed to be comprised of a number of parallel modules to which the flow and current divide equally. Each module is comprised of a number of cell stacks. The cell stacks are assumed to be connected in parallel electrically. Module flow is assumed to divide equally between the stacks. Stack cells are assumed to be connected in series.

For heat transfer purposes, each module is treated as a single lumped mass. Heat losses to the ambient air and structure may be simulated by specifying appropriate input data.

2.0 Subroutine Data

2.1 General Notes

- A primary source flow must be specified to provide an inlet gas flow. The primary side flow code must be 3. The flow constituents in the source of flow must be compatible with those for the component.
- 2. A flow code of 2 or 3 must be specified for the secondary side of this component. The secondary flowout of this component will be composed of the oxygen gas generated in the cell.
- 3. The gaseous feed for the primary side of the component is assumed to be composed of CO_2 , H_2O , CO, and H_2 . The CO may

enter as recycle flow from the disproportionator reactor (CARDP) used to form CO_2 from CO generated in the solid electrolyte cells. Normally, H_2 generated in the cell will be separated out through a semi-permeable membrane. Small amounts, however, may enter as recycle flow. Oxygen and nitrogen should be present only in negligible amounts. H_2 and CO are assumed to enter as special flows 2 and 3, respectively.

4. The unit is assumed to be comprised of a number of parallel modules. Each module is comprised of a number of cell stacks which are also connected in parallel. Flow is assumed to divide equally between the stacks. Each stack is made up of a number of cells connected electrically in series. Flow divides equally among the cells. Figure 1 illustrates how two different concepts may be modeled.


2.2 Instruction Options

NSTR(1): Specifies method for determining cell voltage

- = 0 Cell voltage is calculated from the theoretical cell voltage and power efficiency specified in R(76).
- Cell voltage is determined by interpolating a table of values of cell voltage versus current density (amps/ft²) and cell temperature (°F)


NSTR(2): Specifies method for determining electrolysis current

- = 0 Total current to unit is a constant value input in R(67). Electrolysis current is calculated from 0_2 current efficiency specified in R(72).
- = 1 Cell electrolysis current is calculated from 0_2 current efficiency and the constant value of $C0_2$ and H_2^0 conversion $\frac{1b_{1n} 1b_{0ut}}{1b_{0ut}}$ specified in R(70) and R(71).



- 1 MODULE
- 20 STACKS
- 7 CELLS/STACK

BAFFLES DIVIDE CYLINDER INTO 4 COMPARTMENTS. TOTAL FLOW FLOWS FROM ONE COMPARTMENT INTO NEXT.








FIGURE 1a DETAILS OF BELL AND SPIGOT CONCEPT





2.3 Heat Loss V-Array Data

Reference		•
Location	Description	Data Type
51	Temperature of a module shell (°F)	0
52	Effective thermal conductance from module shell	0
٠.	to surroundings (Btu/hr°F)	
53	Total heat loss from module to surroundings	0
	(Btu/hr) $R(53)=R(56)+R(59)+R(62)$	
54	Ambient gas temperature (°F)	I(R)
55 .	Thermal conductance between surface of module	I(R)
	insulation and ambient gas (Btu/hr-°F)	· .
56	Convective heat loss to ambient gas (Btu/hr)	0
	from a module	
57	Ambient wall temperature (°F)	I(R)
58	Module thermal radiation FA from surface of	I(R)
* *	insulation to ambient wall (ft ²)	
59	Radiative heat loss from a module to ambient	0
	wall (Btu/hr)	
60	Structure temperature (°F)	I(R)
61	Conductance $\binom{kA}{\Delta x}$ between module shell and structure (Btu/hr	I(R)
62	Conductive heat loss to the structure (Btu/hr)	0
63	Insulation surface temperature (°F)	0
64	Conductance $(\frac{kA}{\Delta x})$ between module shell and outer	I(0)
•	surface of insulation	

2.4 Steady State K-Array Data

Reference Location	<u>Description</u>	Data Type
16	Number of cells/stack	I(R)
17	Number of stacks/module	I(R)
18	Number of modules/unit	I(R)
19	Table number for cell voltage (volts) as a	I(0)
	function of current density (amps/ft ²) and	
	temperature (°F)	

2.5 Steady State V-Array Data

Reference	<u>Description</u>	Data Type
65	Heat dissipated in a module by electrical	I(0)
	heater (Btu/hr)	
66	Heat dissipated in a module due to current and	0
	voltage inefficiency (Btu/hr)	
67	Total current to <u>unit</u> (amps)	I(R) if NSTR(2)=0
68	Total electrolysis current to a module (amps)	0
69	Current density (amps/ft ²)	, o
70	CO ₂ conversion (fraction)	I(R) if NSTR(2)=1
71	H ₂ 0 conversion (fraction)	I(R) if NSTR(2)=1
72	Overall O ₂ current efficiency (fraction)	I(R)
73	CO current efficiency (equals 1.0-R(74)	.0
74	H ₂ current efficiency (fraction)	I(R)
75	Cell voltage (volts)	0
76	Voltage efficiency, E _{thr} /E _{act} , (fraction)	I(R) if NSTR(1)=0
77	Electrode area for cell (ft ²)	I(R) if NSTR(1)=1
78	Previous trial value for PHI (Btu/hr)*	· , O
79	Previous trial value for T _{MOD} (°F)*	0
80	Convergence tolerance for calculating cell	0
	temperature (percent)	

^{*} These quantities are used in the trial and error method used for determining module temperature. The technique is described in section 3.0.

2.6 Transient V-Array Data

Reference

Location	Description	Data Type
R(81)	Total module thermal capacitance (Btu/°F	I(R)
R(82)	Initial temperature at time t (°F)	I(R)

3.0 Analytical Model Description

 \mathbf{co}_2 is reduced in this process by the following electrochemical reactions:

at cathode:

$$2\omega_2 + 4e^- \longrightarrow 2\omega + 20^- \tag{1}$$

at anode:

$$20^{-} \longrightarrow 0_2 + 4e^{-} \tag{2}$$

or a net reaction of

$$2\infty_2 \longrightarrow 2\infty + 0_2 \tag{3}$$

Simultaneously with the above reactions

H₂0 is electrolyzed as follows:

at cathode:

$$2H_2O + 4e^- \longrightarrow 2H_2 + 20^-$$
 (4)

at anode:

$$20^{-} \longrightarrow 0_{2} + 4e^{-} \tag{5}$$

or net reaction of.

$$2H_2O \longrightarrow 2H_2 + O_2 \tag{6}$$

By Faraday's law, the total amount of oxygen generated by reactions (3) and (4) will be

$$W_{0_2} = I_{e/1508 (1b/hr)}$$
 (7)

where:

I = electrolysis current (amps)

The amounts of $^{\rm CO}_2$ and $^{\rm H}_2{}^{\rm O}$ reacted (or CO and $^{\rm H}_2$ formed) are more difficult to predict analytically. A simplified approach is used using experimentally determined values for current efficiencies for CO and $^{\rm H}_2$ formation

$$N_{CO} = \frac{M_{CO} \times 24100}{I_{e}}$$
 (8)

$$N_{H_2} = \frac{M_{H_2} \times 24100}{I_e}$$
 (9)

where:

 $M_{CO} = 1b \text{ moles CO formed (1b moles/hr)}$

 $M_{\rm H_2} = 1b \text{ moles } H_2 \text{ formed (1b moles/hr)}$

I = electrolysis current (amps)

$$N_{CO} + N_{H_2} = 1.0$$

The electrolysis current generally will be less than the total current due to miscellaneous shunt losses in the cells. The $^{0}2$ current efficiency thus is defined as the following:

$$N_{0_2} = \frac{I_e}{I_t} \tag{10}$$

where:

I = total cell current (amps)

The cell module is treated as a single lumped mass for transient heat transfer calculations. A heat balance is performed taking into account losses to the ambient (by conduction, radiation, and convection), electrical energy dissipated as heat, energy supplied by an electrical heater, and the net enthalpy change of products and reactants, and the heat of reaction for equations (3) and (6). Figure 2 illustrates the thermal model used in this subroutine.




FIGURE 2 THERMAL MODEL FOR SOLID ELECTROLYTE CELL MODULE

The net enthalpy added by the influx and efflux of reactants and products, respectively, and the heat absorbed by chemical reaction is included in the heat balance mentioned previously. Since the enthalpy change is independent of the thermodynamic path chosen, the net enthalpy added to the module is as follows:

$$\Delta H_{T} = \Delta H_{R} - \Delta H_{P} - \Delta H_{1,TO} - \Delta H_{2,TO}$$
 (11)

when:

ΔH_{1,TO} = heat of reaction for decomposition of CO₂ at 77°F (Btu/hr)

 $\Delta H_{2,TO}$ = heat of reaction for decomposition of $H_{2}O$ at 77°F (Btu/hr)

 ΔH_R and ΔH_P are the integrated enthalpy changes for the reactants and products, respectively, from the inlet and outlet temperatures to the standard state for the heat of reaction (77°F). The integrated enthalpy change for each species is calculated by the following equation:

$$\Delta H_{i} = N_{i} \int_{T_{o}}^{T} \left(aT^{-2} + bT^{-1} + cT^{\circ} + dT^{1} + eT^{2} \right) dT$$
(12)

where:

 $N_i = flow rate (lb/hr)$

 ΔH_1 = enthalpy change for constituent 1 between temperature T and T_0

a, b, c, d = experimentally determined coefficients

for heat capacity as a function of temperature.

The values of these constants for the reactant and product constituents are given in Table I.

The theoretical decomposition voltage for ${\rm CO_2}$ and ${\rm H_2O}$ are both fairly close. At 850°C they are as follows:

E
H₂0 = 1.102 volts

E
co₂ = 0.956 volts

The actual cell voltage has been found to be approximately 1.8 volts. The subroutine has an option for entering tabular data for cell voltage as a function of current density and cell temperature. Alternatively, the cell may be calculated from the cell efficiency

$$E_{cell} = \frac{1.102}{N_{cell}}$$
 (13)

For heat transfer calculations, the amount of electrical energy dissipated due to current and voltage inefficiency is as follows:

$$Q_e = \begin{bmatrix} E_{cell} & I_t - 1.102 & I_e \\ Btu/hr \end{bmatrix} \times 3.41$$
 (14)

The heat balance for the module temperature is given below:

$$\frac{T_{MOD} - T_{MOD}}{\Delta \tau} G = -Q_{AM} + Q_e + Q_H + \Delta H_T$$
 (15)

where:

Q_{AM} = net heat loss to the surroundings by conduction, convection, and ratiation (Btu/hr)

Q_e = electrical energy dissipated in the cells due to inefficiency and Joule heating

 Q_{H} = energy dissipated by electrical heater (Btu/hr)

ΔH_T = net enthalpy added to module by reactants and products and heat of reaction (Btu/hr)

G = module lumped thermal capacitance (Btu/°F)

Table I - CONSTANTS FOR HEAT CAPACITY EQUATIONS

S	$C_{\rm p} = a/{\rm T}^2 + b/{\rm T} + c + d{\rm T}^1 + e{\rm T}^2$	$c + dr^1 + er^2$	g mole oK	×	
					·
:	હા	ام	υļ	υl	υį
⁰ 2(g)	-187700.	.	8.27	.000258	•
H ₂ 0(g)	0.	ċ	8.22	.00015	.00000134
89 2	-195500.	.0	10.34	.00274	•
C (graphile)	0	•	2.673	.002617	-116900.
H ₂	0	•	6.62	.00081	· o
8	•0	0.	09.9	.00120	.0

Equation (15) is rewritten in the following form for solution by a trial and error procedure.

$$PHI = -\frac{T_{MOD}' - T_{MOD}}{\Delta \tau} G - Q_{AM} + Q_{e} + Q_{H} + \Delta H_{T}$$
(16)

For a trial value of $T_{\mbox{MOD}}$, $Q_{\mbox{AM}}$ is calculated using subroutine QSURR. Equation (16) is then solved for PHI. Subroutine ESTIM is then used to determine the value of $T_{\mbox{MOD}}$ for which PHI equals 0. Convergence is satisfied when:

$$\frac{\text{PHI}}{\Delta H_{R} + Q_{e} + Q_{H}} < \frac{R(80)}{100}$$

4.0 Lower Level Subroutines and Functions

QSURR

ESTIM

5.0 References

- 1. Weissbart, J., Smart, Wydeven, "Design and Performance of a Solid Electrolyte Oxygen Generator Test Module," ASME Paper 71-Av-8.
- 2. Weissbart, et al, "Development of ${\rm CO_2-H_2O}$ Solid Oxide Electrolyte Electrolysis System"--2nd Annual Report May 1970. NAS2-4848.
- 3. Elikan, L., Morris, Saunders, "180-Day Life Test of Solid Electrolyte System for Oxygen Regeneration," ASME Paper 71-Av-32.
- 4. Elikan, L., Morris, Wu, "Development of a Solid Electrolyte System for Oxygen Reclamation," NAS1-8896.
- 5. J. Weissbart and W. H. Smart, "Study of Electrolytic Dissociation of CO₂-H₂O Using a Solid Oxide Electrolyte," Feb 1967, NASA CR-68O.

VACPMP

Component Subroutine No. 28 - Vacuum Pump

1.0 Subroutine Description

The performance of a vacuum pump may be simulated with this component. Depending on the options selected by the program user, table data may be interpolated for electrical input power and flow as a function of inlet and outlet pressure. Alternately, the work for compression may be predicted from the equation for an isentropic compression. The flow may be calculated from the equation for a single stage reciprocating compressor. The shaft and electrical input power are then calculated from the isentropic work using specified values for aerodynamic and motor efficiency.

Since the performance of this component is highly sensitive to variations in upstream and downstream pressures, a small subloop should be made for the affected components. For example, for a sorption bed being desorbed by heat and vacuum with the desorbed gas being pumped to an accumulator, a subloop should be set up with these components. The computing interval required for these components generally will be smaller than that required for the complete EC/LS system. Thus, GPØLY logic should be prepared to set up to allow iteration of the three components until the number of iterations times the loop computing interval equals the system computing interval.

2.0 Subroutine Data

2.1 General Notes

- A primary flow source must be specified to provide an inlet gas flow.
- 2. The primary side flow code must be 1, 2, or 3.
- The flow constituents for the source of flow must be compatible with those of the component.
- 4. The discharge pressure for the compressor must be input into R(75). The value for this parameter should be calculated by

appropriate GPØLY logic. Numerically, it should equal the pressure of the accumulator into which the gas is being pumped plus the line and other miscellaneous losses between the pump and accumulator.

2.2 Instruction Options

NSTR(1): Specifies method for determining flow

- = 0 Set flow equal to inlet flow A(01)
- = 1 Interpolate for flow as a function of Po/Pi, and Ti where:

P, = inlet pressure (psia)

P_o = outlet pressure (psia)

T, = inlet temperature (°F)

- = 2 Calculate flow from built-in equations for reciprocating polytropic compression
- NSTR(2): Specifies method for determining electrical input power
 - = 0 Constant value entered in R(69)
 - = 1 Determine input power from equation for isentropic compression
 - = 2 Interpolate for flow as a function of Po/P, Ti
- NSTR(3): Option for overriding calculations for flow during steady state
 - = 1 Set flow equal to inlet flow A(01)
 - = 2 Set flow equal to outlet flow R(01)

2.3 Heat Loss V-Array Data

Reference Location		Description	Data Type
51	Heat lost to ambient	(Btu/hr)	0

2.4 Steady State K-Array Data


Reference Location	Description	Data Type
16	Table number for compressor flow (cfm) (based on inlet density) as a function of P _O /P _i , T _i	I(R) 1f NSTR(1)=0
17	Table number for compressor input power (watts) as a function of P_0/P_1 , T_1	I(R) if NSTR(2)=2

2.5 Steady State V-Array Data

Reference Location	Description	Data Type
65	Total heat added to gas stream (Btu/hr)	0
66	Motor efficiency (dimensionless)	I (R)
67	Aerodynamic efficiency (dimensionless)	I(R)
68	Power required for compression (watts)	0
69	Total electrical input power (watts)	I(R) if NSTR(2)=0
70	Heat dissipated due to motor inefficiency (watts)	0
71	Fraction of heat dissipation, R(70), which is lost to ambient.	I(R)
	0	
	1	
72	Compressor piston displacement (ft ³ /min)	I(R) 1f NSTR(1)=1
73	Clearance factor (dimensionless)	I(R) if NSTR(1)=1
74	Polytropic exponent (equals $\mathcal{V} = \frac{C}{C_v}$ for ideal gas)	Ï(R)
75	Discharge pressure (psia)	I(R)

3.0 Analytical Model Description

The vacuum pump flow and electrical input power may be determined by interpolation of bi-variant table data describing the pump performance. For example



where

$$\dot{\mathbf{m}} = \mathbf{Q}/\mathbf{v}$$

Alternatively, the flow can be calculated from the equation given below for a single stage reciprocating compression

$$m = \left[1 + C - C\left(\frac{P_o}{P_i}\right) \quad \frac{1/n}{v_i}\right] \quad \frac{P.D}{v_i}$$

where

m = flow rate (lb/min)

C = clearance factor = Clear Volume
Displacement

P.D = piston displacement (ft³/min)

 v_1 = specific volume of gas entering (ft 3 /1b)

P = outlet pressure (lb/ft²)

 $P_i = inlet pressure (1b/ft^2)$

n = polytropic exponent

The isentropic work for this compression is given by

$$W_{isen} = \frac{n}{n-1} P_i v_i \left[\left(\frac{P_o}{P_i} \right)^{\frac{n-1}{n}} - 1 \right] \frac{ft-1b}{1b_m}$$

The shaft work required is calculated as follows:

where:

N_{aero} = aerodynamic efficiency

The electrical input power is calculated as follows:

where

N_m ≅ motor efficiency

The total heat dissipated due to inefficiency in the motor is thus

$$Q = W_{IP} (1 - N_m)$$

The fraction of this heat which is dissipated to the surrounding (the remainder being dissipated into the gas being pumped) is specified as input data.

The total heat being dissipated into the gas being pumped is thus

$$Q_t = \left[W_s + \left(1 - F\right)W_{IP}\left(1 - N_m\right)\right]3.41$$

when

F = fraction of heat dissipated to surroundings

The temperature rise for the gas due to compression plus inefficiency is thus

$$T_{out} = T_{in} + \frac{Q_t}{WC_p}$$

- 4.0 Lower Level Subroutines and Functions
 None.
- None.

APPENDIX B

NEW UTILITY OR SPECIAL PURPOSE SUBROUTINES

CØABS

1.0 Purpose

This subroutine computes transient performance of sorbing or purge desorbing packed resin beds.

2.0 Use

This routine is used by component subroutine CØSØRP to simulate absorption or adsorption processes.

3.0 Calling Sequence
Call CØABS

4.0 Output

The computed output for this routine is stored in the R array for CØSØRP. These output are discussed in section 2.8 of CØSØRP.

5.0 Method

The equations and assumptions used in preparing this routine are discussed in section 3.2.1 of CØSØRP.

CO2CP

1.0 Purpose

Subroutine CO2CP computes the effective c_p , denoted as \bar{c}_p , for primary and/or secondary flow to account for the precipitation of ${\rm CO}_2$ in the heat exchanger. The subroutine computes the amount of ${\rm CO}_2$ removed due to the precipitation process which can occur in the gas stream. The effective value of C_p accounts for the effects of precipitation and yields better results in temperature in heat exchanger performance calculations.

2.0 Use

- 2.1 The subroutine is called by ANYHX during steady state solutions when precipitation of CO₂ can occur; that is, NSTR(9) is set to 1.
- 2.2 The subroutine is called twice by ANYHX (NSTR(9) = 1) during transient conditions when a steady state solution is required. The first call is used in obtaining \bar{c}_p based on inlet and outlet temperatures at the start of the time step. The second call is used to obtain updated values for \bar{c}_p following the calculation of new outlet temperatures, for the end of the time step, in ANYHXT.

3.0 Calling Sequence

CALL CO2CP

4.0 Output

Data computed in this subroutine are stored in the R-array for ANYHX. These data are discussed below:

- R(12) and/or R(31), CO₂ outflow, 1b/hr
- R(72) and/or R(73), Effective specific heats
- R(68) and/or R(69), Precipitation rate

The effective specific heats are named XCP(1) and XCP(2) for primary and secondary streams in the heat exchanger common block/CANYXH/.

5.0 Method

When ANYHX calls CO₂CP precipitation of CO₂ is anticipated in the heat exchanger. The subroutine initially sets up functions which compute enthalpies and specific heats for solid and vapor and implemented into the program as follows:

$$c_{p_g}(T) = \frac{8.71 + .0066 T - 22 \times 10^{-7} T^2}{44.0}$$
 (Reference 1)

$$c_{p_g}(T) = .397 + .00115 T$$
 (Reference 2) (2)

$$h_g(T) = 136. + T(e_p(T) + 69.2 e_p(T_g)$$
 (3)

$$h_s(T) = T c_{p_s}(T) + 40.0 c_{p_s}(-40) - 88.7$$
 (4)

where.

 c_{p_s} (T) = Specific heat of solid CO_2 at temperature T, Btu/lb- $^{\circ}F$

 c_{p_g} (T) = Specific heat of CO_2 vapor at temperature T, Btu/lb- $^{\circ}F$

 h_g (T) = Enthalpy of CO₂ vapor at temperature T, Btu.

 h_{s} (T) = Enthalpy of CO₂ solid at temperature T, Btu

T = Outlet temperature of cabin air, °C

 T_s = Temperature at which CO_2 changes phase, -56.2°C = -69.2°F

The saturation pressure and max allowable CO₂ flowrate is determined from the following relationship:

$$Log_{10}$$
 (PCO2) = $\frac{-1275.6}{TK}$ + .00683 TK + 8.307 (TK > 150.) (5)

$$Log_{10}$$
 (PCO2) = $\frac{-1352.6}{TK}$ + 9.83 (TK < 150.) (Reference 4)

where,

PCO2 = CO₂ saturation pressure at temperature TK, mmHg

TK = Heat exchanger outlet temperature, °K.

From saturation pressure of CO_2 , maximum CO_2 flowrate is computed. If the inlet CO_2 flow is greater than maximum CO_2 flow allowable we assure the difference to percipitate out, thus modifying our effective specific heat value. The effective specific heat is then computed from the following relationship:

$$\bar{c}_{p} = \frac{(\hat{w}_{nc} * c_{p_{nc}} * T_{i} + w_{CO_{2}} * h_{g} (T_{i})) - (\hat{w}_{nc} * c_{p_{nc}} T_{o})}{(\hat{w}_{nc} * c_{p_{nc}} * T_{o})}$$

$$\frac{+ w_{CO_2} + h_g (T_o) + w_{c,s} + h_s (T_o)}{\dot{w}_{nc} + (T_1 - T_o)}$$

where:

w = Non-condensable flowrate, lbs/hr

C = Specific heat of non-condensables, Btu/lb-oF

T_i = Air inlet temperature, oF

 T_{o} = Air outlet temperature, oF

 $\dot{\mathbf{w}}_{\text{CO}_2} = \text{CO}_2 \text{ flowrate, lb/hr}$

 h_{α} = Gaseous CO_2 enthalpy, Btu/lb

 h_{g} = Solid CO₂ enthalpy, Btu/lb

c = Effective specific heat, Btu/lb-oF

 $\dot{\hat{\mathbf{w}}}_{\mathbf{c}_{s}} = \mathbf{co}_{2}$ freezing rate, lb/hr

6.0 References

- 1. International Critical Tables Vol. V, p. 83. McGraw-Hill Book Co., New York, New York 1929
- 2. International Critical Tables Vol V, p. 95. McGraw Hill Book Co., New York, New York 1929.
- 3. ASRAE Guide and Data Book Fundamentals and Equipment, p. 342. American Society of Heating Refrigerating and Air Conditioning Engineers, Inc., New York, New York, 1965/1966.
- 4. International Critical Tables, Vol. III, p. 207. McGraw Hill Book Co., New York, New York, 1929.

SDESRP

1. 0 Purpose

This subroutine computes transient performance of steam desorbed packed resin beds.

2.0 Use

This routine is used by component subroutine $C\Phi S\Phi RP$ to simulate steam desorption processes.

3.0 Calling Sequence

Call SDESRP

4.0 Output

The computed output for this routine is stored in the R array for CØSØRP. The output are discussed in section 2.8 of CØSØRP.

5.0 Method

The equations and assumptions used in preparing this routine are discussed in section 3.2.2 of CØSØRP.

SSSØR

1.0 Purpose

This subroutine computes the steady state performance of sorption beds.

2.0 Use

The routine is used by component subroutine CØSØRP to calculate the steady state absorption/adsorption, purge desorption, thermal vacuum and steam desorption of packed resin beds.

3.0 Calling Sequence

Call SSSØR

4.0 Output

The computed output of the routine is stored in the R-array for CØSØRP. These output are discussed in section 2.5 of CØSØRP.

5.0 Method

The methods used for this routine are discussed in sections 3.1.1 3.1.2 and 3.1.3 of CØSØRP.

PØLFT

1.0 Purpose

The purpose of this routine is to perform parabolic interpolation of three pairs of values of independent and dependent variables.

2.0 Use

This routine is used by subroutines CØABS, SDESRP, VACDSP, and SSSØR (lower level subroutines for CØSØRP) to interpolate for the absorption bed CO₂ equilibrium partial pressure at a specified value of CO₂ bed loading and three values of water bed loading. However, the routine is general in nature and can be used to interpolate between any three pairs of values of independent and dependent variables.

3.0 Calling Sequence


Z = POLFT(Y, X, XVALUE)

Function Value or Argument		Туре	1/0	Description
POLFT ()	R	0	interpolated value of dependent variable
Y		R	I	array of 3 values of dependent variables
X		R	I	array of 3 values of independent variables
X VALUE		R	I	value of independent variable

example: Z = POLFT (PP(1), VAR(1), RX(J+06))

4.0 Output

Returns a value for PØLFT () as described above.



$$y = a + bX + cX^2$$

where:

$$a = y_1 - x_1 b - x_1^2 c$$

$$b = \frac{(y_1 - y_2) - (x_1^2 - x_2^2) c}{(x_1 - x_2)}$$

$$c = \frac{(y_1 - y_2) - \frac{x_1 - x_2}{x_2 - x_3} (y_2 - y_3)}{(x_2^2 - x_3^2)}$$

VACDSP

1.0 Purpose

This subroutine computes transient performance of sorption beds which are desorbed by the combined effects of heat and vacuum.

2.0 Use

This routine is used by component subroutine CØSØRP to simulate thermal/vacuum desorption.

3.0 Calling Sequence

Call VACDSP

4.0 Output

The computed output for this routine is stored in the R array for CØSØRP. These outputs are discussed in Section 2.8 of CØSØRP.

5.0 Method

The equations and assumptions used in preparing this routine are discussed in Section 3.2.3 of CØSØRP.

6.0 Lower Level Subroutines

1.0 Purpose

This routine is used to calculate the equilibrium partial pressure of ${\rm CO_2}$ over IR-45 solid amine resin for specified values of ${\rm CO_2}$ and ${\rm H_2O}$ bed loading and bed temperature.

2.0 <u>Use</u>

This function is used by subroutines CØABS, SDESRP, VACDSP, and SSSØR (lower leve subroutines for component subroutine COSØRP). The partial pressure of CO_2 is used to determine the mass transfer rate of CO_2 from the carrier gas to the bed.

3.0 Calling Sequence

Z = VLCØ2(S,W,T)

Function Value or Argument	Туре	1/0	Description
VLCØ2 ()	R	0	Equilibrium partial pressure (lb/in ²)
S	R	I	Bed CO ₂ loading 1b CO ₂
W	R	·	Bed H ₂ O loading lb _{H₂O}
Ψ	R	т.	lb dry resin Temperature (°F) of bed.

example:

Z = VLC02 (RX(J+02), RX (J+04), RX(J+06))

4.0 Output

Returns a value of VLCØ2 () as described above.

5.0 Method

The equilibrium partial pressure of CO_2 is calculated by equations (1), (2), and (3). The assumptions and methods used in the development of equation (1) were presented in reference 1. The equation is based on data reported in references (2) and (3). Equation (2) was determined from a least squares fit if data reported in reference 4. equation (3) is based on a technique reported in reference (5).

$$P_{CO_{2,77}} = \frac{0.587}{\ln (.24 + 16.7W) - \ln (100S)} \frac{14.7}{760.}$$
 (1)

$$P_{CO_{2},T}^{Sat} = e^{X}$$
 (2)

Where:

$$X = 14.205635 - 4274.967 \frac{1}{T} + 172599.27 \frac{1}{T} 2$$

$$P_{CO_{2,T}}^{*} = P_{CO_{2,T}}^{*} \begin{bmatrix} P_{CO_{2,77}}^{*} \\ P_{CO_{2,77}}^{*} \end{bmatrix}$$
 539/T (3)

where:

W, S, T = previously defined

6.0 References

- 1. 2nd Monthly Progress Report, Attachment 1, page 11 thru 13, Contract No. NAS9-12076, Advanced ETC/LSS Computerized Analytical Models, September 16, 1971.
- 2. MSA Research Corporation: Development of System Design Information For Carbon Dioxide Using an Amine Type Sorber NASA CR-111849, June 1971, page 37.
- 3. Ibid, page 12.
- 4. Perry, R. H., Chemical Engineer's Handbook, McGraw Hill, 4th Edition, 1962, page 3-159.
- 5. Treybal, R. E.; Mass Transfer Operations, McGraw Hill (1955), page 453-457.

VLH2Ø

1.0 Purpose

This routine is used to calculate the equilibrium partial pressures of water vapor over IR-45 solid amine resin. This pressure is assumed to be independent of CO_2 loading in the bed.

2.0 <u>Use</u>

This function is used by subroutine COABS, SDESRP, VACDSP, and SSSØR (lower level subroutines for COSORP) to determine the equilibrium partial pressure for specified values of water loading and temperature. This pressure is then used to determine the mass transfer rate of water vapor from the bed to the carrier gas flowing through the bed.

3.0 Calling Sequence

 $Z = VLH2\emptyset (W,T)$

Function Value or Argument		Type I/O		Description		
VLH2Ø	()	R	0	Equilibrium partial pressure $(\frac{lb}{in^2})$	
W			R	I	Water bed loading (\frac{1b \text{ H}_2 0}{1b \text{ dry resin}})	
T			R	I	Temperature (F)	

Example:

$$Z = VLH2\emptyset (RX(J+04), RX(J+06))$$

4.0 Output

Returns a value for VLH2Ø () as described above.

5.0 Method

The equilibrium partial pressure of water vapor is calculated by equation (1) and (2) presented below. Equation (1) is based on a least square fit of data presented in Reference 1 for data at 77°F. The data is extended to other temperatures (T) by use of techniques described in Reference 2.

$$P_{H_2}^*$$
0,77 = .0996972 + .246341w + 68.7792w² (1)
-700.607w³ + 262548w⁴ - 3409.82w⁵

and
$$P^{*}_{H_{2}0,T} = P^{Sat}_{H_{2}0,T}$$

$$P_{H_{2}0,77}$$

$$Sat$$

$$P_{H_{2}0,77}$$

$$P_{H_{2}0,77}$$
(2)

where:

$$T = Bed temperature$$
 (°R)

6.0 References

- 1. Tepper, F.; Vancheri, F.; Samuel, W. and Vdavcak: Development of a Regenerable Carbon Dioxide Removal System NASA CR-66571 (MSA Research Corporation) Jan 1968, p41.
- 2. Treybal, R. E.; Mass Transfer Operations, McGraw-Hill (1955) p. 453-457.

APPENDIX C

MODIFIED SUBROUTINES

Reference Location	Description	Data Type
55	Thermal conductance between surface of insulation and ambient gas (Btu/hr-oF)	I(R)
56	Convective heat loss to ambient gas (Btu/hr)	0
57	Ambient radiation wall temperature (°F)	I(R)
58	Thermal radiation \mathcal{F} A factor from surface of insulation to ambient wall (ft ²)	I(R)
59	Radiative heat loss to ambient wall (Btu/hr)	0
60	Structure temperature for heat shorts (°F)	I(R)
61	Thermal conductance between module and structure temperature (Btu/hr-°F)	I(R)
62	Conductive heat loss to structure (Btu/hr)	0
63	Insulation surface temperature (°F)	0
64	Conductance between module and outer surface of insulation (Btu/hr- $^{\circ}$ F) (If R(64)=0, there is no insulation)	I(R)

2.4 Steady State K-Array Data

Reference Location	Description	Data Type
16	Component number of alternate component	I(R)
17	Table number for bi-variant curve for cell voltage	1(0)
	= -N use constant value for cell voltage in R(75)	
:	<pre>= N table number lst independent variable = current density (amps/ft 2nd independent variable = temperature (°F)</pre>	; ²)
18	Table number for bi-variant curve for CO ₂ transfer rate (lb/hr-amp-cell)	1(0)
	<pre>= -N use constant value in R(66) = N table number lst independent variable = current density (amps/ft</pre>	· ²)

2.5 Steady State/Transient V-Array Data

Reference Location	Description	Data Type
65	Removal rate of CO ₂ (1b/hr)	0 .
66	Transfer rate of CO ₂ (lb/hr-amp-cell)	I(R)
67	Desired module temperature (°F)	I(R)
68	Heater turnoff temperature (°F)	I(R)
69	Heater turnon temperature (°F)	I(R)
70	Actual temperature of module (°F)	I(R),0

Reference		
Location	Description	Data Type
71	Design of current density (amp/ft ²)	I(R)
72	Area of a cell (ft ²)	I(R)
73	Number of cells in module	I(R)
74	Total current (amps)	0
7 5	Voltage per cell (volts)	I(R)
76	Electrical power (watts)	0
77	Relative humidity in exit cathode gases (%)	I(R)
78	Relative humidity in exit anode gases (%)	I(R)
79	Water loss from electrolyte, all cells (lb/hr)	0
80	External water makeup rate to matrix, all cells equally divided (lb/hr) [Applies if NSTR(1) = 1. Can be a fixed input or GPØLY calculated.]	I(R)
81	Weight of water per cell in matrix (lb)	I(R), 0
82	Weight of C CO per cell in matrix (1b)	I(R),0
83	Desired solids concentration in matrix (%)	I(R)
84	Actual solids concentration in matrix (%)	I(R), 0
85	Vapor pressure of water over electrolyte (psia)	0
86	Total pressure of stage (psia)	I(R)
87	Thermal capacitance of stage (Btu/°F) (not required for steady state)	I(R)
88	Coolant flow to stage (lb/hr)	0
89	Coolant c to stage (Btu/lb-°F)	0
90	Coolant inlet temperature (°F)	0
91	Coolant outlet temperature (°F)	0
92	Heat transfer conductance from coolant to cell (Btu/hr-°F)-cell)	I(R)
93	Heat transfer to coolant (Btu/hr)	0
94	Additional heat source or sink to module (Btu/hr)	I(R)

3.0 Analytical Model Description

Mass Transfer Equations

CO₂: The transport of CO₂ from the cathode to the anode compartment is according to the equation.

$$\hat{W}_{CO_2} = r_{CO_2} * A_{cell} * j * N$$
 (1)

Reference Location	<u>Description</u>	Data Type
54	Ambient gas temperature (°R)	I(R)
55	Thermal conductance between surface of insulation and ambient gas (Btu/hr-°F)	I(R)
56	Convective heat loss to ambient gas (Btu/hr)	0
57	Ambient radiation wall temperature (°F)	I(R)
58	Thermal radiation \mathcal{F} A factor from surface of insulation to ambient wall (ft ²)	I(R)
59	Radiative heat loss to ambient wall (Btu/hr)	0
60	Structure temperature for heat shorts (°F)	I(R)
61	Thermal conductance between module and structure temperature (Btu/hr-°F)	I(R)
62	Conductive heat loss to structure (Btu/hr)	0
63	Insulation Surface Temperature (°F)	0
64	Conductance bwtween module and outer surface of insulation (Btu/hr- $^{\circ}$ F) (If R(64) = 0, there is no insulation)	I(R)

2.4 Steady State K-Array Data

Reference Location	: -	Description	Data Type
16		Component number of alternate component	I(R)
17.		Table number for bi-variant curve for cell voltage	1(0)
	=	-N use constant value for cell voltage in R(75)	
	=	N table number	
		lst independent variable = current density (amps/ft ²)	
		2nd independent variable = temperature (°F)	

2.5 Steady State/Transient V-Array Data

Reference Location	Description	Data Type
65	Removal efficiency of oxygen, $0 \le \eta \le 1$	I(R)
66	Not used	


Reference Location	Description	Data Type
67	Desired module temperature (°F)	I(Ŗ)
68	Heater turnoff temperature (°F)	I(R)
69	Heater turnon temperature (°F)	I(R)
70	Actual temperature of module (°F)	I(R),0
71:	Design current density (amp/ft ²)	I(R)
72	Area of a cell (ft ²)	I(R)
73	Number of cells in module	I(R)
74	Total current (amps)	0
75	Voltage per cell (volts)	I(R)
76	Electrical power (watts)	0
77	Relative humidity in exit cathode gases (%)	I(R)
78	Relative humidity in exit anode gases (%)	I(R)
79	Water loss from electrolyte, all cells (lb/hr)	0
80	External water makeup rate to matrix, all cells equally divided (lb/hr) [Applies if NSTR(l) = 1; can be a fixed input or GPØLY calculated.]	I(R)
81	Weight of water per cell in matrix (lb)	I(R), 0
82	Weight of H ₃ PO _l , per cell in matrix (lb)	I(R), 0
83	Desired H ₂ PO _h concentration in matrix (%)	I(R)
84	Actual H ₂ PO ₁ concentration in matrix (%)	I(R), 0
85	Vapor pressure of water over electrolyte (psia)	0
86	Total pressure of stage (psia)	I(R)
87	Thermal capacitance of stage (Btu/°F) (not required for steady state)	I(R)
88	Coolant flow to stage (lb/hr)	0 45 5
89 .	Coolant c _p to stage (Btu/lb-°F)	0
90	Coolant inlet temperature (°F)	0
91	Coolant outlet temperature (°F)	0
92	Heat transfer conductance from coolant to cell (Btu/hr-°F-cell)	I(R)
93	Heat transfer to coolant (Btu/hr)	0
94	Additional heat source or sink to module (Btu/hr) [Can be an external heater for thermal control]	I(R)

HUMIDT

Component Subroutine No. 26 - Humidifier/Dehumidifier

1.0 Subroutine Description

This subroutine simulates a water vapor mass exchanger in terms of an over-all effectiveness factor similar to heat exchanger calculations. A schematic of the component is shown below.



Flow Codes 1, 2, or 3

FIGURE 1. HUMIDIFIER/DEHUMIDIFIER COMPONENT SCHEMATIC

2.0 Subroutine Data

2.1 General Notes

The flow streams may employ flow codes 1, 2, or 3.

2.2 Steady State V-Array Data

Reference Location	<u>Description</u>	Data Type
. 65	Effectiveness factor for mass transfer $\hat{0} < \eta < 1$	I(R)
66	Water transferred in exchanger (1b/hr)	0
67	Total pressure within exchanger (psia)	r(o)
68	Effectiveness factor for heat transfer $0 \le \epsilon \le 1$	I(R)

3.0 Analytical Model Description

3.1 Vapor Transfer

The program computes the outlet partial pressure of stream j according to

$$p_{j,out} = p_{j,in} + n (p_{i,in} - p_{j,in})$$
 (1)

where stream j is that stream which experiences the largest change in partial pressure of water. The + or - sign is chosen to give the correct direction of mass transfer, p_j is the partial pressure of water vapor in stream j, p_i is the partial pressure of water vapor in stream i, and n is the exchanger effectiveness. The subscripts in and out refer to conditions at the inlet and outlet of a stream, respectively.

Once the outlet partial pressure of the more "sensitive" stream is known, the water vapor transfer is easily calculated from the ideal gas laws.

The above definition of effectiveness parallels the definition used by Eckert and Drake "Heat and Mass Transfer" page 481 for heat transfer.

3.2 Thermal Transfer

The program computes the outlet temperature of the gas streams, primary and secondary, using the heat transfer effectiveness factor, ε , as follows:

$$T_{A,O} = T_{A,i} + \varepsilon \frac{C_{min}}{C_A}$$
 $T_{B,i} - T_{A,i}$ (2)

$$T_{B,O} = T_{B,i} - \varepsilon \frac{C_{min}}{C_{B}} T_{B,i} - T_{A,i}$$
(3)

where

TA.i. TA.0 - Inlet and Outlet temperature primary side.

 $T_{B,i}$, $T_{B,0}$ - Inlet and Outlet temperature secondary side.

 $^{\rm C}$ A, $^{\rm C}$ B - The hourly heat capacitance of primary and secondary side. $^{\rm C}$ C min - The smaller of $^{\rm C}$ A and $^{\rm C}$ B magnitudes.

ε - Heat transfer effectiveness factor, input value

The program does not compute external heat losses from the unit.

The above equations for temperature computations using the heat transfer effectiveness factor were obtained from Kreith "Principles of Heat Transfer" page 453.

APPENDIX D

LISTING OF INPUT DATA FOR SAMPLE PROBLEMS

```
*INSERT.GPOLY1.24
          IF ( STEADY) RETURN
       IF ( NPASS NE 20) RETURN
       IF( N.NE.4) RETURN
       SIMULATE SWITCHING FROM ABSORBING TO DESORBING MODE
                SWITCH COLUTION PATHS
       Ma1600000
       CALL SK(M,5,8)
       M=70000
       CALL SK(M, 16,8)
       M# 600000
       CALL SK(M, 15', 8)
       Ma1100000
       CALL SK(M,6,8)
               -- SWITCH PLOW SOURCES
       M#1602
       CALL SK(M,7,2)
       MR602
       CALL SK(M, 11, 2)
       MB1502
       CALL SK(M, 6, 2)
       M#502
       CALL SK(M.16,2)
               SWITCH MODES
       CALL SK(M.6.22)
       Man
       CALL SK(M,16,22)
                SWITCH PROFILES
       Mag.
       CALL SK(M, 6, 23)
       Ma1
       CALL SK(M.16,23)
 BASIC
                                        16 YEA NAY
                               13
 CASE
            STEAM DESORBED RESIN CONCEPT
  SCASE1
       KCHOUTED, KPRNTEOO6, KPTINV(1) 8001, KRUNE1,
       THIN==460., TMAX=2000., WTMAX=10000., MAXSLP=20.
       DTIME#060. START#0. TIMEMX#2400. MAXSSI# 2.
       MINSSIE1 S
  LACKES
       CPC02=.197, CPDIL=.22, VISGAS=.045, WTMTC=16.,
       XKGAS=.0147.WTMDTL#28.,WTMCON#18., CPCONV#.44.
       CPCONL =1., CP(1) #1.0, RHO(1) #62, 4, VISC(1) =2,37,
       WTM(1)=18,,XK(1)=0.347
       CP(2) 8.451, RHO(2) 8.0372, VISC(2) 83.13E-2.
       HTM(2)=18., XK(2)=,0145.CP0XY8.22 $
 ID:
              FLOW MIX
 KBAS
                                                                         10
                                                  -20
- 1-D • •
              SUBSYSTEM BLOWER
 NSTR
             0030
 KBAS
              23
                                                                          5
 VARY
                             HEAT ADDED TO GAS STREAM(WATTS)
 1D ..
              BY PASS VALVE
 NSTR
        5
             0 .
2-KBAS---5-
                   المراجع المراجع المسترك المنافع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع
             ----1-0-----
                                                                          5
 VARY
       05
           65 .0001
                             FRACTION OF FLOWRYPASSING CONCENTRATOR
 1D** _
              ABSORBING SOLID AMINES BED
```

```
NSTR
              2010023
                            15
                               0.0
 KBAS
        6.
               36108
                              5 2
 KARY
                               BED ABBORDING (DURING STEADY STATE)
 ARY
        6
           17
                               USE BUILTAIN RELATIONSHIP FOR H20 ISOTHERMS
 KARY
                               INTERPOLATE TABLE FOR CO2 EQUIL PART PRESS.
           18
                        •
 KARY
        6
           21
                       12
                               NUMBER OF BED ELEMENTS
 KARY
           22
                               BED ABSORBING (DURING TRANSIENT)
 VARY
           65 .018
VARY
           44
               122
           68 28,8
 VARY
                               BULK DENSITY (LB/HR)
           69 .00115
 VARY
                               PELLET DIAMETER(FT)
VARY
           70 40 ....
                               -VOID FRACTION-
 VARY
           71
                               SUPERFICIAL SURFACE AREA(SQ FT/OU FT)
        6
              3130
           72 1.
 VARY
                               SPHERICITY
VARY
           73
                               CHANNELING FACTOR
           75 1.57
 VARY
                               BED PRONTAL AREA(SO FT)
 VARY
           76
               458
                               BED LENGTH(FT)
           77 3,23
VARY
 VARY
           78 3.63
 VARY
           79
              250.
                               HEAT OF SORPTION=CO2=(BTU/LB)
               .536
VARY
           80
                               BINARY DIFFUSION COEF. - CO2/AIR - (SQ FT/HR)
 VARY
       06
           ,81
              14.
                      E-4
                               OVERALL MASS TRANS. COEF. FOR CO2(DESORPTION)
                               OVERALL MASS TRANS. COEF. FOR CO2(ABSORPTION)
           82 6.8
 VARY
                     E-DA
           83 1400,
VARY
                               HEAT OF SORPTION-HEO-(BTU/LB)
                               BINARY DIFFUSION COEF. -H20/AIR-(SQ FT/HR)
 VARY
           84
               .854
                               OVERALL MASS TRANS, COEF, FOR M20(DESORPTION)
 VARY
       06
           85 22.
                      End
 VARY
           86
                               OVERALL MASS TRANS, COEF, FOR M20(ABSORPTION)
              4.8
                      Eos
           98
 VARY
              75.
               , 26
 VARY
        6 100
                               DRY RESIN HEAT CAPACITY (BUT/LB=F)
 ARY.
       6-103
              ...5...
                              <u>-MULTIPLYING FACTOR FOR COMPUTING INTERVAL</u>
               0,
 VARY
        6 104
                               INITIAL VALUE GAS OUTLET TEMPERATURE(F)
 VARY
        6 108
               200.
               200.
 VARY
          109
                               INITIAL VALUE BED TEMPERATURE(F)
 VARY
        6 112 760.
                               INITIAL VALUE AIR PARTIAL PRESSURE (MMHG)
 VARY
       06 107
               26847
                               INITIAL HZO LOADING
                                                                  (LB/LB)
VARY
       06 116 .26912
 VARY
       06 125
               .26975
       06 134
               ,27036
 VARY
VARY
       .06.
          143 27079
 VARY
       06 152
              27116
              27154
 VARY
       06 161
VARY
       06 170 .27194
               ,27239
 VARY
       06 179
 VARY
       06 188
               127291
          107 ,27356
VARY
       06
 VARY
       06 206
              .2741
 VARY
        6 105
               .02383
                               INITIAL CO2 BED LOADING
                                                                  (LB/LB)
VARY
          114 .02228
 VARY
        6 123
               .020738
        6 132 .019277
 VARY
5 VARY
               -01826
          141
        6 150
 VARY
               .017396
        6 159
 VARY
              .016539
4 VARY
        6 168 .0156176
 WARY
        6 177
               .014555
 VARY
        6 186
              .01323
3 VARY
        6 195 -01136
 VARY
        6 204 ,0083
 1D**
               AIR CONDENSING HEAT EXCHANGER
2.NSTR
              2110001
```

```
KBAS
                             6 2
           66 50,
 VARY
                              ESTIMATED VALUE COND. UA
 YARY
           74 3.
                              MAXIMUM NTU
  ARY
        7
           75 55.
                              DESIRED TEMP. FOR AIR TO CABIN(F)
           85 10.
 VÁRY
                              TIME CONSTANT (SECONDS)
 1Dee
              AIR CHARCOAL FILTER
 NSTR
             3
 KBAS
        8
           77 .01
                              TRACE CONTAMINATES REMOVAL EFFICIENCY
 VARY
 1Des
              MAKEUP WATER TANK
 NSTR
             1210
KBAS
                                                                            20
        9 ...
           ____30
                              __0__1
 VARY
           01 4.0
                              TOTAL FLOW WATER FROM ACCUMULATOR(LB/HR)
           02 75.
                              TEMP. OF WATER FROM ACCUMULATOR(F)
 VARY
           04 14 7
                              PRESS OF WATER FROM ACCUMULATOR (LB SO IN)
 VARY
           54 75.
 VARY
        9
                              AMBIENT GAS TEMPERATURE(F)
           55 1.
 VARY
                              UA TO SURROUNDINGS (BTU/HR#F)
        9 57 75.
- VARY
                             --AMBIENT RADIATION TEMPERATURE(F)
                              AMBIENT STRUCTURAL TEMPERATURE+F)
           60 75.
 VARY
 VARY
           67 31.2
                              TOTAL MASS: IN TANK . (LB)
 VARY
           48 75.
                              FLUID TEMPERATURE(P)
           69 0.5
 VARY
                             FLUID VOLUME(CU FT)
           70 14.7
 VARY
                              FLUID PRESSURE (PSIA)
VARY
                              MASS OF HEO IN TANK (LB)
           73 31.2
           90 0.
 VARY
                              THERMAL CAPACITANCE (BUT/F)
           91 0.
                              THERMAL CONDUCTANCE FLUID/TANK WALL(BUT/HR-F)
 VARY
VARY
                             MAXIMUM ALLOWABLE TEMP CHANGE(F)
              WATER ACCUMULATOR
 1000
       10
  STR
       10
              1210
 BAS
                                                                            19
       10...
           ____30___
                              TOTAL FLOW FROM WATER MAKEUP TANK(LB/HR)
 VARY
       10
            01 4.0
            02 75.
 VARY
       10
                              TEMP. OF WATER PROM MAKEUP TANK(F)
 YARY
            04
                              PRESS OF WATER FROM MAKEUP TANK (LB/SO IN)
       10
 VÄRY
            54
              75.
       10
                              AMBIENT GAS TEMPERATURE(F)
            55 1,
 VARY
       10
                              UA TO SURROUNDINGS (BTU/HR#F)
           57.75
VARY
       10
                            --- AMBIENT RADIATION TEMPERATURE(F)
            60 75,
                              AMBIENT STRUCTURAL TEMPERATURE(F)
 VARY
       10
 VARY
       10
            67 4.7
                              TOTAL MASS IN TANK
                                                      (LB)
 VARY
           48
                              FLUID PEMPERATURE(F)
 VARY
            69 .075
                              FLUID VOLUME (CU FT)
       10
           70 14.7
 VARY
       10
                              FLUID PRESSURE (PSIA)
VARY
       10
           73 4.7
                              MASS OF HEO IN TANK (LB)
 VARY
       10
            90
                              THERMAL CAPACITANCE (BTU/F)
                              THERMAL CONDUCTANCE PLUID/TANK WALL(BTU/HR-F)
 VARY
       10
           91
VARY
       10
                              MAXIMUM ALLOWABLE TEMP. CHANGE(F)
               DESORBED CO2 FLOW COMPRESSOR
 ID.
       11
 NSTR
              003
       11
           ----23
KBAS-
      -11-
                                                                            12
                            16-2----
 VARY
                              HEAT ADDED TO GAS STREAM(WATTS)
       11
                10.
               STEAM CONCENSING HEAT EXCHANGER
 IĎ**
       12 .
NSTR
              <del>2110001</del>...
 KBAS
       12
                            11 2
                                                   -18 0
                                                                            13
 VARY
           66 50.
       12
                              ESTIMATED VALUE COND. UA
-VARY
       -12-
           74.3.
                              MAXIMUM-NTU-
 VARY
       12
            75 55.
                              DESIRED TEMP. FOR AIR(F)
 VARY
       12
            85 10.
                              TIME CONSTANT (SECONDS)
3 1 Dee
       13
               CO2 ACCUMULATOR
       13
              0210
 NSTR
       13
              30
                            12 2
 KBAS
2 VARY 13 01 ,575
                          - CO2-USE RATE
                                                                (LB/HR)
```

```
54 75.
                            AMBIENT TEMPERATURE
VARY
      13
                                                           (F)
          55 2.
                            UA INSULATION/SURROUNDINGS
VARY
      13
                                                           (BTU/HR=F)
          67 307
VARY.
      13
                           TOTAL MASS IN TANK (LB)
 ARY
      13
          69 2.0
                            TANK VOLUME:
                                                           (CU PT)
 VARY
                          ACCUMULATOR PRESSURE (PSIA
          70 20.
      13
VARY
      13 78 307 MASS OF CO2 IN TANK (LB
             SOURCE OF FLOW TO SYSTEM (DUMMY COMPONENT)
IDee
      14 .
NS TR
      14
KBAS
                            TOTAL FLOW TO SUBSYSTEM(LB/HR)
 VARY
      14
           1 84.867
           2 75,
                              TEMPERATURE (F)
VARY
      14
VARY 14
          4_14.7
                            PRESSURE (PSIA)
 VARY
      14
           6 76
                            WATER VAPOR(LB/HR)
 VARY
          10 19.4
                              OXYGEN(LB/HR)
      14
VARY-
          11 64.2
                            NITROGEN(LB/HR)
         12 .507
                            CARBON DIOXIDE(LB/HR)
      14
 VARY
                                                         (LB/HR)
      14
          13 .02
 VARY
                            TRACE CONTAMINATES
          -- STEAM BOILER (GENERATOR)
. I Das.
     ...15...
 KBAS
      15
             27
                                                                      16
                         19 2
          66 20
                                                           (F)
 VARY
      15
                            DEGREES SUPERHEAT
NSTR
      15
            -01-
 1D.
            DESORBING SOLID AMINES BED
      16
 NSTR
      16
            201002300
                         15
                             0
KBAS 16
          36108 15 2
                                                                      11
                            BED DESORBING DURING STEADY STATE
      16
 KARY
          16
                            USE BUILT IN ISOTHERM DATA FOR H20
      16 17
                     • 🐔
 KARY
KARY
                      I
                            INTERPOLATE TABLE FOR COZ EQUIL PART PRESS.
      16
          18
                     19
 KARY
      16
          21
                            NUMBER OF BED ELEMENTS
 KARY
      16
          22
                            BED DESORBING DURING TRANSIENT
 ARY
      16 65 0075
                           AVERAGE CO2 BED LOADING(LB/LB)
                            AVERAGE H20 BED LOADING
 VARY
      16
          66 ,22
 VARY
          68 28,8
                            BULK DENSITY(LB/CU FT)
      16
VARY
      _16
          69 .00115
                           PELLET DIAMETER (PT)
          70 .40
 VARY
     16
                           VOID FRACTION
          71 3130,
                       SUPERFICIAL SURFACE AREA(SQ FT/ CU FT)
 VARY
      16
VARY
          72 1
     ...16
                       CHANNELING FACTOR
          73 1.
 VARY
      16
          75 1.57
                           BED FRONTAL AREA(SQ FT)
 VARY.
      16
          76 458
VARY
      16
                           BED LENGTH (FT)
          77 3,23
 VARY
      16
 VARY
      16
          78 3,22
VARY
     -16
          79 250
                         HEAT OF SORPTION-CO2-(BTU/LB)
 VARY
                            BINARY DIFFUSION COEF. - CO2/AIR- (SQ FT/HR)
      16
          80 ,536
                            OVERALL MASS TRANS. COEF. FOR CO2(DESORPTION)
 VARY
          81 14.
                    E=4
      16
                            OVERALL MASS TRANS. COST. FOR COSTABSORPTION)
          82 6.8
                   E-04
 VARY
       16
                            HEAT OF SORPTION-H20-(BTU/LB)
 VARY
      16
          83 1400,
 VARY
          84 ,854
                            BÎNARY DIFFUSION COEF. -H20/AIR-(SQ FT/HR)
      16
                           OVERALL MASS TRANS. COEF. FOR H20(DESORPTION)
VARY
      16
          85 22.
                  ___E=4
                            OVERALL MASS TRANS. COEF. FOR H20(ABSORPTION)
          86 6.8
 VARY
      16
                    E=4
          99 0,50
                            DURATION DESORPTION CYCLE
 VARY
      16
                                                           (HOURS)
      16 100 .26
                           DRY RESIN SPECIFIC HEAT(BUT/LB=F)
5 VARY
      16 103 ,5
                         MULTIPLYING FACTOR FOR COMPUTING INTERVAL
 VARY
 VARY
      16 104 0.
4 VARY 16 108 75.
                       VARY
      16 109 75.
                      INITIAL BED TEMPERATURE(F)
                        INITIAL VALUE AIR PARTIAL PRESSURE (MM HG)

INITIAL HED LOADING (LB/LB)
      16 112 760.
 VARY
3 VARY 16 107 .18070
 VARY
      16 116 .18068
      16 125 18068
 VARY
<sup>2</sup> VARY 16 134 ,18068
```

```
16 143 ,18067
  VARY
            16 152 18059
  VÁRY
             16 161 18029
              16 170 .17938
   RΥ
  VARY
              16 179 117692
 VARY
            16 188 .17304
            16 197 .16597
  VARY
  VÄRY
              16 206 .16245
  VARY
                    105 0155
              16
                                                          INITIAL COZ LOADING
  VARY
              16 114 .0155
              16 123 ,0156
  VARY
  VARY.
              16 132 .0156
              16 141 ,0156
  VARY.
              16 150 ,0156
  VARY
  VARY
  VÄRY
              16 168 .01659
             16 177 0325
  VÄRY
            16 186 .0485
 VARY
              16 195 ,0496
  VARY
              16 204 .0481
  VARY
  1000
                             SOURCE OF COOLANTIDUMMY COMPONENT)
  NSTR
              17
KRAS 17 49 0 1
Vary 17 1 200: Total Coolant Flow to process air condenser(Lb/hr)
              17
            17 2 40, TEMPERATURE(F)
17 4 14.7 PRESSURE(PSIA)
  VARY
  VARY
                         SOURCE OF COOLANT (DUMMY COMPONENT)
  <u>lĎe•</u>
  NSTR
              18
              18 49 0 1
18 1 200, TOTAL COOLANT FLOW TO DESORBED GAS CONDENSER(LB/HR)
     RAS
      PY....
                   2 40. TEMPERATURE(P)
4 14.7 PRESSURE PRIAS
  VARY 18
  VARY
              18
              19
                         - WATER METERING PUMP
  1Dee
              19 0002
19 22 10 0 1
19 85 15, HEAT INPUT TO PLUID BY PUMP (WATTS)
  NSTR
  KBAS
 VARY
 KBAS 20 12 0
VARY 20 03 14.7 CONDENSATE TEMPERATURE
KARY 20 16 2
KARY 20 18 12
TABL 1 1 3 8 5 LOG LIN LIN
  TITL 1 2 IRA45 EQUILIBRIUM ISOTHERMS(24,5 HT PER CENT H20) PPCO2 VS LOADING VALU 1 11 31 74. 100.
               1 11 3 74, 100, 130, 180, 250, 1 12 30 0, 0,0001 0,0001 0,0001 ,0001

      VALU
      1 12 3D 0.
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
      0.0001
                                               10.7 135. 303.

1.4 8.0 25. 220. 492.

2.5 8. 37. 345. 653.

230. ABSORBING BED AVER, BED TEMP.(F)

.08 ABSORBING BED AVG. CO2 LOADING(LB/LB)

.30 ABSORBING BED AVG. H20 LOADING(LB/LB)

10. ABSORBING BED CO2 FLOW OUT(LR/HB/LB)

20. ABSORBING BED CO2 FLOW OUT(LR/HB/LB)
                1 19 3D .045
  VALU
PLOT 6 98 0,

PLOT 6 65 0,

OT 6 66 0,

PLOT 6 12 0,

PLOT 6 0
                                             .30
10.
                                                                              ABSORBING BED M20 FLOW OUT(LB/HR)
PLOT 6 207 0.
PLOT 6 203 0.
2 PLOT 6 205 0.
                                               230.
760.
                                                                                ABSORBING RED GAS TEMP OUT(F)
                                                                                ABSORBING BED CO2 PARTIAL PRESSURE OUT (MM)
                                                760. ABSORBING BED H20 PARTIAL PRESSURE OUT (MM)
```

	•	I)–6		
PLOT PLOT	16 98 0. 16 65 0,	230,	DESORBING BED DESORBING BED	AVER, BED TEMP, (F) AVG, CO2 LOADING(LB)	'LB)
PLOT PLOT PLOT PLOT PLOT PLOT PLOT	16 66 0. 16 12 0. 16 6 0. 16 207 0. 16 203 0. 16 205 0.	10. 20. 230. 760.	DESORBING BED DESORBING BED DESORBING BED DESORBING BED DESORBING BED	AVG, H20 LOADING(LB, CO2 FLOW OUT(LB/HR) H20 FLOW OUT(LB/HR) GAS TEMP OUT(F) CO2 PARTIAL PRESSURE H20 PARTIAL PRESSURE	(LB);
ENDR					
				e E	÷
The second of the second secon					
		: :			
					The second secon
,					
5			4		·
4					

```
INSERT.GPOLY1,24
                   *VACUUM DESORBED AMINES*****
       IF ( STEADY) GO TO 10
      IF- NPASS, GT, 1< KCHOUTED
      IF ( N.NE.12) RETURN
      R(01) = 0.6
      V0801=VV(09.01)
    V0805# VV(09,05)
      V08068 VV(09:06)
      V0810# VV(09,10)
      V0811# VV(09,11)
      V0812= VV(09,12)
      V0813# VV(09,13)
      CALL SV(V0801,08,01)
      CALL SV(V0805,08105)
      CALL SV(V0806,08:06)
      CALL SV(V0810,08:10)
      CALL SV(V0811,08:11)
      CALL SV(V0812,08712)
      CALL SV(V0813,08,13)
   10 CONTINUE
       IF( N, NE. 12) RETURN
       R(01) # A(01)
TAPE
 BASIC
            THERMAL/VACUUM DESORBED SOLID AMINES
 CASE
      KCHOUTEO, KPRNTenoo, KPTINV(1)e030, KRUNE1,
       TMINE=460., TMAX=2000., WTMAX=10000.MAXSLP=30.
       DTIMER2. STARTSO. TIMEMX=1200. MAXSEIR2.
      MINSSIE1 5
  SPROP1
      CPCQ28-197. CPDILE-22. VISQA98-045. WTMTC#16.
       XKGASE, 0147, WTMD LE28, WTMCONR18, CPCONVE, 44,
       CPCONL#1., CP(1)#1., RHO(1)#62,4, VISC(1)#2,37,
       WTM(1)=18. XK(1)=.347.
       CP(2)=1, , RHO(2)=60.1, VISC(2)=.738.
       CPOXY#, 22, CPTC#, 50.
       WTM(2)=18. XK(2)=.394
 !D..
              SOURCE OF CABIN AIR FLOW TO SUBSYSTEM
              49
 KBAS
NSTR
       01
           1 84.87
 VARY
                            TOTAL FLOW TO SUBSYSTEM
                                                            (LB/HR)
       01
           2 75,
 VARY
      01
VARY
       במ
 VARY
       01
           6 0,766
 VARY
       01
           10 19.4
          11 64,23
VARY
      01
VARY
       01
           12 .628
```

```
VARY
      01
          13 .01
 ID.
             SUBSYSTEM BLOWER
       2
 KEAS
  PR
      02
            003
VARY
      02
          91 60.
                           HEAT ADDED TO GAS STREAM
1 D ..
      - AIR BYPASS VALVE
 KBAS
             10
                           2 2
NSTR
      03
          45 .001
VARY
      03
                           <u>Fraction of total flow bybassin subsystem</u>
 ID.
             SOURCE OF COOLANT FOR ABBORRING BED (COOL WATER)
 ID:
             SOURCE OF HOT FLUID FOR DESIRBING BED(HOT WATER)
KBAS
             NSTR
      04
           1 270.
 VARY
                            FLOWRATE
                                                           (LB/HR)
VARY
           2 200-
                            TEMPERATURE
                                                          (5)---
           4 14.7
 VARY
                                                           (PSIA)
                            PRESSURE
             49
KBAS
       5
                            0 1
      05
NSTR
           1 270.
                            FLOWRATE
 VARY
       5
                                                           (LB/HR)
 VARY
       5
           2 55.
                            TEMPERATURE
                                                           (F)
-VARY
           4 14.7
                                                          . (PSIA)
                           PRESSURE
 i D.
             ABSORBING SOLID AMINES BED
       6.
                                               e5 0
                                                                       7
 KBAS
             36108
                           3 2
       6
NSTR 6 2131
                       - 4.1----
 KARY
       6
         16
                            BED ABSORBING(STEADY STATE)
 KARY
         17
                     • 4
                            USE BUILT-IN H20 ISOTHERMS
       6.
         _18
 KARY
                     _0
                          - INTERPOLATE TABLE FOR CO2 PART, PRESS-
 KARY
          21
                     19
                            NUMBER OF BED ELEMENTS
                    Ò
       6
          22
  MRY
                            BED ABSORBING (TRANSIENT)
      6 57 5
 ARY
 VARY
       6
          55 15
 VÄRY
          65 1018
 VARY
          66 .22
 VARY
          68 28.8
                            BULK DENSITY(LB/HR)
 VARY
       6 69 .00115
                            PELLET DIAMETER(FT)
VARY 6 70 40
                          VOID FRACTION
          71 3130.
                            SUPERFICIAL SURFACE AREA(SQ FT/CU PT)
 VARY
       6
          72 1.
 VARY
       6
                            SPHERICITY
          73 1
 VARY
                            CHANNELING FACTOR
 VARY
       6
          75 1.57
                            BED FRONTAL AREA(EG FT)
 VARY
       6
          76 .458
                            BED LENGTH(FT)
 VARY 6 77 3.23
 VARY
       6 78 3,63
 VARY
          79 250.
        6
                            HEAT OF SORPTION-CO2-(BTU/LB)
VARY
         80 .536
                            SINARY DIFFUSION COEF. = CO2/AIR=(SQ FT/HR)
                            OVERALL MASS TRANS. COEF. FOR COR(ABSORPTION)
 VARY
       6 82 6.8
                   E-04
                            HEAT OF SORPTION-H20-(BTU/LB)
          83 1400.
 VARY
VARY 6 84 854
                          BINARY DIFFUSION COEF, -H20/AIR-(SQ FT/HR)
          86 6.8
                            OVERALL MASS TRANS. COEF. FOR H20(ABSORPTION)
 VARY
 VARY
        6
          87 0,
                            U CORE/GAS
                                                           (BTU/HR=SQ FT=F)
          88 1.
                              CORE/GAS
5 VARY
                                                          (SO FT)
                            U CORE/BED
 VARY
          89 .146.
                                                          (BTU/HR-SQ FT-F)
                                                         (80 FT)
 VARY
          90 1.
                            A CORE/BED
VARY 6 91 1.
                           - A GAS/CANNISTER
                                                           (SO FT)
                                                         (BTU/HR-SQ FT-F)
ARY
        6 92 0.05
                            U GAS/CANNISTER
                                                         (BTU/HR=SQ FT+F)
 VARY
          93 146.
                            U FLUID/CORE
          94 1.
3:VARY
                            A FLUID/CORE
                                                         --- (SO FT)
       6 98 75.
 VARY
 VARY
       6 100 .26
                          DRY RESIN HEAT CADACITY(BTU/LB=F)
2.VARY......6.102.1.0
```

```
VARY
       6 101 ,208
     6 103 ,5
                           MULTIPLYING FACTOR FOR COMPUTING INTERVAL
VARY
MARY
       6 104 9
  RY
       6.105 .018
                           INITIAL VALUE CO2 LOADING(LB SORBATE/LB DRÝ RESIN)
VARY
       6 106
VARY 6 107 .25
                      INITIAL VALUE H20 LOADING(LB SORBATE/LB DRY RESIN)
       6 108 200. INITIAL VALUE GAS DUTLET TEMPERATURE(F)
6 109 200. INITIAL VALUE BED TEMPERATURE(F)
6 112 760. INITIAL VALUE AIR PARTIAL PRESSURE(MM HG)
 VARY
     6 108 200.
VARY
VARY
             CHARCOAL TRAP
 IDe.
KBAS
             11
NSTR 07
           . . 3......
          77 :01
                           (1=TRACE CONTAMINATES REMOVAL EFFICIENCY)
VARY
      07
       B DESORBING SOLID AMINES BED
1Dee
            34108
KBAS B
      8
 NSTR
            2131
                         11
                             0.0
      8 16
KÄRY
                            BED DESORBING(DURING STEADY STATE)
      8 17
                            USE BUILD-IN RELATIONS HIP FOR H20 ISOTHERMS
KARY
                     ■ §
          18
      8
                            INTERPOLATE TABLE FOR COZ PART PRESS
KARY
                     2
          21
                   12 NUMBER OF BED ELEMENTS

BED DESORBING(DURING TRANSIENT)
KARY
      8
KARY...
          22
VARY 8 65 1018 SS AVERAGE CO2 BED LOADING (LB CO2/LB BED) VARY 8 66 22 SS AVERAGE H20 BED LOADING (LB H20/LB BED)
                                                          (LB/CU FT)
                         BULD DENSITY
VARY 8 68 28.8
 VARY
      8 69 00115
                                                           (FT)
                            PELLET DIAMETER
       8 70 ,40
 VARY
                            VOID FRACTION
                           SUPERFICIAL SURFACE AREA (SO FT/CU PT)
VARY
          71 3130.
          72 1.
VARY
       8
                          SPHERICITY
       8 73 1.
 MRY
                            CHANNELING FACTOR
ARY
                           BED PRONTAL AREA
      8 75 1.57
                                                          (SO FT)
          76 1458
 VARY
       8
                           BED LENGTH
                                                            (FT)
                            UA GAS/PELLETS DURING ABSORPTION(BTU/HR=S4 FT-F)
       8 77 3 23
 VARY
VARY
      8 79 250.
                          HEAT OF ABSCRPTION-CO2 (BTU/LB)
                            BINARY DIFFUSION COEF, = CO2/AIR (8G FT/HR)
       8 80 536
                   E=04
 VARY
OVERALL MASS TRANS, COEF, FOR CO2-ABSORPTION
                            HEAT OF SORPTION-H20- (BTU/LB)
                            BINARY DIFFUSION COEF, #H20/AIR (SO FT/ HR)
                            OVERALL MASS TRANS, COEF, H20=ABSORPTION
       8 87 0.
VARY
                            U CORE/GAS
                                                    (BTU/HR-SO FT-F)
                           A CORE/GAS (SQ FT)
U CORE/BED (BTU/HR=SQ FT+F)
A CORE/BED (SQ FT)
       8 88 1,
 VARY
VARY 8 89 146.
VARY 8 90 1.
                     A GAS/CANNISTER (SQ FT)
U GAS/CANNISTER (BTU/HR=SQ FT=F)
U FLUID/CORE (BTU/HR=SQ FT=F)
       8 91 1.
 VARY
 VARY
       8 92 0,
       8 03
VARY
       8 94 1.
 VÁRY
                           A FLUID/CORE
                                                            (80 FT)
VARY 8 98 180.
VÁRY 8 99 25
                      DURATION OF DESCRIPTION CYCLE (HOURS)
       8 100 26 DRY RESIN HEAT CAPACITY (BTU/LB=F)
8 101 208 HX THERMAL CAPACITANCE (BTU/F)
8 102 1.0 FLUID THERMAL CAPACITANCE (BTU/F)
VARY 8 100 ,26
 VARY
5 VARY
                        MULTIPLYING FACTOR FOR COMPUTING INTERVAL
 VARY 8 103 50
 VARY 8 104 0.
                           INITIAL VALUE CO2 PART, PRESSURE (MM HG)
4VARY 8 105 0,031
                         - INITIAL VALUE CO2 BED LOADING (LB/LB)
 ARY
VARY
       8 106 20.
                          INITIAL VALUE HZO PART, PRESSURE (MM HG)
       8 107 ,25
                           INITIAL VALUE H20 LOADING (LB/LB)
3 VARY 8 108 75.
                           INITIAL VALUE GAS TEMPERATURE (F)
VARY 8 109 75.
VARY 8 110 75,
                      INITIAL VALUE BED TEMPERATURE (F)
HEAT EXCHANGER CORE TEMPERATURE (F)
2 VARY 8 111 75.
                          - HEATING FLUID TEMPERATURE (F)
```

VARY	Ω	442	740	•	14771A	MAI HE ATE B	ABT PPECCHI	35 (MM DO)	·
	0	776	(90)		INTITAL	VALUE AIR P	AKI FLUESON	TE (MM MW)	
1D**			VACUU	M PUMP			•		
LEAS	9_		28	<u> </u>	5				10
P rR	-		72 '	•					•
	y		144					1000.1	
VARY	9	75	20.	I	PISCHARG	E: PRESSURE		(PSIA)	
-KARY	9	16			PABLE FO	R COMPRESSO	R- FLOW		
VARY	9		0.60		ANTID DE	CHATCHTY	., , , ,	(DIM)	
VARY	9	67	0,40		LERODYNA	MIC EFFICIE	NCY	(D.IM)	
-VARY	9	71	_ n		PACTION	O LOST TO	AMRIENT	(DIM)	
VARY	09								•
						IC EXPONENT			
1 D • •	10		CONDE	SING HEAT !	EXCHANGE	R			
KBAS	_10		Δ	9			.=11 1		12
	10		200000		4		- m as a		
NSTR					3				
VARY	10	75	75.		DESIGN T	EMPERATURE		(F)	
-VARY	10	66	7.5		IL FOR H	X	·		
1 D	11						AT SYCHAMO	20	
	-		SOURC	E OF GOOGA	NT 10 CO	NDENSING HE	AT EXCHANGE	5 r	
KBAS	11		49	2 41.	0 2				
NSTR	11								
-		4	4.0		P. ALDAR	,		410400	•
VARY	11		. 40 t	!	PONKATE	}		(LB/HR)	
VARY	11	2	40.		TEMPERAT	'URE		(F)	
-VARY	-11		14.7		BESSUEE	URE		(PSIA)	
			600 4	ACHMAN ARAB					
ID**	12	3	AOS V	CCUMULATOR					_
KBAS	12		3 0	10	2				2
NSTR			0020					k .	
						B. 55		41.04.004	
VARY	12		, 19/0	Į.	CO2 USE	RATE		(LB/HR)	
VARY	12	. 54	75.	i	AMBIENT	TEMPERATURE	·	(F)	
VARY	12	E 5	2	i i	IA INCIII	ATION/SURRO	HARTNES	/RYIL/MD.	· F \
_			-			A I I A II P S A I R A	DIVER TO A LAND		
VARY	7,2	67	0,307		TOTAL MA	SS IN TANKE IN TANKEIN	INITIALTY	(PB)	
MRY	12	78	0.307	`	MASS CO2	I IN TANKLIN	ITIALLY	(LB)	
ARY	12	9 (24		TANK OOF	SSURE	g / g / ww.i /	(PSIA)	
		·- ·/\			1 4 14 th 14 14 E			(POTA)	
TABL	1	1	-3	1	1. 4	LOG L	DG FIN		
7176	1	2	VACUUM	PUMP FIOW	CHARACT	'ERISTICS (LA	RGE PUMP)		
-VALU								50.	
·	-	- 43	3+			44.7	- 9 V I		Approximation and the contract of the contract
VALU	1	12	3h 1'	4,:	15	4,35	4,8	5,	
VALU	1	13	3D 5.	4.	19	4,25	4,8	5	
	1	14	TD 40.	3,	7 #	4,15	A R	5.	
			· 2 th · · · # 10-1	51.	Jg		4,5		•
VALU	1	15	30 30,	2,	30	3,20	4,0	4.3	
VALU	1	16	3D 50,			2,5	3,3	3,9	
-VÁLU	7	1 7	3D 70.	*1	4 68	2.05	2.80	7 7	
			- m - 1 - 1	<u>a T</u>	} 		- \$100		
VALU	1	18	3D 100			1,35	2,25	2.8	
VALU	1		30 118		0001	1,25	2,15	2,6	
						A 1 T A A 4			
VALU			30 228		0001		0,8	1,2	
VALU	1	21	3D 370	0.	0001	0.0001	0,0001	, 4	
VALU	1		30 420		0001	0.0001	0,0001	0.0001	
T T L			3	•				AIAAAT	
TABL			•		65		IN LIN		
TITL	2	2	1R=45	EQUILIBRIU	M ISOTHE	RMS(24.5 WT	PER CENT	H20) PPC02	VS LDADING
			31	74		100.	130,		250,
VALU	~							180.	
VĀLU-	2	1 2-	.3D0.,	D ₁ -	0001	0,0001	0,0001	0,0001	,0001
VALU	2		3D ,00			,16	.30	,50	78
	2								
VALU	<		3D .01			. 26	.87	2,0	3,58
5 VALU	2	<u>15</u>	30 .05	2		69	4.0	20,	42.4
VĀLU	2	16	30 03	•		1.85	11.	85	189.
				19	<i>*</i>	#4 % A			1071
VALU			30 ,03		7	3,0	16,5	135.	303,
4 VALU			3D 04		4	5.0	25,	220.	492.
ALU	6	Ÿ A	3D ,04	5 2.	7	8,	37.	345,	653,
ENDC									•
	1								
ENDR									and the same and t

```
*INSERT.GPOLY1.24
       IF(N .NE. 18) GO TO 10
       VV12=VV(4,12)
       VV431=VV(4.31)
       VV4018VV(4,1)
       VV420=VV(4,20)
       VV720=100. =VV431/VV420
       VV7218100.* VV12/VV401
       VV722#VV(4,12)+VV(4,10)
       CALL SV(VV720,7,00)
       CALL SV(VV721,7,21)
       CALL SV(VV722,7.22)
       V480=VV(4.80)
       V880=VV(8,80)
       R(1) =
                  V480+V880
    10 CONTINUE
 TAPE
 BABIC
                                         12
                                                YEA
                                                         NAY
CASE
             CARBONATION CELL CO2 CONCENTRATOR SYSTEM CHECKOUT
  SCASE1
   KCHOUTED, KPRNTe6, KPTINV(1)#15, MAXSLP#7, MINSSI#2, KRUN#1, DTIME#30.
   <u> TIMEMX=3600..MAXSSIas. TMAX2250..TMINB=450..WTMAX#1.54 S</u>
  SPROP1
  GP(1)=,239,RHO(1)=,16 ,VISC(1)= ,036 ,WTM(1)=28,0
                                                           XK(1) 5.007
  <del>CP(2)=1,,PH0(2)=62,</del>4
                          -VISC(2) = 3.6 - WTM(2) = 18.0
                                                         - XK(2)* 325
  CP(3)=,175,RHO(3)=,25
                          , VISC(3) = , 036 , WTM(3) = 44, 0
                                                           ,XK(3)#,007
   CPCONL#1,, CPCONV#0,44, CPCO2#0,2, CPDIL#0.25, CPOXY#0.22, CPTC#0.2,
   BAMGAS:1.4. VISGAS:0.44. WIMCON:18.. WIMDIL:28.. WIMIC=20..
   CPC02 = .178.
                       WYMCONE18. ,
   XKGASED.146 $
....ID++.......1...1.DUMMY..COMPONENT.PROVIDING THE INLET FLOW TO CO2 REMOVAL SYSTEM USIN
 1Das
             2 THE CARBONATION CELL CONCEPT.
 KBAS
               49
 VARY
                 211,987
                               TOTAL FLOW
                                                                            (LB/HR)
 VARY
             2
                  70,
                               TEMPERATURE
                                                                            (F)
 VARY
             3
                                                                            (PSI)
                 14.7
                               PRESSURE
                14.7
VARY
             4__
                               PRESSURE
                                                                            (PSI)
 VARY
             5
                209,697
                               NON#CONDENSABLE FLOW
                                                                            (LS/HR)
 VARY
             6
                  2,29
                               VAPOR FLOW
                                                                            (LB/HR)
                               NON-CONDENSABLE SPECIFIC HEAT
VARY
             8
                  -24
                                                                            (BTU/LB-F)
 VARY
            9
                28.97
                               NON-CONDENSABLE MOLECULAR WEIGHT
                                                                            (MOLES/LB)
 VARY
            10
                  49.3
                               OXYGEN FLOW
                                                                            (LB/HR)
VARY
           11
                 159,13
                                                                            (LS/HR)
                               DILUENT (N2) FLOW
 VARY
           12
                  1,267
                               CO2 FLOW
                                                                            (L3/HR)
 ID**
        2
               BLOWER PASSING THE STREAM: FROM COMPONENT 2 TO 3
 KBAS
               23
 NSTR
        2
              0030
                                     SUBROUTINE FAN ADD HEAT SPECIFIED IN R(91)
 VARY
        2
                 150.
                               HEAT ADDED TO GAS STREAM AS IT FLOWS THROUGH THE
 10+
               WATER VAPOR MASS EXCHANGER HUMIDIFIER/DEHUMIDIFIER
 KBAS
               26
                               EFFECTIVENESS FACTOR FOR MASS TRANSFER
        3
           65
 VARY
                   , 95
5 VARY
                               EFFECTIVENESS FACTOR FOR HEAT TRANSFER
                   .94
 ID:
               FIRST STARE OF ELECTROCHEMICAL CARBONATION CELL CO2 CONCENTRATOR SY
 IBAS
               24
                              3 2
 NSTR
                                   --- POUNDS OF HEO AND TEMP, OF STAGE TRANSIENT
           - 01--
           16
                               COMPONENT NUMBER OF COOLANT SUPPLY
 KARY
                       34
 VARY
                 231.00
                               FLOW
                                                                            LB/HR
VARY
                               TEMP
                 -140-
 VARY
             3
                 14,7
                                                                            PS1
                               PRESS
 VADV
                 14.7
                               PRESS
                                                                            PS1
```

```
VARY
            6
                 13.61
                              VAPOR FLOW
                                                                           LB/HR
                  24
 VARY
            8
                                                                           BTU/LB+F
                              SPECIFIC HEAT
 LARY
            ٥
                 28,923
                              MOLECULAR NEIGHT
                                                                           LB/MOLE-
  RY
           10
                 49.3
                              OR FLOW
                                                                           LB/HR
VARY
                159,13
           11
                              N2 FLOW
                                                                           LB/HR
                  ,84
VARY
           12
                              CO2 FLOW
                                                                           LB/HR
                  7Ō,
VARY
           54
                              AMBIENT GAS TEMPERATURE
                                                                           ·F)
                              THERMAL CONDUCTANCE HETWEEN SURFACE AND GAS (B/HR-F)
 VARY
           55
                  0.1
                 40.
                              AMBIENT RADIATION WALL TEMP (F)
VARY
           57
                               THERMAL RADIATION PA FACTOR
                                                                           (FT==2)
 VARY
           58
                  2
 VARY
                               STRUCTURE TEMP FOR HEAT SHORTS
                                                                           (F)
           60
                 60,
                              THERMAL CONDUCTANCE BETWEEN MODULE/STRUC. (BTU/HR.F)
VARY ....
           61
                 .1
 VÀRY
                 .00121
                               TRANSFR RATE OF CO2
                                                                     (LB/HR-AMP-CELL)
           66
                              DESIRED MODULE TEMPERATURE
 VARY
           67
                 140.
VARY
                              HEATER TURNOFF TEMPERATURE
                                                                          (5)
           48
                  142.
 VARY
                                                                           (F)
           69
                              HEATER TURNOFF TEMPERATURE
                  138.
                                                                           (F)
 VÁRY
           70
                  140.
                               ACTUAL TEMPERATURE OF MODULE
VARY.
           71
                 35..0. ...
                              DESIGN CURRENT DENSITY
                                                                           (AMP/FTSQ)
           72
VARY
                                                                           (FTSQ)
                  1.0
                               AREA OF A CELL
 VÁRY
           73
                  15.
                              NUMBER OF CELLS IN MODULE
                   1.17
-VARY
           75
                               VOLTAGE PER CELL
                                                                           (VOLTS)
 VARY
           77
                               RELATIVE HUMIDITY IN EXIT CATHODE STREAM
                   48.
 VARY
           78
                               RELATIVE HUMIDITY IN EXIT ANODE GASES
                  95.
VARY
           80.
                               EXTERNAL WATER MAKEUP RATE TO MATRIX
                  1,52
 VĂRY
           81
                  1.5
                              WEIGHT OF WATER PER CELL IN MATRIX.
 VARY
                                                                           (LB)
           82
                  1,83
                               WEIGHT OF CS2CO3 IN CELL
                  55,
VARY
           22
                               DESIRE SOLIDS CONDENTRATION IN MATRIX
                                                                        (PER CENT)
                  55,
 VARY
                               ACTUAL SOLIDS CONCENTRATION IN MATRIX
           84
                                                                           (PER CENT)
  ARY
            86
                  14.7
                               TOTAL PRESSURE OF STAGE
                                                                           (PSIA)
                  40.
 ARY
           87
                               THERMAL CAPACITANCE OF STAGE
                                                                           (BTU/F)
 VARY
                               HEAT XSFR CONDUCTANCE FROM COOLNY TO CELL (BTU/HR-F)
           92
                  33.0
 VARY
           94
                               ADDITIONAL HEAT SOURCE/SINK TO MODULE (BTU/HR)
               DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT 4
 Dee
                                                                         CARCLA
 KBAS
       33
               40
 VARY
       33
                  100.
                               COOLANT PLOWRATE
                                                                            (LS/HR)
 VARY.
                              TEMP OF COOLANT
                                                                            (F)
       33
             2
                  100 ...
 VÄRY
       33
             3
                   20.
                               PRESSURE
                                                                            (PSIA)
 VARY
       33
                   20.
                               PRESSURE
                                                                            (PSIA)
       34
KBAS
                            33 0 2
 VARY
       34
                  100.
                               COOLANT FLOWRATE
                                                                            (LB/HR)
 VARY
       34
                  100.
                               TEMP OF COOLANT
                                                                            (F)
                              PRESSURE
VARY
       34
                  --20...
                                                                           (PSIA)
 VARY
       34
                   20.
                               PRESSURE:
                                                                            (PSIA)
                          HEAT EXCHANGER H20 SEPARATOR SUBROUTINE ANYHX
 ID.
        6
               CONDENSING
CABX
                                                    -36 0
 NSTR
             211000100
                                     LIQ. ... GAS HX WITH PRI OUT TEMP CRITERIA FOR SIZ
 VARY
            66
                  35.
                               OVERALL UA
                                                                            (B/HR-F)
VARY
           7.4...
                  5.0
                              (NTU)MAX
            75
                  65,
 VARY
                               DESIGN OUTLET TEMP PRI SIDE
                                                                            (F)
                               TOLERANCE FOR PRI BIDE TEMP
 VARY
        6
            76
                                                                            (F)
               DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT
5 1 Das
 KBAS
       36
               49
       36
                   40.
 VARY
                               COOLANT FLOWRATE
                                                                            (LB/HR)
4 VARY
       36 -
                  45,
                               TEMP OF COOLANT
                                                                            (F)
 ARY
       36
             3
                   20.
                               PRESSURE
                                                                            (PSIA)
 VARY
                   20.
                               PRESSURE
                                                                            (PSIA)
3 ! Ďa e
               FLOW RETURN TO CABIN METERED.
        7
              29 12
 KBAS
                              6 2
 NSTR
                                     METER ALL CONSTITUENT FLOWS
                  32.0 REFERENCE TEMP FOR ENTHALPY.
2 VARY
                                                                            (F)
```

```
ID.
             2ND STAGE CARBONATION CELL COR CONCENTRATION SYS, (CARCL2)
KBAS
       8
             25
                          -4 2
NSTR
                                  H20 BALANCE CONSTANT TEMP OF STAGE TRANSIENT
            01
 RY
       8
          16
                            COMPONENT NUMBER OF COOLANT SUPPLY
 VARY
                70.0
          54
                            AMBIENT GAR TEMP.
VARY
                0.1
                            CONDUCTANCE BETWEEN SURFACE AMBIENT GAS
       8
          55
                                                                      (BTU/HR)
VARY
       8
          57
                            AMBIENT RADIATION WAL TEMPERATURE
                                                                      15)
                60.0
 VARY
       8
                 2.0
                            THERMAL RADIATION FA FACTOR
                                                                     (FTSQ)
          58
                            STRUCTURE TEMP FOR HEAT SHORTS
VARY
          60
                60.0
                                                                     15)
                            CONDUCTANCE BETWEEN MODULE AND STRUCTURE (BTU/HR-F)
 VARY
                 0.1
       8
          61
                            REMOVAL EFFICIENCY OF OXYGEN
 VARY
       8
          65
                 .98
VARY
          67
                172.
                            DESIRED MODULE TEMPERATURE.
                                                                      (F)
                            HEATER TURNOFF TEMP.
 VARY
          68
                174.
                                                                      (F)
                                                                      (F)
 VARY
       8
          69
                170,
                            HEATER TURNON TEMP
VARY
          70
                172.
                            ACTUAL TEMP OF MODULE
                            DESIGN CURRENT DENSITY
 VARY
          71
                 50.
                          NUMBER OF CELLS IN MODULE
 VARY
       8
          72
                 1.0
VARY
          73
                 8.0.
                 1,25
       8
          75
 VARY
                            VOLTAGE PER CELL
                                                                     (VOLTS)
                            RELATIVE HUMIDITY IN EXIT CATHODE GASSES
 VARY
          77
                 35.
          78
                            RELATIVE HUMIFITY IN EXIT ANODE GASSES
VARY
                 9B.
                            EXTERNAL H20 MAKEUP RATE I(R) IF NSTRIBL (L3/HR)
 VARY.
       8
          80
                 .5
                 1.20
 VARY
          81
                            WEIGHT OF H20 PER CELL IN MATRIX
                                                                     (LB)
                 1.2
VARY
                         WEIGHT OF H3PO4 PER CELL IN MATRIX
       8 82
                                                                      (LB)
                            DESIRED HSPO4 CONCENTRATION IN MATRIX
 VARY
       8
          83
                 50.
                            ACTUAL HSPO4 CONCENTRATION IN MATRIX
 VARY
          84
                 50.
 VARY
          85
                            VAPOR PRESSURE OF WATER OVER ELECTROLYTE (PSIA)
 VARY.
                            TOTAL PRESSURE OF STAGE
       -8
          86
                14,7
                                                                      (PSIA)
          87
                            THERMAL CAPACITANCE OF STAGE
  ARY
       .8
                 45.
                                                                     (BTU/F)
                            HEAT TRNSFR CNDCTNC FROM COOLANT TO CELL
       .:8. 92.
  ARY.
                                                                      (B/HR-F)
                 Ů.
                                                                      (BTU/HR)
 VARY
       8
                            ADDITIONAL HEAT SOURCE/SINK TO MODULE
 ID.
       38
             DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT 8
                                                                    CARCL2
 KBAS
       38
       38
                                  DUMMY COMPONENT PROVIDING COOLN'T FLO TO CARCL2
 NSTR
 VARY
               100.
       38
                            COOLANT FLOWRATE (LB/HR)
VARY
      38
            2 100.
                           TEMP_
                                                                      (F)
                20.
 VARY
       38
                            PRESS
                                                                      (PSI)
 VARY
       38
                20.
                            PRESS
                                                                      (PS1)
             CONDENSOR SEPARATOR SIMULATED BY ANYHX COZZHZO SEPARATION
 IDea.
      9
 KBAS
                                               -39 0
            211000100
                                  LIQ.BAS HX WITH PRI OUT TEMP CRITERIA FOR SIZ
 NSTR
VARY 9 66 1,5
                          OVERALL UA
                                                                      RTU/HR-P
 VARY
        9
          74
                5,0
                            NTU (MAX)
          75
                            DESIGN OUTLET TEMP PRI SIDE
 VARY
                                                                      (F)
 VARY
                            TOLERANCE FOR PRI SIDE TEMP
 ID.
       39
              DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT
       39
 KBAS
              49
                             .39
             20.0
 VARY .
                           COOLANT PLOWRATE
                                                                      (LS/HR)
                40.0
 VARY
       39
                            TEMP OF COOLANT
                                                                      (F)
       39
            3
                20.
 VARY
                            PRESSURE
                                                                      (PSIA)
VARY
       30
                            PRESSURE
 ID.
       10
              CONDENSOR SEPARATOR SIMULATED BY ANYHX 02/H20 SEPARATION
                                                -40 0
 KHAS
       10
                           LIGGAS HX WITH PRI OUT TEMP CRITERIA FOR SIZW
NSTR
      10
             211000100
 ARY
       10
         66
                3.0
                            OVERALL UA
                                                                      (BTU/HREF)
 VARY
       10
          74
                6.0
                           NTN(MAX)
3 VARY
      10
          75
                           DESIGN OUTLET TEMP PRI SIDE
                           TOLERANCE FOR PRI SIDE TEMP
 VARY
      10
          76
              5.
              DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT 10 HX
 ID:
       40
Z KBAS 40
```

```
FLOWRATE
Temperature:
VARY
      40
               10.0
                                                                  (L2/HR)
      40
           2
VARY
               40.0
                                                                  (F)
YARY.
      40
               20.0
                          PRESSURE
                                                                 PSI
  ARY
      40
              20.0
                          PRESSURE
 TD:*
      20
             COMPRESSOR SIMULATED BY FAN FOR STORING CO2 INTO THE RESERVOIR
KBAS 20
           25____
                                                                  21
NSTR
                            CO2 COMPRESSOR FOR CO2 ACCU, ADD HEAT ONLY.
      20
             CO2 RESERVOIR SIMULATED BY TANKS
1D.
      21
                 20 2
KBAS
            30_
NSTR
      21
           1100
             70.0
      21
          54
                     AMBIENT GAS TEMP
VARY
                         THERMAL CONDUCTANCE BETWEEN SURFACE/AMBNY (BTU/HRAF)
              05
VARY
      21
          55
              6.0
VARY
      21
          37
                          AMBIENT WALL TEMP
                                                                  (F)
              6.0
VARY
      21
                                                                  (FTSQ)
          58
                          RADIATION PA FACTOR
               60, ...
VARY
                         STRUCTURE TEMP.
                                                 60
      21
              2,2
                          CONDUCTANCE BETWEEN THE WALL AND STRUCT. (BTN/HR-F)
VARY
          61
                        TOTAL WEIGHT IN THE COS
      21
              0.076
VARY
          67
                                                                  (LBS)
VARY 21 68 80.0
                                                                  (F)
VARY
      21
          69
              1,0
                          VOLUME
                                                                  FTCUB ..
VARY
      21
              10.0
          70
                          CO2 PRESS
                                                                  PSIA
                         WEIGHT OF NON CONDENSABLES IN THK (LB)
VARY.
               076
                       SPECIFIC HEAT
               ,205
      21
          74.
VARY
                                                                 BTJ/LB-F
VARY
      21
          75
                          MOLECULAR WEIGHT OF CO2
               44,
                                                                 LB/MOLE
              2.5 THERMAL CAPACITANCE OF THE SHELL
CONDUCTANCE BETWEEN FLUID AND HALL
VARY 21
          78 ..... 1076
                                                                 LB .
VARY
      21
          90
                                                                 (BTU/F)
VARY
      21
          92
                                                                 (BTU/HRef)
             COMPRESSOR FOR STORING THE O2 INTO THE O2 RESERVOIR
KBAS
      22
             23
                         10 2
      22
 LSTR
                                OZ COMPRESSOR FOR OZ ACCU ADD HEAT ONLY,
 D . ..
      23
             OZ RESERVOIR SIMULATED BY TANKS
KHAS
      23
             30
                         22 2
NSTR
      23
            1100
VARY
      23
                          AMBIENT GAS TEMP
              60
                          THERMAL CONDUCTANCE BETWEEN SURFACE/AMBNT (BTU/HR-F)
VARY
      23
          55
                           AMBIENT WALL TEMP (F)
VARY
      23
          57
VARY
      23 58 6.0
                       RADIATION PA FACTOR
                                                                  (FTSQ)
          60 60. STRUCTURE TEMP, (F)
61 2.2 CONDUCTANCE BETWEEN THE WALL AND STRUCT, (BTN/HR#F)
 VARY
      23
 VARY
      23
               -0555
VARY
      23
                          TOTAL WEIGHT IN THE 02
 VARY
      23
                        02 TEMP IN THK.
          68
             80.0
                                                                  (F)
      23
 VARY
          69
              1.0
                           VOLUME.
                                                                  FTCUB
      23 70
VARY
                        - 02 PRESS
             10.0
                                                                  PSIA
                .0555 WEIGHT OF NON CONDENSABLES IN THK
 VARY
      23
          71
                                                                 (LB)
 VARY
      23
                .217
                          SPECIFIC HEAT
                                                                  BTU/LB-F
                                                          _____LB/MOLE
      23
                          MOLECULAR WEIGHT OF 02
VARY
                        WEIGHT OF DR IN THE
THERMAL CAPACITANCE OF THE SHELL
               .0555
 VARY
      23
          76
                                                                 LB
              2.5 THERMAL CAPACITANCE OF THE SHELL
CONDUCTANCE BETWEEN FLUID AND WALL
                                                                 (BTU/F)
      23
 VARY
          90
VARY 23
        ...92...
                                                                  (BTU/HRef)
             H20 COLLECTOR FOR CONDENSATE THAT MAY BE FORMED
 ID.
      16
      16
             12
 KBAS-
                           Ô
5 KARY
      کد
                           COND
                         CONDENSATE FROM HUMIDITY CONTROLLER
 KARY
      16
          17
          18
 KARY
      16
                           CONDENSATE FROM CO2/H20 SEPARATOR
4 KARY 16 19
               D . .
             PUMP FORCING CONDENSATE INTO HEO RESERVOIR
      17
      17
 KBAS
             22
                         16 0 2
                               ADD HEAT TO FLUID STREAM NO OP OR PERFRHNC CAL
3 NSTR
            0002
            HZO RESERVOIR SIMULATED BY TANKS
 ID .
      18
      18
                                                                    2
 KBAS
             30
                   17 0 2
            1200
2 NSTR 18
```

NAME	VARY VARY	18 18 18	54 55 57	70,		AMBIENT GAS TEMP. THERMAL CONDUCTANCE BETWEEN SURFAC AND AMBIBTU/HR-P) AMBIENT WALL TEMP. (F)
VARY 18 67 62.4 TOTAL FLUID WEIGT IN INK (LEVARY 18 68 60. FLUID TEMP. IN INK (FRUID VOLUME IN INK (PSI) VARY 18 69 1. FLUID VOLUME IN INK (PSI) VARY 18 70 62.4 WEIGHT OF LIQUID IN INK (LB) VARY 18 80 1.0 SPECIFIC MEAT (BTU/LB) VARY 18 90 2.5 THERMAL CAPACITANCE OF TNK SMELL (BTU/LB) PLOT 7 21 0. 100. PER CENT CO2 IN ANODE GAS = STAGE 1 PLOT 2 12 CO2. NPROCESS GAS TO SUBSYSTEM LB/HR PLOT 4 12 CO2 in PROCESS GAS LEAVING SUBSYSTEM LB/HR PLOT 4 24 CO2 * O2 GAS LEAVING ANODE STAGE 1 LB/HR PLOT 7 22 CO2 * O2 GAS LEAVING CATHODE STAGE 1 LB/HR PLOT 8 12 CO2 * PROM STAGE2 CATHODE TO CO2 RES. LB/HR PLOT 8 29 O2 FROM STAGE2 NODE TO C2 RES. LB/HR PLOT 8 29 O2 FROM STAGE2 ANODE TO C2 RESRVR. LB/HR PLOT 22 6 H20 IN C2 TO CQ2 TANK LB/HR PLOT 22 6 H20 IN C2 TO CQ2 TANK LB/HR PLOT 32 6 H20 IN C2 TO CQ2 TANK LB/HR PLOT 32 6 H20 IN C2 TO CQ2 TANK LB/HR PLO	VARY	18	58 60	6,		RADIATION FA FACTOR (FTSQ) STRUCTURE: TEMP. (F)
VARY 18 70 14.7 PRESSURE IN INK (PSI) VARY 18 72 62.4 WEIGHT OF LIQUID IN INK (LB) (BTU/LB-F VARY 18 86 1.0 SPECIFIC HEAT (BTU/LB-F VARY 18 90 2.5 THERMAL CAPACITANCE OF TNK SHELL (BTU/LB-F PLOT 7 20 0. 100. PER CENT CO2 IN ANODE GAS - STAGE 1 PLOT 2 12 CO2 IN PROCESS GAS TO SUBSYSTEM LB/HR PLOT 4 12 CO2 IN PROCESS GAS LEAVING SUBSYSTEM LB/HR PLOT 4 24 CO2 + 02 GAS LEAVING CATHODE STAGE 1 LB/HR PLOT 7 22 CO2 + 02 GAS LEAVING CATHODE STAGE 1 LB/HR PLOT 8 12 CO2 FROM STAGE2 CATHODE TO CO2 RES. LB/HR PLOT 8 29 O2 FROM STAGE2 ANODE TO 02 RESRVR. LB/HR PLOT 8 29 O2 FROM STAGE2 ANODE TO 02 RESRVR. LB/HR PLOT 20 6 H20 IN 02 TO CO2 TANK LB/HR PLOT 22 6 H20 IN 02 TO 02 TANK LB/HR PLOT 22 6 H20 IN 02 TO 02 TANK LB/HR PLOT 18 1 H20 FROM WATER SUPPLY LB/HR	VARY VARY	18	67 68	60,		TOTAL FLUID WEIGT IN INK (LB) FLUID TEMP IN INK (F)
VARY 18 90 2.5 THERMAL CAPACITANCE OF TNK SMELL (BTU/LB) PLOT 7 20 0. 100. PER CENT CO2 IN ANODE GAS = STAGE 1 PLOT 7 21 0. 100. PER CENT CO2 IN CATHODE GAS = STAGE 1 PLOT 2 12 CO2 IN PROCESS GAS TO SUBSYSTEM LB/HR PLOT 4 12 CO2 IN PROCESS GAS LEAVING SUBSYSTEM LB/HR PLOT 7 22 CO2 • 02 GAS LEAVING ANODE STAGE 1 LB/HR PLOT 7 22 CO2 • 02 GAS LEAVING CATHODE STAGE 1 LB/HR PLOT 8 12 CO2 FROM STAGE2 CATHODE TO CO2 RES. LB/HR PLOT 8 29 O2 FROM STAGE2 ANODE TO 02 RESRVR. LB/HR PLOT 20 6 H20 IN CO2 TO CO2 TANK LB/HR PLOT 22 6 H20 IN CO2 TO CO2 TANK LB/HR PLOT 18 1 H20 FROM WATER SUPPLY LB/HR ENDC	VARY	18	70 72	14:7 62:4		PRESSURE IN INK (PSI) WEIGHT OF LIQUID IN INK (LB)
PLOT 2 12 PLOT 4 12 PLOT 4 12 PLOT 5 22 PLOT 7 22 PLOT 8 12 PLOT 8 29 PLOT 8 29 PLOT 8 29 PLOT 20 PLO	VARY PLOT			215	0.	THERMAL CAPACITANCE OF THE SHELL (BTU/LB) 100, PER CENT CO2 IN ANODE GAS - STAGE 1
PLOT 7 22 PLOT 8 12 PLOT 8 12 PLOT 8 29 PLOT 20 6 PLOT 22 6 PLOT 18 1	PLOT		2 4	12 12	•	CO2 IN PROCESS GAS TO SUBSYSTEM LB/HR CO2 in process gas leaving subsystem lb/Hr
PLOT 8 29 C2 FROM STAGE2 ANODE TO 02 RESRVR, LB/HF PLOT 20 6 M20 IN CO2 TO CO2 TANK LB/HR PLOT 22 6 H20 IN O2 TO 02 TANK LB/HR PLOT 18 1 H20 FROM WATER SUPPLY LB/HR ENDC	PLOT		8 3		· page and the state garage	CO2 + O2 GAS LEAVING CATHODE STAGE 1 LB/HR
PLOT 18 1 H20 FROM WATER SUPPLY LB/HR ENDC	PLOT PLOT		20	29 6 6		D2 FROM STAGE2 ANODE TO D2 RESRVR. LB/HR H20 in cO2 to CO2 tank Lb/HR
	PLOT			1		

```
TAPE
BASIC
                                                             NAY
             HYRDROGEN DEPOLARIZED CELL SAMPLE PROBLEM
CASE.
 CASE1
      KCHOUT=0, KPRNTH 6, KPTINV(1)=006, KRUNH1,
       TMIN==460., TMAX#4000., WTMAX#10000.,
       DTIMES10., STARTEO, TIMEMX $1200. MAXSSIN4,
       MAXSLP=1.
       MINSSIES S
 SPROP1
      CPCQ2=.197, CPDILE.24, VISGAS*,045, WTMTC=16., CPTC=1., XKGAS*,0147, WTMCIL=28., WTMCON*18., CPCONV*,44,
       CPCONLEI. CPOXY : . 22.
       CP(1)=1, RHD(1)=62,4, VISC(1)= 2,22 ,WTM(1)=18,, XK(1)=.350 ,
CP(2)=3,41, RHO(2)=.0052, VISC(2)=.0216, WTM(2)=2., XK(2)=.106 S
               SOURCE OF CABIN AIR FLOW
ID.
KBAS
VARY
       01
           01 1085.5
                             TOTAL PLOW TO SUBSYSTEM
                                                                     (LB/HR)
VARY
       01
           02 75.
                                TEMPERATURE
                                                                     (F)
           03 14.7
VARY
       01
                                PRESSURE
                                                                     (PSIA)
VARY
           04 14 7
       01
                                PRESSURE
                                                                     .(AI89)..
           05 989.97
VARY
       01
                                NON- CONDENSABLES
                                                                     (LB/HR)
           06 9.4
VARY
       01
                                H20
                                                                     (LB/HR)
VARY.
       01...
          10 228.
                              ... 02... ..
                                                                     (LB/HR)
VÂRY
       01
           11 756.
                                                                     (LB/HR)
                                N2
           12 5.973
VARY
                                COZ
       01
                                                                     (LB/HR)
       01
                                TRACE CONTAMINATES
VARY
           13 .0001
                                                                     -(LB/HR)
               HUMIDITY CONTROL HEAT EXCHANGER
I Do o
 STR
        2
              0110001
  2AS
                                                     -11 0 -1
             3.
VARY
        2
           66 50.
                                OVERALL UA
                                                                     (BTU/HR-F)
VARY
           67 .95
                                EFFECTIVENESS
                                                                      (DIM)
```

```
VARY
                                                               (F)
           75 40.
                              DESIGN TEMPERATURE
              SUBSYSTEM BLOWER
 ID:
KBYS
              23____
  BTR
               3
 VARY
           91 20.
                             HEAT DISS, INTO GAS
                                                               (WATTS)
            BYPASS VALVE ---- ---
__!D**
 KHAS
                            3 3
                                                    . 3
                                                                            8
 NSTR
                         SPLIT RATIO
 VARY
           65 0.00001
 ID:
        5
              HYRDROGEN DEPOLARIZED CELL MODULE
        5
 KBAS
                             4 3
KARY
           16
 KARY
        5
           17
 KARY
           18
                        3
KARY
           19
        5
 KARY
           20
        5
 KARY
           21
KARY
           22
           65 3.0
 VARY
                              MAXIMUM CO2 PARTIAL PRESSURE CABIN(MM HG)
                              CELL TEMPERATURE AT TIME ZERO
 VARY
           66 62.0
                                                              . (F)
           67 52.0
VARY
                              LOWEST AIR TEMP, FOR OPERATION (F)
           68 14.7
                              MAXIMUM AIR PRESSURE FOR OPERAT, (F)
 VARY
 VARY
           69 200.
                              MAXIMUM AIR FLOW FOR OPERATION
                                                               (CFM)
          70.7.925
VARY
                              MAXIMUM AIR WATER VAPOR PP
                                                               (MM HG)
 VARY
           71 0.5
                              CELL LENGTH
                                                               (FT)
           72 54.
                              TOTAL WIDTH OF ALL CELLS
 VARY
                                                               (FT)
 VARY
           73
              0.2
                              AIR CHANNEL DIMENSION
                                                               (INCHES)
           74 0.05
                              CURRENT COLLECTOR WIDTH
        5
 VARY
                                                               (INCHES)
           75 25.
 LARY
        5
                              ELECTRODE SPACING
                                                               (MILS)
                              MATRIX THICKNESS BEFORE COMP.
 ARY
           76 60.
                                                               (MILS)
                              MATRIX VOID VOLUME FRACTION
 VARY
           77 0.70
                                                              (DIM)
                              TOTAL MASS OF CELL STACK
        5
 VARY
           78 111.
                                                               (LB)
           79 .125
 VARY
                             AVERAGE OF CELL STACK
                                                               (BYU/LB=F)
 VARY
        5 80 6.1
                              AVAILABLE BPONGE VOL. OF MATRIX (ML/SQ FT)
 VÄRY
        5
          129 1
!Das
              GAS MIX
                                                                            7
 KBAS
              6
                             5 3
 NSTR
 10**
 KBAS
             11
                             6 3
                                                                           10
 NSTR
            3
 VARY....
           77. . 4.01.
                              (1. REMOVAL EFFICIENCY)
                                                               (DIM)
 VARY
           78
              H2 STORAGE TANK
 ID*+
 KBAS
              30_
 NSTR
        8
             0210
           54 75.
                              AMBIENT TEMPERATURE
                                                              (F)
 VARY
VARY
           55 2,
                              UA TO SURROUNDINGE
                                                               (BTU/HR=F)
 VARY
           67 0,014
                              INITIAL MASSITOTALS
                                                               (F8)
           69 2.
 VARY
                              TANK VOLUME:
                                                               (CU FT)
           70 20.
5 VARY
                              INITIAL PRESSURE
                                                               (PSIA)
                              INITIAL MASS(NON- CONDENSABLES) (LB)
           71 0.014
 VARY
           75 2.
 VARY
        8
                              MOLECULAR WEIGHT
                                                               (LB/LB MOLE)
                              INITIAL MASS H2
4.VARY 8. 80.0.014
                                                               (LB)
ARY
           68 75.
                              INITIAL TEMPERATURE
                                                               (F.)
 70 **
        9
              FILTER
KBAS
 NSTR
        9 .
             3
           77 ,01
 VARY
                              (1. REMOVAL EFFICIENCY)
                                                               (DIM)
        9 78
VARY.
```

```
1Da+
      10
            CO2/H2 ACCUMULATOR TANK
      10
           30 -5 3
 KBAS
                                                             2
 ALSTR
      10
0210
                                                 (BTU/HR=F)
     10 71 0.076 INITIAL MASS(NON CONDENSABLES) (LB)
10 75 2. MOLECULAR: WEIGHT (LB/LB MOLE)
10 78 0.062 INITIAL MASS CO2 (LB)
10 80 0.014 INITIAL MASS H2 (LB)
 VARY
 VARY
VARY
 VARY
        SOURCE OF COOLANT
 1D.
      11
          1 150. TOTAL PLOW
 KBAS
      11
VARY 11 01 150. TOTAL FLOW
VARY 11 02 40. TEMPERATURE
VARY 11 03 14.7 PRESSURE
VARY 11 04 14.7 PRESSURE
1D++ 12 SOURCE OF HYDROGEN
KHAS 12 49 3 2
                                                   (LB/HR)
                                                   (F)
                                                   (PSIA)
                                                   (PSIA)
(F)
(PSIA)
05 0.182 NON= CONDENSABLES (LB/HR)
06 0.0001 WATER VAPOR (LB/HD)
13 :001
14 0.182
 VARY
      12
12
 VARY
```

```
VALU 3 14 3D 60, .173 .201 .196 .136 .128

VALU 3 15 3D 65, .183 .212 .206 .146 .138

VALU 3 16 3D 70, .192 .222 .2170 .156 .138

LU 3 17 3D 75, .202 .233 .227 .167 .147

VALU 3 18 3D 80, .211 .243 .238 .177 .144

VALU 3 19 3D 85, .221 .253 .248 .187 .154

TABL 4 1 2 7 LIN LIN

TITL 4 2 ELECTROLYTE CONCEN.(HT PER CENT) VS. MOLARITY(GMOLES/LITER)
        4 10 21 1.0 2.0 3.0 4.0 5.0 69.5 74.5
 VALU
                                                                                         69.5 74.5
 VALU
            4 12 21 7.
 VALU
VALU 4 13 2D 79.
           5 1 2 7 LIN LIN
5 2 ELECTROLYTE MOLARITY (GMOES/LITER) VS. CONCEN. (WT PER CENT)
 TABL
 TITL
 VALU
            5 10 21 20, 50, 40, 50, 60, 70,
                                                  1.87 2.60 3.6 5.05
           5 11 20 ,7
 VALU 5 11 20 .7
VALU 5 12 21 80.
                                       1.25
 VALU 5 13 2D 7-18
                                          9 LIN LIN
 TABL 6 1 2 9 LIN LIN LIN TITL 6 2 ELECTROLYTE SP. VOL(CM++3/QRAM) VS. CONCEN.(WT PER CENT)
VALU 6 10 21 40. 45. 50. 55. 60. 65.

VALU 6 11 2D 1.667 1.4 1.176 .994 .847 .713

VALU 6 12 21 70. 75. 8D.

VALU 6 13 2D .606 .513 .45

TABL 7 1 2 10 LOG LOG

TITL 7 2 REYNOLDS FACTOR VERSUS FRICTION FACTOR
            7 10 21 5.3 B=2 9.65 E=2 1.413 E=1 2.605 E=1 3.4 E=1 4.61 E=1
 VALU
           7 11 2D 2.08 E-4 8.3 E-4 1.805 E-3 5.35 E-3 8.38 E-3 1.373 E-2 7 12 21 5.47 F-1 6.59 E-1 1.028 1.538
 VALU
  MALU
          7 13 20 1.788 E=2 2.368 E=2 4.488 E=2 7.6 E=2
 ALU...
 PLOT 5 128 0. 1. CO2 REMOVAL RATE (LB/HR)
PLOT 5 87 0. 1000. TOTAL CURRENT (AMPS)
PLOT 5 85 0. 100. AVERAGE CELL TEMPERATURE
                                                         AVERAGE CELL TEMPERATURE(F)
PLOT 5 98 0. 5. CO2 IN AIR LEAVING CELL (MM HG)
PLOT 5 99 0. 20. H20 IN AIR LEAVING CELL (MM HG)
RLOT 5 115 CATHOLYTE CONCENTRATION (WT PERCENT)
PLOT 5 111 0. 2000. HEAT GENERATED IN STACK (BTU/HR)
PLOT 5 110 0. .5 CELL VOLTAGE (VOLTS)
PLOT 5 94 0. 500. H2 PARTIAL PRESSURE EXIT H2 STREAM (M
                                                         HE PARTIAL PRESSURE EXIT HE STREAM(MM HG)
            5 95 0. 100. CO2 PARTIAL PRESSURE EXIT H2 STM(MM HG)
5 96 0. 50. H20 PARTIAL PRESSURE EXIT H2 STM(MM HG)
 PLOT
 PLOT
 ENDC ...
 ENDR
```

```
D-20
 .INSERT, GPOLY2, 21
                      +SOLID ELECTROLYTE+++
       IF( N,NE,8) RETURN
CALL SV( R(14), 13,14 )
CALL SV( R(01), 13, 1 )
      CALL SV( R(05), 13, 5 )
 BASIC
                                                             NAY .
              SOLID ELECTROLYTE CO2 REDUCTION CONCEPT
CARE
  SCASE1
       KCHOUT#0, KPRNT#806, KPTINV(1)#006, KRUN#1,
       TMIN=460. TMAX#2000. WTMAX#10000.
       DTIME#10., STARTED., TIMEMX#1200., MAXSBIR 5.
       MAXSLP=3.
       MINSSI=4 S
  SPROP1
```

```
CPCO2m.197, CPDILm.22, VISGASm, 045, WTMTCp16., XKGASm, 0147, WTMDILm28., WTMCONm18., CPCONVm.44,
       CPCONL =1... CPOXY :. 22.
       CP(1) = 3.51, RHO(1) = 0.0019, VISC(1) = 0.0416, XK(1) = 0,208, WTM(1) = 2., CP(2) = .2730, RHO(2) = 0.0263, VISC(2) = 0.084, XK(2) = .0322, WTM(2) = 44., S
I Das
              CO2 FEED PANK (ACCUMULATOR)
 NSTR
             0210
 KBAS
              30
                                                                            2
VARY
       01
              75.
                            AMBIENT GAS TEMPERATURE
           55 2.0
 VARY
       01
                              UA INSUL SURFACE/AMBIENT
                                                                (BTU/HR=F)
 VARY
       01
           64 0.
                             INSULATION CONDUCTANCE
                                                                (BTU/HR=F)
       01 69 2.
                           ---TANK-VOLUME: -----
VARY
                                                                (CU FT)
 VARY
       1
           68 75.
 VARY
           78 1.
                              FRACTION COZ IN TANK
 VÄRY
           70 14.7
              SUBSYSTEM BLOWER
 IDe:
              23
 KBAS
        2
                                                                            3
                            1 2
 NSTR.
             :003
 VARY
        2
           91 2.0
                              BLOWER HEAT DISSIPATION
                                                               (WATTS)
 ID:
              HUMIDIFIER
NSTR
              6
                                                   -12 2
 KBAS
                             2 2
 IDee
              GAS MIX
NSTR
                             3 3
 KBAS
              SOLID ELECTROLYTE CELLS
 ID.
             00
 NSTR
        5
                                                   -13 3
 KBAS
             51
                        Ť
        5 16
                              NUMBER CELLS/STACK
 KARY
 RY
        5 17
                             NUMBER STACKS/MODULE
 KARY
           18
                       A
                              NUMBER MODULES/UNIT
           51 1652,
 VARY
                              SHELL TEMPERATURE
           54 75.
 VARY
                              AMBIENT TEMPERATURE
                                                               (F)___
           55 2,1
 VARY
                              UA INSUL. SURFACE TO AMBIENT
                                                               (BTU/HROF)
           57 75,
        5
 VARY
                              AMBIENT WALL TEMPERATURE
                                                               (F)
VARY
                              SORIPT FAINSULATION SURFACE TO WALL
 VARY
           64 0,222
                             INSULATION CONDUCTANCE
                                                               (BTU/HROF)
           65 500.
 VARY.
                              HEATER DISSIPATION
                                                              (BTU/HR)
           67 135,
 VARY
                              TOTAL CURRENT TO UNIT
                                                              (AMPS)
           72 0.81
                              O2 CURRENT EFFICIENCY
H2 CURRENT EFFICIENCY
 VARY
                                                               (FRACTION)
 VARY
           74 0,175
                                                               (FRACTION)
        5 76 0.614
                            CELL VOLTAGE EFFICIENCY
VARY
                                                               (VOLTS)
 VARY
                              CONVERGENCE TOLERANCE
                                                               (PERCENT)
           80 0.01
                              MOLULE THERMAL CAPACITANCE
 VARY
           81 4.0
                                                               (BTU/F)
                              INITIAL TEMPERATURE (TRANSIENT) (F)
 VARY
        6
              02 ACCUMULATOR
 ID**
             0210
 NSTR
 KBAS
        --5-3--1-2---
           54 75,
                                                              (F)
 VARY
       06
                          AMBIENT GAS TEMPERATURE
           55 2.
       06
 VARY
                              UA INSUL, SURFACE/AMBIENT
                              INSULATION CONDUCTANCE
VARY
       06
           44
                                                               ---(-BTU/HR=F)
           69 2,
       06
 VARY
                              TANK VOLUME
                                                                (CU FT)
       6 68 75.
 VARY
       6 70 14,7
4 VARY
       06 78 1.
  MRY
                              FRACTION OR IN TANK
      7 .
              HYDROGEN SEPARATOR
 TD . .
3 NSTR
       7
 KBAS
                                                   e13 3
        7
           16
                             NUMBER OF H2 SEPARATION CELLS
 KARY
                            - AMBIENT GAS TEMPERATURE
```

```
55 0.1
VARY
                              UA INSULA SURA TO SURROUNDINGS.
                                                               (BTU/HR-F)
                              AMBIENT WALL TEMPERATURE
VARY
        7
           57 75.
                                                               (F)
VARY
                              SORIPT FA AMBIENT WALL/INSUL.SURFACE
           64 0.1
                              INSULATION: CONDUCTANCE
                                                               (BTU/HR-F)
VARY
           65 1,48
                              MEMBRANE AREA
                                                               (SO FT)
          66 .005
VARY
                              MEMBRANE THICKNESS
                                                               (INCHES)
VARY
           77.1.
VÄRY
           71 5.18
                     E-&
                              H2 PERMEABILITY(CU FT/HR)(INCHES)/(SQ FT-MMHG)
                              UA CELL/WALL(PRIMARY SIDE) (BYU/HR-F)
VARY
           91 1
           92 1.
                              UA CELL/WALL(SECONDARY SIDE)
VARY
                                                               (BTU/HROF)
VARY
           93 100.
                              UA ACROSS MEMBRANE
                                                               (BTU/HR-F)
                                                               (FT)
VARY
          103 0,667
                              CELL LENGTH
                              CELL FRONTAL AREA(PRIMARY SIDE) (SO FT)
VARY
          104 0.2
VARY
          105 1,
                             CELL FRONTAL AREA(SECONDARY SIDE)(SQ FT)
                     Ens
VARY
          106
                              MODULE THERMAL CADACITANCE (BYU/F)
                              DT MULTIPLYING FACTOR
VARY
        7 107 0.9
          108 0,1
VARY
                              MINIMUM ALLOWABLE COMPUTING INT. (F)
I Dan
      A VACUUM PUMP
NSTR
        8
             10
 KBAS
              38
                            -7 3 1 2
VARY
           75 20.
                             DISCHARGE PRESSURE
VARY
        8
           66 0,60
                              MOTOR EFFICIENCY
                                                               (DIM)
                              ABRODYNAMIC EFFICIENCY
           67 0.40
 VARY
                                                               (DIM)
          71 0.
VARY
                              FRACTION O LOST TO AMBIENT
                                                               (DIM)
                              TABLE FOR VACUUM PUMP FLOW
 KARY
           HE ACCUMULATOR
 1.D. .
NSTR
             0210
 KBAS
        9
                             8 3
                                                                           10
              30
 YARY
           54 75.
       09
                              AMBIENT GAS TEMPERATURE
                                                                (F)
   Y.
       0.9
         ... 55. 2.....
                             -UA INSUL, SURFACE/AMBIENT
                                                               (STU/HR-F)
 VÁRY
       09
           64 0.5
                              INSULATION CONDUCTANCE
                                                               (BTU/HROF)
       9
 VARY
           68 75.
       00
 VARY
           49
              2.
                             TANK VOLUME
           70 14.7
 VARY
        9
 VARY
       09
           80 1,
                              FRACTION H2 IN TANK
       10
              CARBON DEPOSITION REACTOR
1Dan
 NSTR
       10
 KBAS
       10
              50
                             7 3
                                  1 2
                                                                           11.
VARY
       40
              986
                              TEMPERATURE
           54 75.
                              AMBIENT GAS TEMPERATURE
                                                                (F)
 VARY
       10
 VARY
       10
                              UA INSULATION/SURROUNDINGS
           55
              3.0
                                                                (BTU/HR=F)
VARY
       10
           57 75.
                              AMBIENT WALL TEMPERATURE
                                                                (F)
           58 0.6
 VARY
       10
                              SCRIPT F INSULATION/WALL
                                                                (SG FT)
              4,56
 VARY
       10
           64
                              INSULATION CONDUCTANCE
                                                                (BTU/HR=F)
              1000.
                              ELECTRICAL HEATER DISSIPATION
VARY
       10
                                                               (BTU/HR)
           67 .212
       10
 VARY
                              CO CONVERSION
                                                                (FRACTION)
 VARY
       10
           68 0.0
                              H2 CONVERSION
                                                                (FRACTION)
 VARY
     10
           71 .01
                             CONVERGENCE TOLERANCE
                                                                 (PERCENT)
 VARY
       10
           74 986
                              INITIAL TEMPERATURE
                                                                (F)
           73 2.
       10
                              TOTAL THERMAL CAPACITANCE
                                                                 (BTU/F)
 VARY
              RECYLE BLOWER
5 IDee
 KBAS
       11
             23
                            10 3
                                   1 2
                                                                            1
 NSTR
       11
             003.
VARY
         01 7.6616
                              RECYCLE PLON(TOTAL)
       11
                                                                  (LB/HR)
           02 986
   RY
       11
                                      TEMPERATURE
                                                                  (F)
 VARY
       11
           03 14.2
                                      PRESSURE
                                                                  (PSIA)
JVARY
       11
           04 14 2
                                      PRESSURE
                                                                  (PSIA)
       11
           06 .0595
 VARY
                                      WATER VAPOR
                                                                  (LB/HR)
 VARY
       11
           07
                                      LIQUID WATER
                                                                  (LB/HR)
           10
2 VARY
                                      OXYGEN....
                                                                  (LB/HR)
```

```
NITROGEN
  VARY
              11
                      11
                                                                                                                             (LB/HR)
            11 12 4,92
  VARY
                                                                         CD2
                                                                                                                           (LB/HR)
                                                                       TRACE CONTAMINATES (LE/HR)
                    11 14 0.0221 H2 (LB/HR
11 15 2.66 CO (LB/HR
11 91 60, RECYCLE BLOWER HEAT DISSIPATION (WATTS)
                                                                                                                           (LB/HR)
   VARY
                                                                                                                           (LB/HR)
 VARY
                            WATER FEED TANK
            12
   IDas
  KBAS
              12
                            49.
                      01 0.1232 WATER FLOW TO HUMIDIFIER (LB/HR)
 _VARY
 VARY 12 02 75. TEMP. FLOW TO HUMIDIFIER (F)
VARY 12 03 14.7 PRESSURE FLOW TO HUMIDIFIER (PS
VARY 12 04 14.7 PRESSURE FLOW TO HUMIDIFIER (PS
                                                                                                                          (PSIA)
                                                                                                                           (PSIA)
                     05 .0001
   VARY
              12
   VARY 12
                      06 .0001
                      07 0.1230 WATER FLOW TO HUMIDIFIER (LB/HR)
  VARY
  ID++ 13 DUMMY COMPONENT
KBAS 13 49 3 1 2
VARY 13 01 0.0136 FLOW HYDROGEN TO ACCUMULATOR
              13 02
   VARY
              13 03 14,7
   VARY
  VARY
              13
  VARY 13 05 0.0136
VARY 13 08 3.4
VARY 13 09 2.
                     14 0.0136
   VARY
              13
                            SOURCE OF CO2(FROM CONCENTRATOR)
   ID:
              14
                          40 2
  KBAS.
  VARY 14 01 54204 TOTAL FLOW TO SUBSYSTEM (LB/HR)

RY 14 02 75. TEMPERATURE (F)

RY 14 03 14.22 PRESSURE (PSIA)
                                            PRESSURE
              14
              14 04 14,22 PRESSURE (PSIA)
14 05 54203 FLOW NON-CONDENSABLES (LB/HR)
14 06 00001 FLOW WATER VAPOR (LB/HR)
                   04 14.22
   VARY
   VARY
                    06 00001
   VARY
VARY 14 07 FLOW ENTRAINED WATER (LB/HR)
VARY 14 10 .00001 FLOW OXYGEN (LB/HR)
VARY 14 11 .00001 FLOW NITROGEN (LB/HR)

    VARY 14 12 542
    FLOW CO2
    (LB/HR)

    VARY 14 13 00001
    FLOW TRACE CONTAMINATES
    (LB/HR)

    TABL 1 1 3
    10 4 LOG LOG LIN

TABL 1 1 3 10 4 LOG LOG LIN

TITL 1 2 VACUUM PUMP FLOW CHARACTERISTICS (SMALL PUMPS)

VALU 1 11 31 7. 14.7 30. 50.

VALU 1 12 3D 1. 1.6 1.8 1.9 1.95

VALU 1 13 3D 2. 1.55 1.79 1.89 1.94

VALU 1 14 3D 5. 1.3 1.65 1.86 1.92

VALU 1 15 3D 7. 1.15 1.52 1.85 1.90

VALU 1 16 3D 10. 1.0 1.40 1.75 1.85

VALU 1 17 3D 20. 0.62 1.08 1.45 1.65

VALU 1 18 3D 42. 0.00001 0.65 0.94 1.2

VALU 1 19 3D 100. 0.00001 0.00001 0.16 0.9

VALU 1 20 3D 130. 0.00001 0.00001 0.00001

PLOT 14 12 0. 1.00001 0.00001 0.00001

      PLOT
      14
      12
      0
      1
      CO2 FLOW TO SUBSYSTEM(LB/HR)

      PLOT
      5
      29
      0
      1
      02 FLOW TO ACCUMULATOR(LB/HR)

      BLOT
      12
      07
      0
      0
      5
      H20 FLOW TO SUBSYSTEM(LB/HR)

      DOT
      05
      51
      0
      1500
      CELL MODULE TEMPERATURE(F)

      PLOT
      10
      51
      0
      1500
      REACTOR TEMPERATURE(F)

      PLOT
      8
      14
      0
      0
      142 FLOW TO ACCUMULATOR(LB/HR)

 4.<u>Bl</u>07. ---
3 PLOT
   ENDC
```

ENDR

```
*I GPOLY1.24
                   *LIGUID ABSORPTION***
      IF(NPASS LT. 15 .OR. N .NE. 2) GO TO 100
      NPASSED
      PCO2NEVV(9.65)
      PCO2NAPCO2Na1.
      CALL SV(PCO2N,9,45)
  100 CONTINUE
      IF(N NE. 14) GO TO 14
      A(15)8A(1)
      R(1)=VV(9,72)
      R(15)=R(1)-
   14 CONTINUE
      IF(N NE. 8) GO TO 8
      R(65) = A(1) + CPA+(485 - A(2))
      R(66)#185
    B CONTINUE /
 el GPOLY2.21
      IF(N .NE, 4) GO TO 4
      DO 40 KK#24.33
    40 RIKKIBO.
    4 CONTINUE
      IF(N .NE. 16) GO TO 16
      R(3)=14.7
     R(4)=14,7
   16 CONTINUE
      IF(N NE. 18) GO TO 18
      R(3)=14.7
      R(4) #14.7
   18 CONTINUE
 TAPE
 BASIC
            COR CONCENTRATOR USING LIQUID ASSORPTION
CASS
 SCASE1
   KCHOUTEO, KPRNTE6, K#TINV(1)#15,MAXSLP#4; MINSSIE2, KRUN#1, DTIME#30.,
 ....TIMEMX=4050...MAXSSIe6. TMAX=250..TMIN==400...WTMAX=1.E4 S:
 SPROP1
  CPCONLa1., CPCONVEO.44, CPCO280.2, CPDILa0.25, CPOXY*0.22, CPTC#0.2.
              -CP(2)=,#39
                             CP(5)=1, CP(6)=,216 CP(7)=,28
 CP(1)=1---
                                           ,RHO(6)#142,8 ,RHO(7)#136.
                              RHO(5) #62.4
               RHO(2)=.16
 RHO(1)#62.4
                              , VISC(5) = 3.6
                                             , VISC(6) #3.6
               .VISC(2) ... 036
                                                            *VISC(7)#3.6/
 VISC(1)=3.6
                             WTM(5) 818.
 WTM(1)=18. WTM(2)=28.
                                            ..., WTM(6)#138.2
                                                            .WTM(7)#100.1
 XK(1)8.235
               XK(2)*.007
                              ,XK(5)#,325
                                             ,XK(6)=,65
                                                            .XK(7) F. 65
              VISGAS#0.44, WTMCON#18,, WTMDIL#28,, WTMTC#20,,
  GAMGAS=1.4.
                 WYMCONEIS.
  CPC02 = 178.
  XKGA5=0.146 5
            1 THIS COMPONENT DEFINES THE FLOW INTO THE COZ CONCENTRATOR SYSTEM US
 1Des
            2 THE LIQUID ABSORPTION CONCEPT
49
 KBAS
                                   DUMMY COMPONENT DEFINING INLET FLOW TO CO2 CNT
 NSTR
                             TOTAL FLOW
 VARY
            1 368,283
                                                                       FBYHR-
            2 70.
                             TEMPERATURE
                                                                       Ė
 VARY
                             UPSTREAM DUCT OUTLET PRESSURE
            3 14.7
                                                                       PSI
 VARY
                             COMPONENT OUTLET PRESSURE
          4.14.7.....
                                                                       PSI
VARY
                             NON-CONDENSABLE FLOW
            5 364,201
                                                                       LB/HR
            6 4,082
                             VAPOR FLOW
                                                                       L'B/HR
VARY
                             CONDENSABLE ENTRAINED LIGUID FLOW
                                                                      LB/HR
              ,24145
                             NON-CONDENBABLE SPECIFIC HEAT
       1
                                                                       BTU/LB=F
 VARY
            9 29.048
                             NON-CONDENSABLE MOLECULAR WEIGHT
 VARY
                                                                       LB5/MOLE:
VARY
        1 10 96,920
                             PXYGEN FLOW
                                                                      eC2/Q9
```

```
VARY
          11 265.08
                           DILUENT FLOW
                                                                     LB/HR
VARY
          12 2,201
                          CO2 FLO
                                                                     LB/HR
          13 0, ....
YEAV
                            TRACE CONTAMINANT FLOW
                                                                    LB/HR
                          SPECIAL FLOW NO. 1
                                                                     LB/HR
           1 BLOWER FORCING THE CABIN AIR THROUGH THE CO2 CONCENTRATOR
1 De a
KBAS
          NSTR
                                  ADD HEAT NO HEAD RISE OR FAN PERFORMANCE CHAR.
           1 LIQUID CONTACTOR SIMULATED BY SUBROUTINE LIGCON THE CO2 GAS IN THE
1 Das
!Dee
           2 STREAM IS REACTED WITH THE CARBONATE SOLUTION TO FORM BICARBONATE
KBAS
                                                         5 6 7
             52
                           2 3
                                   5 6 7
                                               w15 4
NSTR
                                  THE PROGRAM COMPUTES REQUIRED SECONDARY FLOWS
            01
          65 , 233333
VARY
                            REMOVAL EFFICIENCY OF THE ABSORBER TARGET.
VARY
          66 16
                            TARGET CO2 REMOVAL RATE
VARY
          67 .37
                            FRACTION OF BASE THAT IS BICARBONATE FLOWING IN
VARY
                            NORMILITY OF BARBONATE SOLUTION FLOWING IN
           1 LIQUID GAS SEPARATOR SIMULATED BY SUBROUTINE SPLIT SPECIAL FLOW COM
 I Due
           2 PONENTS ARE DIRECTED TO THE SECONDARY FLOW
 IDe.
KBAS
                           3. 3. .... 5. 6, 7. .... 3.
                                CALCULATE EACH OUTLET CONSTITUENT FLOW
NSTR
          66 0,
 VARY
                         72 SPLIT RATIO FOR GAS
VARY
                         76 SPLIT RATIO FOR LIQUIDS
 1.D. .
             CABIN AIR DEN POINT AND TEMP CONTRAL HEAT EXCHANGER SIMULATED BY-
 I Das
           2 SUBROUTING ANYHX
KBAS
                                      __ 25 O .
 NSTR
            210000100
                                  COUNTERFLO HX NO SIZING
 VARY
          66 130,
          75 65
                           DESIGN OUTLET TEMP PRIMARY SIDE
VARY
 VARY
                           TOLERANCE FOR DESIGN OUTLET TEMP
           1 FLOW RETURN TO CABIN AS MEASURED BY FLOW METER SUBROUTINE FLOMET
 NSTR
                                  METERED ALL PLOWS
          65 32.0
                            REFERENCE TEMPERATURE FOR ENTHALPY
 VARY
           1 REGENERATIVE HEAT EXCHANGER FOR HEATING THE SOLUTION USING MINIMUN
 IDes.
 IDee.
           2 HEAT INPUT
 KBAS
          210020000
NSTR
                             LIGALIO COUNTERFLO HX NO SIZING
                            UA OF THE REGENERATIVE HX
          66 1385,
75 175,
 VARY
                                                                     BTJ/LB-F
 VARY
                            DESIGN OUTLET TEMP PRIMARY SIDE
           1 FOR HEATING THE SOLUTION TO DESIRED LEVELS COMPENSATING FOR THE
 1000
           2 INEFFICIENCY OF THE REGENERATIVE HEAT EXCHANGER
 1D.
 KBAS
                                   5 6 7
NSTR
                                  MODIFY REARRAY)
 VARY
          65 700.
                            HEAT LOAD
          66 185.
                            TEMP OF OUTLET FLUID
 VARY
 IDee
             FLASH VAPORIZATION AS SIMULATED BY LOPUSH THIS COMPONENT SIMULATE
 ID.
           2 THE REACTION OF BICARBONATE TO GENERATE CARBONATE SOLUTION +CO2 +H2
           3 0 AND SEPARATE THE GAS FROM LIQUID.
 1D.
KBAS.
                          NSTR
                                  LOFLEH
                            TOTAL FLOW
 VARY
           1 215,604
                                                                     LB/HR
VARY
             185,....
                            TEMPERATURE ---
 VARY
           3 3,98864
                            PRESSURE, UPSTREM DUCT
           4 3.98864
 VARY
                            COMPONENT OUTLET PRESS
                                                                     PSI
4 VARY
         15 198,030
                           -WATER
                                                                     LB/HR
          16 9,52496
 RΥ
                            CARBONATE
                                                                     LB/HR
 VARY
          17 8.04875
                           BICARBONATE
          54 70.
                           AMBIENT GAS TEMPERATURE
· VARY
                                                                     · (F.)
 VARY
          55 5
                           CONDUCTANCE BETWEEN SURFACE AND AMBIENT GAS.BTU/HR=F
 VARY
          57 60.
                            AMBIENT RADIATION WALL TEMP
2 VARY
          58 8.
                           RADIATION PA FACTOR FROM SURFACE TO WALL (FTSQ)
```

```
VARY
           60 60.
                              STRUCTURE TEMPERATURE FOR HEAT SHORTS
 VARY
                             THERMAL CONDUCTANCE BETWEEN MODULE/STRUCTR STU/HR-F
           61 1
 VARY
                             <u>-CONDUCTANCE BETWEEN MODULE/SURFACE INSULATION B/HR-F</u>
           44
                              CO2 PARTIAL PRESSURE IN VAPORIZER
              10.
           65
                                                                          MMHG
 VARY
           68
                              DESIRED NORMALITY OF SOLUTION
              1,
                              DESIRED NORMALITY OF SOLUTION
 ID.
       10
             HZO CONDENSOR USED TO SEPARATE H2D FROM COZ BY CONDENSATION (ANYHX)
                                                         . 2
 KBAS
       10
                                                   -30 0
                            16. 2
NSTR
       10
             200000100
                                    HI3/CO2 CONDENSOR LIQ-GAS COUNTERFLO HX NOBIZ
           66 100.
                                                                          BTU/LB-F
 VARY
       10
                              UA :
 VARY
                              DESIGN OUTLE TEMP PRI SIDE
           75 50.
       10
VARY
       10
           76 5.....
                            TOLERANCE DESIGN TEMP
 IDo.
            1 THE CO2 GAS FLOWS INTO CO2 RESERVOIR SIMULATED BY TANKS
 KBAS
       12
              30
                            10 2
                                                                           13
             1100
NSTR
                                    CO2: TNK TEMP SET
           54 70.
                                                                         ル学 2 1 円
 VARY
       12
                              AMBIENT GAS TEMP
 VARY
       12
           55
              5,
                              THERMAL CONDUCTANCE BETWEEN AMBIENT THE
                                                                          BTU/HR-F
VARY
       12
           57 60.
                             AMBIENT WALL TEMP
              6,
                             REALATION FA SKIN TO WALL
 VARY
       12
           58
                                                                          FTSD
 VARY
       12
              60.
                              STRUCTURE TEMP
                              CONDUCTANCE BETHEEN THE AND STRUCTURE
VARY
           61
 VARY
       12
           67
              0.5
                              TOTAL FLUID WEIGHT IN THE
                                                                          LB
 VARY
       12
           68
              70.
                            FLUID TEMP IN THE
                         FLUID-VOLUME IN THE
       12
           69
 VARY
                                                                          FTCV
                             FLUID PRESS IN THE
 VARY
       12
           70
              14.7
                                                                          PSI
                             WEIGHT OF NON-CONDENSABLE INSTAK.
           71 0.5
 VARY
       12
                                                                         LBS
 YARY
       12
                             NON CONDENSABLE SPECIFIC HEAT IN THE BTU/LB-F
 VARY
       12
           75
                             NON-CONDENSABLE MOLECULAR WEIGHT
                                                                          LB/MOLE
 MARY
       12
           78
                              WEIGHT OF CO2 IN THE
                                                                         LB
             -CHILLER-TO COOL DOWN THE CARBONATE SOLUTION SIMULATED BY ANYHX.
                                                   -35 0
 KBAS
                            -7 4
                                     5 6 7
                                                          2
 NSTR
       15
             210020000
                                    LIGHLIG COUNTERFLO HX NO SIZING
 VARY
              142.
           75 70.
                              DESIGN OUTLET TEMP
 VARY
       15
 ID.
           1 THE CONDENSATE IS COLLECTED BY H20 COLLECTOR SIMULATED
       13
                                                                        BY HEOSUM
 KBAS
                              KARY
       13
           16
                              NUMBER OF COMPONENSATE IS COLLECTED FROM
           17
 KARY
       13
                              FIRST COMPONENT CONTRIBUTING CONDENSATE
 KARY
                              SECOND COMPONENT CONTRIBUTING CONDENSATE
            3 14.7
                              COMPONENT PRESS
 VARY
       13
                              COMPONENT PRESS
 VARY
       13
            4 14.7
            1 H20 SUPPLY TANK (TANKO) RECEIVES THE CONDENSATE FROM 13 AND PROVIDE
....IDes
              S MAKEUP #20
 ID:
              30
 KBAS
                            13 4
             1100
NSTR
                                    HATER THE ONLY PRAYER BUT GOD WORKS FOR NOBODY
 VARY
            1 5,8951
                              FLOW
                                                                          LB/HR
 VARY
              70.
                              TEMP.
           3 14.7
 VARY
                             PRESS
                                                                          PSI
              14.7
 VARY
                              PRESS
                                                                          PSI
              5.8951
 VARY
                              FLOW
                                                                          LB/HR
              70,
VARY
                              AMBIENT GAS TEMP
 VARY
       14
           55
              5,
                              CONDUCTANCE SURFACE INSULATION TO AMBIENT
 VARY
              60,
                              AMBIENT WALL TEMP
           58
VARY
       14
                             RADIATION FA FACTOR
              0.4 . *...... .
                                                                          FISO.
           60
              60,
                              STRUCTUR TEMP
                              CONDUCTANCE BETWEEN WALL AND INSULATION
           64
              .05
· VARY
              62.4
                            TOTAL FLUID WEIGHT IN THE
              60,
       14
           68
                              FLUID TEMP IN TNK
 VARY
                                                                          F.
       14
 VARY
           69
              1.
                              FLUID VOLUME IN THE
                                                                          CUFT
VARY ...
       .1.4
           81 62,4
                          WEIGHT OF SPECIAL FLOW NO, 2 IN TANK
```

```
MAX ALLOWABLE TEMP CHANGE FOR SS
VARY
       14
              VACUUM PUMP SIMULATED BY PAN TO PUMP OUT CO2/M20 GAS FROM LGFLSH
ID:
       16
KRAS
               23-
                                                                            10.....
       16
                                     ADD HEAT SPECIFIED ONLY NO HEAD
                                                                         RISE/PERFORMN
   PR
       16
10.
               JUNCTION WHICH PROVIDES FOR THE ADDITION OR MAKEUP WATER TO SYSTEM
       17
                                                              5 6 7
                                                                             18
       17
KBAS
                                    .....5...6. 7 ...... . . . .
                                                    -14 4
                                     OUTLET PRESS EQUALS PRIMARY SOURCE
NSTR
       17
                          WHICH REMOVES AND PRESSURIZED THE WATER TO 1 ATM.
 ID:
       18
NSTR
                                     ADD HEAT ONLY NO HEAD RISE OR PUMP PERFORMANCE
       18
KHAS
               22
       18
                                      5 6 7
                                                                             15.
                               TOTAL FLOW
VARY
                                                                             LB/HR
       18
              216.16
VARY
       18
              173.
                               TEMP.
                                                                             Ė.
VARY
            3
                               PRESS, UPSTREAM DUCT
                                                                             PSI
       18
              14.7
              14.7
                               PRESS.COMPONENT OUTLET
VARY
                                                                             PSI
       18
VARY
       18
               199.900
                               H20 FLOW
                                                                            LB/HR
VARY
       18
           16 8,5912
                                                                            LB/HR
                               K2CO3 FLOW
VARY
       18
           17 7.57385
                               KHCOB FLOW
                                                                            LB/HR
1000
       25
              <u>-Dummy component providing coolnt flow to component no. 5</u>
 KBAS
       25
               4.9
 NSTR
       25
                                     COOLANT TO CABIN TEMP/HUMIDT CONTROL
            1 150.
VARY
       25
                                                                            LB/HR
                               COOLANT FLOW
       25
            2 45
                               COOLANT TEMP
 VARY
                                                                            .
 VARY
       25
             3 15.
                               PRESS. UPSTREAM DUCT
                                                                             PSIA
       25
            4 15,
                               PRESS, COMPONENT OUTLET
VARY
                                                                             PSIA
 ID**
       30
             1 DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT NO.
 KBAS
       30
               49
NSTR
       30
                                     COOLANT TO HOD/CO2 SEPARATOR
 VARY
       30
               250.
                                                                             LB/HR
                               COOLANT PLOW
  ARY
       30
             2
              35.
                                                                            F. -
                               TEMPERATURE
       30
                                                                            PSI
   RY
            .3. 10.
                               PRESSURE.
 VARY
       30
                                                                             PSI
            4 10.
                               PRESSURE
 ID.
       35
             1 DUMMY COMPONENT PROVIDING COOLANT FLOW TO COMPONENT NO. 15.
 KBAS
       35
               49
 NSTR
       35
                                     COOLANT TO CHILLER
                                                                             LB/HR
       35
 VARY
              100.
                               COOLANT PLOW
VARY
       35
             2 45.
                               TEMP
 VARY
       35
             3
              10.
                               PRESS.
                                                                            PSI
       35
             4
               10.
 VARY
                               PRESS.
                                                                             PSI
PLAT
                72
                                          PPCO2 CAS FLOWING IN CO2 CONCENTRATOR MMHG
                               10.
             3
                    0.
 PLOT
                49
                                          PPCO2 GAS LEAVING CO2 CONCENTRATOR
                               10.
                                                                                 -MMHG
                    0.
             2
                 2
                                          GAS TEMP ENTERING COZ CONCENTRATOR DEG-F
 PLOT
                               100.
                    0.
                                          GAS TEMP LEAVING COZ CONCENTRATOR DEG-F
PLOT
                               100.
                                          PPCO2 IN FLASH VAPORIZATION MODULE MMHG
            9
                65
                    0
PLOT
                               15.
             9
                                          TOTAL PRESSURE IN VAPORIZATION MODULE PSI
 PLOT
                    0.
                               15.
                                          SOLUTION FLOW THROUGH COR CONCENTRIR LBAHR
PLOT
                                          GAS FLOWING THROUGH COZ CONCENTRATOR LB/HR
 PLOT
            2
                 1
                                          HEAT ADDED PRIOR TO VAPORIZATION BTU/HR
PLOT
             8
                65
 PLOT
                                          HEAT ADDED TO THE VAPORIZER BTU/HR
                                          TOTAL WATER CONDENSATED IN HX LB/HR
 PLOT
            13
                                                ADDED TO THE SYSTEM LB/HR
 PLOT
            14
ENDC
 ENDR
```

			D-28		
*INSE	RT, GPOLY1, 24	LECTRODIALYSIS			
	TOTAL MAKEUP WAREUP WHUME,55 WHOTE VV(12,81 IF(WTOT:LE.O.)	TER TO ELECTRO Hemum	DIALYSIS S	SUBSYSTEM	, 1
	-				

```
CALL SV(WTOT, 3, 1)
       CALL SV( WTOT, 3, 15)
                SET FLOW TO HUMIDIFIER:
       RH65# WHUM/WTOT
       IF ( RH65.LT.0.) RH65= 0.
       IF (RH65.GT.1.) RH65. 1.
       CALL SV( RH65,5,65)
       T1# VV(5,21)
       P1= VV(5,23)
       CALL SV(WHUM, 27, 90)
       CALL SV(WHUM, 27, 26)
       CALL SV(71,27,21)
       CALL SV(P1,27,23)
       MUHWETOTH BITH
       IF ( WIT-LE-D) GO TO 10
C
               SET MAKEUR FLOW TO CATHODE LOOP
      WC= VV(12,83)
      ...R665=..WC/WTT...
       IF( R665.GT.1.) R665# 1,
       IF( R665 LT, 0, ) R665 0.
       CALL SV( RAGB, 6" 65)
   10 CONTINUE
 TAPE
BASIC
              1 7 YEA
                                                       NAY
            CO2 ELECTRODDALYSIS MODULE SAMPLE PROBLEM
 CASE
  SCASE1
       KCHOUTED. KPRNTEDOS. KPTINV(1) = 006. KRUNE1.
       TMIN==460., TMAX=2000., WTMAX=10000.
       DTIME#10., STARTRO., TIMEMX#1200., MAXSSI#5.,
       MAXSLP#3
       MINSSI=3 S
  SPROP1
       CPCOSE.197, CPD1L=.25, VISGAS=.045, WIMTCEIG.,
       XKGASE.0147. WTMDILe28. WTMCONe18., CPCONVa.44.
       CPCONL=1., CPOXY=.22.
       CP(1)#1,0, RHO(1)#62,4, VISC(1)#2,22, XK(1)#,35, WTM(1)#18,,
       CP(2) # . 22, RHO(2) # . 0827, VISC(2) # . 0492, XK(2) # . 0152, WTM(2) #32.,
       CP(3) #3,41,RHO(3) #,0052,VISC(3) #,0216,XK(3) #,106,WTM(3) #2.,
       CP(4)=,198;RHO(4)=,114; VISC(4)=,0363;XK(4)=,0094;HTM(4)=44;
 ID.
              SOURCE OF FLOW TO SUBSYSTEM
 KHAS
                              3
       01 01 207.037
VARY
                            FLOW GAS FROM CABIN
                                                              (LB/HR)
           02 75.
 VARY
       01
                             TEMPERATURE
                                                              (F)
           04 14.7
                             PRESSURE
 VARY
       01
                                                              (LB/SQ IN)
 VARY
       11
           06
                             WATER VAPOR
                                                              (LB/HR)
       01
           10 47.6
                             OXYGEN
 VARY
                                                              (LB/HR)
           11 156.8
 VARY
       01
                             NITROGEN
                                                              (LB/HR)
           12 1.237
VARY
       01
                            CARBON DIOXIDE
                                                              (LB/HR)
              0001
                             TRACE CONTAMINATES
VARY
       01
           13
                                                              (LB/HR)
 IDe.
        2
              SOURCE OF SWEEP FLUID
5 KBAS
              49
                                    1 2 3 4
 VARY
       02
           01 200.
                             SWEEP LIQUID FLOWRATE
                                                              (LB/HR)
           02 75,
 VARY
       02
                             TEMPERATURE
                                                              (F)
       02
4 VARY
          04 14.7
                             PRESSURE
                                                             (LB/SQ IN)
  RY
       02
           15 200.
                             WATER PLOWRATE
                                                              (LB/HR)
 1000
              WATER FEED TANK
        3
3 KBAS
              -30-
             1210
       3
 NSTR
                                                              (LB/HR)
 VARY
       03
           01 0.658
                             TOTAL PLOW OUT OF TANK
       03
           34 75.
                              AMBIENT TEMPERATURE
                                                              .(F.) ....
2 VARY
```

VARY	0.7	EE 2	ILA TO GUSBALL	ND THOS	(BTU/HR=F)	
	03	77 6 t	UA TO SURROU GAS TEMPERAT	MAIMAR		
VARY	03	68 75.	GAS TEMPERAT	URE	(F)	
VARY	03	40 2 0	VALUE LEAUT	D IN FANK	(CU FF)	
	03	70 14.7	DOCCOURE:	S TA LEMAN	(1.0.400 7.11)	
Y		70 341/	LKESSOKE.		(PELRA IN)	
VARY	03	81 1.0	PRESSURE: Fraction wat	ER IN TANK	(FRACTION)	
1000	Ā	WATER MAKE	UP TANK			
KBAS	4	90	3 4 1 2 3	4	5.	
NSTR	. 4	0210				
VARY			TOTAL FLOW O	HT OF TANK	(LB/HR)	
				O TOTAL PROPERTY OF THE PROPER	. — **	
VARY	04	54 75	AMBIENT TEMP	ERATURE	(F)	
VARY	04	55 Ž.	UA TO SURROU	NDINGE	(RTU/HR-F)	
VARY	04	40 98	A 4 8 . TE 44 B E B 4 T			
	-				(F)	
VARY	04	69 , 15	VOLUME LIQUI	D IN TANK	(CU FT)	
VARY	04	70 14. 7	PRESURE		CLR/RD TNI	
VARY	04	04 4 0	VOLUME LIQUI PRESSURE FRACTION WAT	Ph In BANK		
		# 1 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		EK-IN TANK		
10+	5	FLOW SPLIT			· t	
KBAS	S	10	4 4 1 2 3	4	1 2 3 4 5	-
MARK	-	45 0			1 2 0 7	
VARY	5		4 4 1 2 3 SPLIT RATIO			
1D**	6	FLOW SPLIT				
KBAS	6		5 4 1 2 3	4	1 2 3 4 12	
				7	* * A 4 * TE	
VARY			SPLIT RATIO			
ID.	7	SOURCE COO	LANT TO CONDENSER	21		
VARY	07	01 64.	FLON COOLANT	TA UV CAMP 34	(D/UD)	
		U. 971	LOW COOLWAY	LIO MX COME 1 ET	/ Polyuni	
VARY		05-50-0	TEMPERATURE		(P')	
VARY	07	04 14.7	PRESSURE	•	(LB/SQ:IN)	
1D**	8		LANT TO CONDENSER			
		PUONUE CUC	PAMI IN ACUDEUSED	64	14. 1. 2. 14. 2. 14. 14. 14. 14. 14. 14. 14. 14. 14. 14	
VARY	_08_	<u> </u>	FLOW COOLANT	TO HX COMP, 24	(L8/HR)	
VARY	08	02 50.	TEMPERATURE		(F)	
				•	VI V	
KRAS	7	49	0 1			
S_	8_	49		المراكب المستوانية والمراكب المستوانية والماك		
KBAS	9	40	o i		÷,	
					41 0 400 211	
VARY	08	04 14.7	PRESSURE		(L8/SG IN)	
IDee	- 9	SOURCE COS	LANT TO CONDENSER	14		
VARY	9	01 64.	TOTAL FLOW		(LB/HR)	
VARY	9	05 50	TEMPERATURE		(F)	
VARY	9	04 14.7	TEMPERATURE PRESSURE		(PSIA)	
1000	4 0	SUBSYSTEM	AL AMER			
KBAS	10	23	1 3		11	
-NSTR	10	0.03	·			
VARY	10	91 50,	HEAT DISSIPA	TION	(WATTS)	
				(1 ↓ ∪ (1	(MAIIS)	
IDe*	11	HUMIDIFIER	•			
KBAS	_11	<u>6</u>	10 3	27 3	3	
	-	. ••		• •		
NSTR	11	00			•	
10.0	12		LYSIS MODULE		and the second s	
KBAS	12	53	11 3		1234 14	
NSTR	12	. * *				
		2	· · · · · · · · · · · · · · · · · · ·			
KARY	12	16 13	ALTERNATE: CO	MPONENT		
KARY	-	17	- .		•	
KARY	12	18 40		LL UNITS/STACK		
VARY	12	51 75.	ESTIMATED MO	DULE TEMPERATURE	(F)	
VARY	12	84 75		TEMPERATURE	(F)	
VARY	12	55 6.	UA TO SURROU		(BTU/HR=F)	
VARY	12	57 75.	AMBIENT WALL	TEMPERATURE	(F)	•
VARY	12	664.,6	CURRENT DENS		(AMPS/SQ FT)	
RY	12	67 0,72	AREA PER ANO		(SQ FT)	
VARY	12	68 1,28	CURRENT EFF1	CIENCY	(FRACTION)	
VARY	_12_	49 90,	RH PROCESS G		- (PER CENT)	
VARY	12	71 212,	STACK VOLTAG		(VOLTS)	
VARY	12	72 0.3	POWER EFFICI	ENCY	(FRACTION)	
	12	74 75		DULE TEMPERATURE	(F)	
F P FT	· - 4· &	·····································	COLDINA CED MA	AND THE TEMPERATURE	NF /	•
				•		

			g Asi	•	D-31			
VARY	12	75	1.00	CONVER	GENCE TOLERAN	CE	(PRR CÉNTA	
VARY	12	14	18.	MARINE	THERMAL CAPA	C I TANCE	ABTILLES	٠.
-VARY	12	45	75	MARINE	INITIAL TEMP	COATIDE	(F)	
	13		ALTERNATE C	TOMBOOR TO	LECTRODIALYSI	C MARINES		
KBAS	13						1 2 3 4	
NSTR	_13_		49	EU •	7 8 8 4	-10 -	1 2 3 4	
	14				PHANE SERVICE	. • •		
10**	4.		TEAT BACHAN	MATH LOK CV	THODE EFFLUEN		•	•4.
KBAS	14			-13	1 2 3 4	44 0 I		31
NSTR	-14		4.4				41.041.01	
VARY	14	01	991	FLOW C	DOLANT TO HX	COMP. 14	(PRNHW)	
VARY	14	02	50,	TEMPER	IATURE IRE		(F)	•
VARY	\$4	-04	1417	PRESSU	IRE:			
VARY			0.9	EFFECT	Iveness	•	(FRACTION)	
10			HR COMPRESS	SOR			•	
KBAS-	45		23	-31 3	1234		and the second s	-16
NSTR	15	(003			•		21
VARY	15	91	5.0	HEAT	ISSIPATION .		(WATTS)	•
10.4	16		H2 ACCUMULA	TOR		•		
NSTR	16		0210					
KBAS	16	.*	30	15 3	1 2 3 4	•		10
VARY	_16_	01	0.0216		RATE		(LB/HR)	
VARY	16		75,	TEMPER	ATURE		(F)	
VARY	16			PRESSL			(L8/50 IN)	
VARY		.04.	20.0		RE.		(LR/SQ IN)	
VARY	16	54	75,	AMBIEN	TEMPERATURE	· · · · · · · · · · · · · · · · · · ·	(F)	•
VARY	16	55		LIA TO	SURROUNDINGS		(BTU/HR=F)	
VARY	16		7R.	CAR TE	MPERATURE	•	(P)	
VARY	16	40	3,	TANK V			(CU FT)	
YARY	16	70	20 0	DAG DE	RESSURE	•	(LB/SQ IN)	
S Y		47	1,	COACT!	ON HYDROGEN		(FRACTION)	
lĎ	17	- 6 9 -	PIOU NIV.	intellerine 1994 i Altania	-CARLORE LOAD		THE WALL TOWN	
			EPON MIX W	AKEUP WAJER	CATHODE LOOP	6 4	*	4.9
KBAS	17		7	31 4	1 2 3 4	0 7	1 2/3 4/5	18
-NSTR	17		SAEUSSE L	20.0114				
10.0	18	•	CATHODE LO			•		- 4
KBAS.	18		32	17 4	1 2 3 4	:	•	24
NSTR.	18		2	. · · · · ·		4.5		
VARY	18	01	64,		E LOOP FLOW		(LB/HR)	
VARY	18	02	50,	TEMPER			(.F.)	
VARY	18	-04	_14,7	PRESSU	F 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		- (FB/80 IN)	
VARY	18	15	-64,	WATER	FLOW		(LB/HR)	
VARY	18	85		THERMA	L DISSIPATION	}	(WATTS)	
1.De=	19		PLOW MIX MA	AKEUP WATER	CATHODE LOOP			
KHAS	19		7	29 4	1234	-m6 4	1 2 3 4	20
NSTR	19	•		•	, ,	•	± •	•
_1D++-	-50		ANODE LOOP	PUMP				
KBAS	20		22	19 4	1 2 3 4			22
NSTR	20		2	= • •	. • • · · · · · · · · · · · · · · · · ·	•		
VARY	20	01	64	ANODE	LOOP FLOW		(LB/HR)	
VARY	20	02	5 0.	TEMPER			(F)	
VÄRY	20	04	14.7	PRESSI		•	(LB/SQ IN)	
5 VARY	_20_	15	_AA	WATER				
VARY	20	85	10,		L DISSIPATION		(LB/HR) (WATTS)	
		9 -	HEAT EXCHA!		NODE: EFFLUENT	1	(MAITO)	
ID#+	21		TOTAL BAUMAI		· · · · · · · · · · · · · · · · · · ·		•	
A KHAS	21			13 4	1234			29
TR	21		0 2	1	1. V.C			
VARY	21	97	0.9	EFFECT	riveness		(FRACTION)	
3 1000	22		DA COMPRES		4 4 7 4	·.		
KBAS	22		23	-29 3	1234			23
NSTR	22		003					
2 VARY	22	-91	-5,0	HEAT I) ISSIPATION		(WATTS)	

	~		A COLLEGE OF A COL					• .	
10**		ĎŠ.	ACCUMULATOR		4 - 7	à	•	*	4.0
KBAS	23	20	9	3	1 2 3	4		,	25
-NSTR	52-	088	}		25				the formula of the control of the co
RY	23	01 1	7 .	02 USE	RATE	ERATURE DINGS RE		(LB/HR)	*
VARY	23	54 / 7	•	AMBINE	NT TEMP	ERATURE		(F)	
	23	55 2		UA -TO A	SURROUN	DINGS		- (BTU/HR-F)	
VARY	23	68 75	•	GAS TE	MPERATU	RE		(F)	
VARY	23	69 2,		TANK V	OLUME		*4	(CU FT)	•
VARY	23	70 20						LB/SQ IN	
VARY	23			FRACTI	ON OXYG	EN		(FRACTION)	,
1Da e		HE	AT EXCHANGER	FOR CO	NCENTRA	TAP EFFI II	ENT	(FIRMOTO WITE	
KBAS	94		A I GAUNANAGA -40			4			30
		.0			· · <u>* · · · · · · · · · · · · · · · · ·</u>		6 A 7		3 4
NSTR	24		. K	1				40040000	
VARY	24	67 0	9	EFFECT	IAEMEDS		•	(FRACTION)	}
	25		COMPRESSOR						
KBAS	25	23	-30	3	1 2 3	4			25
NSTR	25	003	•						
VARY		91 5.	<u> </u>	HEAT D	ISSIPAT	10N		(WATTS)	
1D.	26		2 ACCUMULATOR						
NSTR	26								
KBAS	26	30	0		4 2 3	A	*		4 R
		6 A 7 E		AUBIEN	1 2 3	DATION			-
VARY	26	24 /2		AMBIEN	TIEMPE	RATURE	•	(F)	
VARY	26	22 51		UA TO	SURROUN	DINGS		(BTU/HR=F)	•
		68 75			MPERATU	RE		(P)	
VARY	26	69 2.	- S	TANK V	OLUME			(CU FT)	
VARY	26	70 20	•	GAS PR	ESSURE		*	(LB/SQ IN	,
VARY-	26	84 1.	•	FRACTI	ON GARB	ON DIOXID	§	- (FRACTION)	
VARY	26	01 .5	75	CO2 US	E RATE		-	(LB/HR)	
LDee	27	SO	URCE LICUID F				•		
	27		ALAM PIRATE IL			1. ******		5° 9	:
VARY	27					A HILLIPE	150	(L8/HR) (F)	
		20 01	55 I	FIRATE	A TUDE	O MUMILITY	1 難立	(CO/AN)	
VARY	27	27 /3	1_	TEMPER.	AIURE				
VARY	27	23 14	,7	BURZAO.	H 5			(F8/80 IN	
VARY	27	24 1	E=4			1997年 1997年 1997年			and the state of
VARY	27	25 1,	E=6	•					A Company
VARY	27	28 29	E-6				للافيد أرابيع بالمراجد		
VARY	27	26 0.	5 5	LIGUID	WATER			(LB/HR)	•
10	29	02	WATER SEPARA	TOR					
-KHAS-	29			4	1 2 3	4	4	1214	19
NSTR	29	4 7 7	: 5 44	• •					•
VÁRY	29	67 0.	0000	00 50	IT ŘÁTÍ	^ -		(FRACTION)	•
VARY					SPLIT A	AT LU	-	(FRACTION)	,
10.0	30		2/WATER SEPAR						
KBAS	20	10	5 24) . 4	1 2 3	4 .	9	1 2 3 4	21
- NSTR	-30								a santanan da da angentara da an
VARY	30	66 0,			split r		•	(FRACTION:	
VARY	30	69 0.	9999		LIT RAT			(FRACTION	
1D**.	31	H2	/WATER SEPARA			oficial of the state of the st			٠.
KBAS	31		· · · · · · · · · · · · · · · · · · ·		1 2 3	4	4	1 2 3 4	17
NSTR		4	- - • • •	• 7	•• ₹	•			• 1
LVARY	_31	68 0.	9999	U2 901	IT RATI	۸.	•	- (FRACTION	•
	-								
VARY	31	66 0	0001		SPLIT		6 0 5.5 7	(FRACTION)	
PLOT		10 1		2.	CUZ	IN PROCE	55 GAS E	NTERING MODE	/LE(LB/HR)
PLOT		12 1			C05	IN PROCE	55 GAS L	EAVING MODUL	E(LB/HR)
TOT		13 1	6 0,	. 5	08	GENERATED	BY ELEC	TROLYSIS(LB)	'HR
701		13 3		. 5	H2	GENERATED	BY ELEC	TROLYSIS(LB)	HR)
PLOT		12 1		-5		REMOVED			e e e e e e e e e e e e e e e e e e e
PLOT		12 5		100,		ULE TEMPE			•
PLOT	÷	12 8		2.		AL WATER			
		7.5	• *1	6 •	1 V 1	AL MAIST	Coudence	INDIAN)	*
2 ENDC									

```
*INSERT, GPOLY2,21
       IF(.NOT.STEADY) 00 TO 10
      IF( N.NE.5) RETURN
      TSET=1050.
      R65avv(13,65)
      R65# R65 + (R(51)=TSET)/TSET +5.
      IF( R65, GT, 1, 0) R65=1.
IF( R65, LT, 0.) R65=0.
      CALL SV( R65, 13, 69)
      RETURN
   10 CONTINUE
      IF(N.NE.7) RETURN
      IF (NPASS.LE.O) RETURN
      BYPASS FLOW CONTROLLED BY TEMPERATURE CONTROLLER
      R658 VV(10,68)
      CALL SV(R65,13,65)
      ADJUST MOLTEN CARBONATE CELL TO CONTROL CO2 PARTIAL PRESSURE
      R67# VV(9,68)
      CALL SV(R67,5,67)
*INSERT.GPOLY1.24
      IF(STEADY) RETURN
      IF( N.EQ.9) GO TO 9
      IF( N.NE.10) RETURN
      TEMPERATURE CONTROLLER
      TMPS VV(5,02)
      R(66) STMP
     RETURN
      CURRENT CONTROLLER
    9 CONTINUE
      PAIRS VV(5,04)
      WC02# VV(5,12)
      XHTE VV(5.09)
      WAIRE VV(5.01)
      IF ( WAIR, LE, 0.) RETURN
      PCOZE WCOZEXWTEPAIR/ ( WAIR#44.)
      R(66) = PC02
 TAPE
BASIC
           MOLTEN CARRONATE CONCEPT
 CASE
 SCASE1
  KCHOUTED, KPRNTEGOS, KPTINV(1) 8006, KRUNE1,
      TMIN#=460., TMAX#4000., WTMAX#10000..
      DTIME#10.. STARTED.. TIMEMX#1200.. MAXSSI#4.
      MAXSLPe3.
      MINSSIES S
  SPROP1
   XKGASE.0147.WTMDTLe28..WTMCON818..CPCONV=.44.
      CPCONL#1., OP(1)#1., RHO(1)#60.1, VISC(1)#0,704,
      WTM(1)=18. XK(1)=.394.CROXY=.22.
      CP(2)=1, , RHO(2)=62,4, VISC(2)=3.90,
      WTM(2)=18., XK(2)=.325
           SOURCE OF CABIN AIR TO SUBSYSTEM
4 1D.
            49
      01 1 82,288
                         TOTAL PLOW
  RY
                                                     (LB/HR)
     01
VARY
         4 14.7
                        PRESSURE
                                                   (PSI)
         02 75.
 VARY
      01
                         TEMPERATURE
                                                     (F)
```

```
06 0.766
                          WATER VAPOR
                                                       (LB/HR)
VARY
      01
VARY
      01
         07 D.
VARY
      01
         10 18.8
                        N2
 ARY
         11 62.23
                                                       (LB/HR)
      01
VARY 01 12 0,4918
                                                       (LB/HR)
                        ----
            SUBSYSTEM BLOWER
ID.
     -2
           23
KBAS
                         1.2.
NSTR
          0.03
         91 60,
                          HEAT ADDED TO AIR STREAM
                                                       (WATTS)
VARY
            ADSORBING SILICA GEL BED
ID.
                                           -12 0 2
KBAS
                                                                 13
       3 211
NSTR
VARY
        66 1.
VARY
         67-68
       3 68 0,85
                     HEAT EXCHANGER EFFECTIVENESS
AVERAGE SS BED LOADING
VARY
       3 76 05
VARY
                                                       (LB/LB)
VARY
       3 79 432
                        --- CORFFIGIENT A
VARY
       3 80 1062,
                       COEFFICIENT B
                        FRONTAL AREA
VARY
       3 83 1,
                                                      ($0 FT)
        84 1.8
VARY
                         LENGTH-
                                                      3 85 507
                         AV. SUPERFICIAL SURPACE AREA (SQ FT/CU FT)
VARY
         86 D.4
                         VOID FRANTION
VARY
VARY 3 87 .22
                       PELLETT SPECIFIC HEAT
                                                      (BTU/LB=F)
       3 88 45.
3 89 0.01
VARY
                        PELLET BULK DENSITY MASS TRANSFER COEF.
                                                       (L8/CU FT)
VARY
                                                       (LB/HR-SQFT-MM HQ)
                         MASS OF COOLANT DN MX
VARY
         90 1.
                                                       <del>(LB)</del>__
                    EXIT ADSORBATE PARTIAL PRESSURE (MM HG)
BED LOADING (LB/LB)
         91 1
VARY
         99 ,05
VARY
       3 107 75,
                     CARRIER GAS TEMPERATURE
                                                       (F)
  RY
       3 115 75,
3 123 40,
 VARY
                          BED TEMPERATURE
                                                      (F)
                         LIGUID OUTLET TEMPERATURE
VARY
1Das
            AIR/AIR REGENERATIVE HEAT EXCHANGER
       4 4 13 2
4 67 97 HEAT
KBAS
                                                                14
                     HEAT EXCHANGER EFFECTIVENESS
VARY
       4____10000 ___1___
NSTR
IDA+ 5
KBAS 5
            MOLTEN CARBONATE CELL
            54 14 2
                                                                 10.
KARY
       5 01 81,03
 VARY
       5 02 1022,
VARY
       5 03 14.7
VARY
         04 14.7
VARY
VARY ...
         05 81.03
         6 01
VARY
       5 08 0.22
VARY
       5 09 29
VARY
VARY 5 10 18.8
VARY
       5 11 62,23
                       TEMPERATURE MODULE SHELLINS/WALL(F)
         51 80,
VARY
         84 70.
5 VARY
                        UA INSUL SURFACE TO AMBIENT
       5 55 5
VARY
                                                       (BTU/HR-F)
       5 57 70.
                         AMBIENT WALL TEMPERATURE
VARY
4 VARY 5 58 .05
       5 60 70.
 MARY
                         STRUCTURAL TEMPERATURE
                      THERMAL CONDUCTANCE TO STRUCTURE (BTU/HR-F)
       5 61 0,
  RY
                         INSULATION THERM, CONDUCTANCE (BUT/HR-F)
3 VARY
       5 65 1600,
5 67 30,
VARY
                          HEAT DISSIPATED BY ELEC. HEATER (BTU/HR)
VARY
                          CELL VOLTAGE
                                                       (VOLTS)
                      -----POWER-EFFICIENCY-
Z VARY...
                                                      (FRACTION)
```

```
5 72 1 CONVERGENCE TOLERANCE (PER CENT)
5 77 75. CELL THERMAL CAPACITANCE (BTU/F)
5 78 1022. INITIAL CELL TEMPERATURE (F)
    VARY
    VARY
    VARY
                               OXYGEN GAS ACCUMULATOR
     6 30 -5
    KBAS
   NSTR
                         6 0210
                        6 54 75. AMBIENT GAS TEMPERATURE (F)
6 55 2.0 UA TO SURROUNDINGS (STU/HR-F)
6 67 1.0 WEIGHT GAS IN TANK (LB)
    VARY
    VARY
    VARY
                        6 68 75, TEMP, GAS IN TANK (F)
6 69 2. VOLUME GAS IN TANK (CU FT)
6 70 14.7 GAS PRESSURE (PSI)
6 71 1.0 WEIGHT NON-CONDENSABLES (LB)
6 76 1.0 WEIGHT OXYGEN (LB)
7 DESCRIBING SILICA GEL BED
    VARY
                       VULUME GAS IN TANK (CU F)

0 70 14.7 GAS PRESSURE (PSI)

6 71 1.0 WEIGHT NON-CONDENSABLES (LB)

6 76 1.0 WEIGHT OXYGEN (LB)

7 DESORBING SILICA GEL BED

7 66 1.

7 67 65.

7 68 0 48
    VARY 6 69 2.
VARY 6 70 14.7
    VARY
    VARY
    1Dax
    KBAS
    VARY
    VARY
                        7 68 0.85 HEAT EXCHANGER EFFECTIVENESS
7 76 0.05 AVERAGE SS BED LOADING (LB/LB)
7 79 432 COSFFICIENT A
    VARY
    VARY

        VÂRY
        7
        9
        432
        COMFFICIENT A

        VÂRY
        7
        80
        1062
        COMFFICIENT B

        VÂRY
        7
        83
        1
        FRONTAL AREA
        ($0 FT)

        VÂRY
        7
        84
        1:8
        LENGTH
        ($0 FT/CU FT)

        VÂRY
        7
        85
        507.
        SUPERFICIAL SURFACE AREA
        ($0 FT/CU FT)

        VÂRY
        7
        86
        0.4
        VOID FRACTION
        ($0 FT/CU FT)

        VÂRY
        7
        86
        4
        VOID FRACTION
        ($0 FT/CU FT)

        VÂRY
        7
        86
        45.
        PELLET SPECIFIC HEAT
        ($50 FT/CU FT)

        VÂRY
        7
        89
        0.01
        MASS TRANSFER COBE.
        ($60 FT/CU FT)

        VÂRY
        7
        90
        .01
        MASS OF LIQUID IN HX
        ($8)

        VÂRY
        7
        91
        .0
        EXIT ADSORBATE PARTIAL PREBSURE (MM HG)

        VÂRY
        7
        107
        75.
        CARRIER GAS TEMPERATURE
        ($6$)

        VÂRY
        7
        107
        55.
        BED TEMPERATURE
        ($6$)</t
   VARY
                                          SUBSYSTEM BÝPASS VALVE
     10** 8
                                                                                                                                                                                                                  3
    KBAS 8
                                       10 2 2
                                       -0----
    NSTR.
                         8 65 .0001 SPLIT RATIO SYSTEM BYPASS VALVE
    VARY
                         9 CURRENT CONTROLLER
     ID.
  KBAS 9....
                                    .....15.....
    NSTR 9 00011
NSTR 9 00011

VARY 9 65 35

SET POINT (MM HG)

VARY 9 66 40

CONTROLLED VARIABLE (CO2 PP OUT) (MM HG)

VARY 9 73 1 TIME CONSTANT MAIN SENSOR (SECONDS)

VARY 9 74 1. GAIN FOR MAIN ERROR SIGNAL

VARY 9 75 01 DEADBAND (MM HG)

VARY 9 76 69 PROPORTIONAL BAND (MM HG)

VARY 9 77 0.1 MAXIMUM SPEED FCE (1/SEC)

VARY 9 68 30. CURRENT SETTING (AMPS)

VARY 9 87 29. CONSTANT B

VARY 9 88 14.3 CONSTANT A

VARY 9 88 14.3 CONSTANT A

VARY 9 98 14.3 CONSTANT A

VARY 9 98 14.3 CONSTANT A

VARY 9 98 14.3 CONSTANT A

VARY 9 91 0.5 POSITION OF FINAL CONTRLELEMENT
                                          TEMPERATURE CONTROLLER
                      10
     * *
    KHAS
                                           15
 - NSTR
                                    00011
VĀRY 10 65 1022, SET POINT
VARY 10 66 1030, CONTROLLED VARIABLE (TCELL)
2 VARY 10 68 0,5 BYPASS VALVE SPLIT RATIO
                                                                                                                                                                                    (F)
                                                                                                                                                                                       (F).
```

VARY	10		14	TIME CONS			(SECONDS)
VARY	10	74	1.	GAIN FOR I	MAIN ERROR SIG	NAL	484
VARY	10 10	75	150.	DEADBAND PROPORTIO	NAL BAND		(F)
VARY	10	77	0.1	MAXIMUM S			(1/SEC)
-VARY	10	87	<u> </u>	CONSTANT			
VARY	10	88	1.0	CONSTANT		1	•
VARY	10	91	0.5	POSITION	FCE		•
-IDea	11		SOURCE OF	HOT FLUID			
KBAS	11	v	49	0 1			
VARY	11	01	100,	FLOW			(LB/HR)
VARY.	11	02	200.	TEMPERATU	R.&:		()
VARY	11	04	14.7	PRESSURE			(LB/SQ IN)
1D.	12		SOURCE OF	COLD FLUID			A 4.1
-KBAS-	12		49	0 2			The state of the s
VARY	12	01	100.	FLOW			(LB/HR)
VARY	12	02	38,	TEMPERATU	RE'	•	(P)
VARY.	12	0.4 .	14.7	PRESSURE			(L8/80 IN)
1D##	13		HX BYPASS	VALVE			
KBAS.	13		10	3 2		2	4
-NSTR	_13_)				The state of the s
VARY	13	65		HX BYPASS	RATIO		
1D••	14	-	HX/BYPASS	MIXING			
KHAS	14			4 2		3 2	5 ,
NSTR	14	(_		
PLOT		5	02 0,	1500,	CELL TEMPERAT		•
PLOT		5-	13 0,		COS LEAVING C		
PLOT		5	67 0.	40.	CELL CURRENT		
PLOT		9	91 0.	1,	CURRENT CONTR		
		10	-91 0.				R FCE POSITION
PLOT		13	65 0,	1.	HX BYPASS VAL		RATIO
PLOT		14	06 0,	1.	HEO ENTERING		
PLOT		-14	12 0,		COS ENTERING		· .
PLOT	,	05	29 0,	1.	OXYGEN GENERA	TED(LB/H	R)·
ENDC				.*		(

```
*INSERT, GPOLY1,24
                  **MECHANICAL FREEZEDUT*******
      IF(N .NE. 8) GO TO 14
      HG70 HG (70.)
      V96EVV(9,6)
      IF(NPASS , EQ. 0) V96*A(6)*.1
      R(66) BA(1) CPA+(70, AA(2))+(V96-A(6))+HG70
   15 R(65) BA(2)+R(66)/(A(1)+CPA)
      A(2)=R(65)
   14 CONTINUE
      IF( NPASS .NE, 60 ) GO TO 17
     IF(-N-- NE, 2) Ge TO 17
      M#1902
      CALL SK(M,6,2)
      Ms-1101
     CALL SK(M,6,5)
M8602
      CALL SK(M.14.2)
      M#600000
      CALL SK(M, 18,8)
      ME1400000
      CALL SK(M,6,8)
```

M#210010002

```
CALL SK(M.6.9)
      M=502
      CALL SK(M.10.2)
      M=-1601
      CALL SK(M.10.5)
      Me700000 .....
      CALL SKIM.10.8)
      Ms210010001
      CALL SK(M.10.9)
      Me-1002
      CALL SK(M,5,5)
      Me1000000
      CALL SK(M.5.8)
      DO 16 LL81:14
      VRSLLEVV16.LL)
      VR10LL=VV(10.LL)
     CALL SV(VR5LL.107LL)
      CALL SV(VR10LL,6%LL)
   16 CONTINUE
   17 CONTINUE
 1 GPOLY2.21
      IF(N.NE.20) GO TO 20
      VV12=VV(1,2)
      VV1128VV(1,12)-
      VV16mVV(1,6)
      VV1928VV(19.2)
      CALL SY ( VY 12 - 20720)
      CALL SV(VV12,20,21)
      CALL SV(VV16.20.22)
      CALL SV(VV192.20,23)
   20 CONTINUE
 TAPE
BASIC
                                     ____
 CASE
            MECHANICAL FREEZOUT SYSTEM PERFORMANCE ANALYSIS
  SCASE1
  KCHOUTEO, KPRNTEG, KPTINV(1)=15,MAXSLP=7, MINSSIEZ. KRUNE1, DTIMEE30.,
   TIMEMX#3600..MAX8SI##, TMAX#250..TMIN##450..WTMAX#1.E4 S
  SPROP1
                                                     --XK(1)=.007
  GP(2)#1,,RHO(2)#62,4 ,VISC(2)# 3,6 ,WTM(2)#18,0
                                                      .XK(2)9.325
  CP(3)=,175,RH0(3)=,25 ,VISC(3)= ,036 ,WTM(3)=44,0
                                                      ,XK(3)#,007
 CPCONL=1., CPCONVBO.44, CPCO2BO.2, CPDIL#0.25, CPOXYBO.22, CPTCFO.2,
   GAMGASE1.4, VISGASEO.44, WIMCONE18., WIMDILE28., WIMICE20.,
   CPC02 # .178.
  XXGAS=0.146 S
 1Des
           1 DUMMY COMPONENT WHICH DEFINES THE INFLUENT TO THE MECHANICAL PREEZO
            2 SYSTEM , THE INLET CONDITIONS OF THE H20 CONDENSER,
1D.
KBAS
 NSTR
                                  DUMMY COMPONENT PASSES ALBRARRAYS TO REARRAY
 VARY
              111,6
                            TOTAL FLOW INTO THE MECH FREEZONT SYS
                                                                         (LB/HR)
5 VARY
                            FLUID TEMPERATURE
               70.0
               14,7
                            UPSTREAM DUCT OUTLET PRESSURE
 VARY
                                                                           (PS1)
               14.7
 VARY
                            COMPONENT OUTLET PRESSURE
                                                                           (PSI)
              110,427
4 VARY
                            NON-CONDENSABLE FLOW
                                                                         (LB/HR)
                1,17
  RY
                            CONDENSABLE VAPOR FLOW
                                                                         (LB/HR)
 VARY
                            CONDENSABLE ENTRAINED LIQUID FLOW
                0.0
                                                                         (LB/HR)
                 -124
VARY
                            NON-CONDENSABLE SPECIFIC HEAT
                                                                   (BTU/LB-F)
           9
               28.97
 VARY
                            NON-CONDENSABLE MOLECULAR WEIGHT
                                                                     (LBS/MOLB)
 VARY
           10
               29,35
                            OXYGEN FLOW
                                                                         (LB/HR)
               80.41
                            DILUBRY (N2) FLOW
2 VARY
          11
                                                                         (LB/HR)
```

```
12 :667 CO2 FLOW
 VARY
                                                                        (LB/HR)
             H20 CONDENSER'ASSUME 100 PER CENT WATER SEPARATION GAS-LIGUID HX
 !Des
 KRAS
                      1 2 -12 0 2 3
 R
                                  PRIMARY OUTLET TEMP CRITERIA FOR SIZING HX
            211000100
 VARY
               93.5
         66
                           OVERALL UA
VARY
        2 ...74
             ... .. 3<sub>1</sub>0
                          NTU (MAX
                                                                           (ND)
 VARY
               45.0
                           DESIGN OUTLET TEMPERATURE FOR PRIMARY SIDE (DEG.F)
          76 3 3 0
                            TOLERANCE FOR PRIMARY SIDE DESIGN OUTLET TEMP, DEG.F.
 VARY
             DUMMY COMPONENT PROVIDING COOLANT/SEC FLOW TO HEO CONDENSER COMP.
 lDas
             49 0 2
       12
 KBAS
          1 270:0
       12
                           COOLANT PLOWRATE
 VARY
                                                                        (LB/HR)
       12
                         - COOLANT TEMPERATURE
VARY
         2 38.0
                                                                   (DEG.P)
              15.0 COOLANT PRESSURE
 VARY
       12
                                                                          (PSI)
       12 4
 VARY
                                                                          (PSI)
             DUMMY COMPONENT PROVIDING THE TRICKLE FLOW TO COZ SUBLIMATOR
 · Dee
         SILICA GEL BED FOR H20 ADSORPTION, INTEGRAL HEAT EXCHANGER
       3
 10.
 KBAS
                          H20 ADSORPTION WITH INTEGRAL HX EFFECT. . . 88
-NSTR
          ___208____
       3 66 1,
3 67 65,
                          EFFECTIVE HEAT EXCHANGER AREA NFT + 2E
 VARY
 VARY
                0.85
          -68
                           HEAT EXCHANGER EFFECTIVENESS
 VARY
              0.055 AVERAGE STEADY STATE BED LOADING (LB/HR)
432 COEFICIENT FOR H20 ADSORPTION (ND)
L062.0 COEFICIENT FOR H20 ADSORPTION (ND)
          76
 VARY
 VARY
          79
       3 80 1062.0
 VARY.
                           ADSORPTION FRONTAL AREA (FT**2)
        3 83
 VARY
               1.0
               1.8
                             ADSORPTION BED LENGTH (FT)
 VARY
         84
          85 507,
                             SUPERFICIAL SURFACE AREA PER VOLUME OF BED 1/FT
 VARY
       3 86 0.40 VOID FRACTION OF THE PACKED BED
3 87 22 SPECIFIC HEAT OF BED MATERIAL BTU/LB=F
3 88 45. BULK DENSITY OF BED MATERIAL LB/FT++3
 VARY
  RY
               .01 MASS TRANSPER COEFFICIENT BETWEEN GAS AND ADSORBEN MASS OF COOLANT IN MY
  RY.
 VARY
        3 89
        3 90
 VARY
                1.0 E-10 98 EXIT ADSORANTE GAS PRESSURE
 VARY.
          -91
               1.0 E-19 106 BED LOADING (LB ADSORBATE/LB BED)
5.0 114 CARRIER GAS OUTLET TEMP
 VARY
          99
               45.0 114 CARRIER GAS OUTLET TEMP
 VARY
        3 107
                                                                     DEG=F
                      122 ADSORBENT BED TEMP
              40.0
        3 115
              40.0 122 ADSORBENT BED TEMP
40.0 130 LIQUID COOLANT OUTLET TEMP
                                                                      DEG-F
VARY
 VARY
        3 123
                                                                        DEG-F
             DUMMY COMPONENT PROVIDING COOLANT/SEC FLOW TO SILICA GEL BED , ADSOR
 ID:
       13
 KBAS
       13
                            COOLANT FLOWRATE
 VARY
       13
              270.0
                                                                        (LB/HR)
       13
                            COOLANT TEMPERATURE
 VARY
              38.0
                                                                        (DEG-F)
       13 3 15.0
                           UPSTREAM DUCT OUTLET PRESSURE
 VARY
                                                                         ·(PS1)
              15.0 COMPONENT DUTLET PRESSURE
 VARY
                                                                          (PSI)
             DUMMY COMPONENT SIMULATING A HEATER THAT IS OFF, DATA PASSES UNCHANG
 ID.
 KBAS
 NSTR
                                  ALTOOM PASSES DATA UNCHANGED
             REGENERATIVE HEAT EXCHANGER GAS-GAS COUNTERFLOW WITH EFFICIENCY#.95
 ID.
            KBAS ....
              210.0 OVERALL UA GIVEN PRI UDILEI (BTU/HR-DEG-F)
            211010000
 NSTR
        5
 VARY
         -66
VARY
          -74
             -----B<sub>1</sub>B--
          75 -190.0
                            DESIGN OUTLET TEMP FOR PRIMARY SIDE (DEG.F)
 VARY
             CO2 PERCIPITATOR A GAS-GAS HX WITH PERCIPITATING CO2, NSTR(9)=1
 1Dee
              7
4.KBAS.....6
           210010001 1 PRECIP HX UA GIVEN PRI DUT TMP SIZING CRITERIA
1 109,92 TOTAL FLOW
 TR
 VARY
VARY
              <del>=217,4</del>
                           -- TEMPERATURE---
                                                                       (DEGoF)
                        UPSTREAM DUCT OUTLET PRESSURE
COMPONENT OUTLET PRESSURE
NON-CONDENSABLE FLOW
           3 13,7
4 13,7
5 109,89
 VARY
        6
                                                                         (PSI)
 VARY
                                                                         (PSI)
2 VARY --- 6 5
                                                                        (LB/HR)
```

```
.242 NON CONDENSABLE SPECIFIC HEAT (BTU/LB=F)
28.97 NON CONDENSABLE MOLECULAR WEIGHT (L3/MOLE)
29.35 OXYGEN FLOW (L8/HR)
80.41 DILUENT FLOW (L8/HR)
.12505 DILUENT FLOW (L8/HR)
-35.0 OVERALL UA (BTU/HR-DEG-F)
3.0 NTU(MAX)
 VARY
 VARY
 VARY
             -10
                   80,41 DILUENT FLOW
               11
 VARY
               12
 VARY
         6 66 35,0
 VARY
        6
               74
                   DUMMY COMPONENT PROVIDING THE REFRIGERATION FLOW FOR COS PRECIPITAT
 IDe+
         16
 KBAS
                1 45.0 FLOWRATE
2 = 280. TEMPERATURE
3 20. UPSTREAM DUCT OUTLET PRESS (PSI)
4 20. PRESSURE COMPONEN OUTLET
5 45.0 NON=CONDENSABLE FLOW (LB/HR)
8 239 SPECIRIO HEAT (BTU/L8-F)
9 28.0 MOLECULAR WEIGHT (LBS/MOLE)
                  45.0 FLOWRATE
 VARY
         16
 VARY
         16
 VARY
         16
 VARY
         16
         16
 VARY
             9 28 0
 VARY
 VARY
         16
               FAN SIMULATED ONLY TO AN EXTENT OF HEAT ADDITION TO THE SYSTEM
           7
 10.
             23 -5 2 3 B
030 FAN.ADD HEAT SPECIFIED NO FAN PERFORMANCE CALC
91 100.0 HEAT WHICH IS ADDED TO GAS STREAM (WATTS)
92 1.0 THERMAL CAPACITANCE OF FAN ASSY (BTU/DEG-F)
 KBAS
 NSTR
 VARY
 VARY
                      30.0 THERMAL CAPACITANCE OF PAN ASSY (BTU/DEG-F)
               93
 VARY
               HEATER THE REQUIRED POWER INPUT WILL BE COMPUTED BY GPOLY LOGIC
 ID.
 KBAS
                                                 HEATER CHANGES THE TEMPERATURE OF THE FLUID.
 NSTR
                   DESORBISILICA GEL BEDS DESORBED BY THE WARM AIR FLOWING OUT OF HEAT
 ID.
 KBAS
              200
 NSTR
                                                 SILICA GEL BED DESORB CYCLE.
                                 EFFECTIVE HEAT EXCHANGER AREA
               66 1.
                                                                                               NFT++2E
        9 67 65.
   AY
 VARY 9 68 0.85 HEAT EXCHANGER EFFECTIVENESS

VARY 9 76 .055 AVERAGE SS LOADING FOR H20 REMOVAL BEDS (BTU/HR-F)

VARY 9 70 .42 THERMAL COEFFICIENT FOR H20 CONDENSATION

VARY 9 80 1062.0 THERMAL COEFFICIENT FOR H20 CONDENSATION

VARY 9 83 1.0 ADSORPTION FRONTAL AREA (FT • 2)

VARY 9 84 1.8 ADSORPTION BED LENGTH (FT)
           9 85 507. SUPERFICIAL BURFACE AREA PER VOLUME OF BED 1/FT 9 86 0.40 VOID FRACTION OF THE PACKED BED SPECIFIC HEAT OF BED MATERIAL BTU/LB-6
 VARY
 VARY
           9 88 45.
9 89 .01
9 MASS TRANSFER COEFFICIENT BETWEEN GAS AND ADSORBEN
9 90 4.0
9 91 7.5
9 8 EXIT DESORBATE GAS PRESSURE
9 99 .1
106 BED LOADING (LB ADSORBATE/LB BED)
 VARY
 VARY.
          9 89
 VARY
 VARY
        9 91
 VARY
 VARY
                                                                                          DEG-F
                                114 CARRIER GAS OUTLET TEMP
              107
 VARY
                                  130 LIQUID COCLANT OUTLET TEMP
           9 115 70.0
9 123 40.0
                                122 ADSORBENT BED TEMP
 VARY
 VARY
                                                                                                        DEG-F
         20 METERED FLOW TO CABIN OUT OF MECH FREEZOUT SYSTEM.
 1000
               29 12 9 2
 KBAS
          20
          20
                                                 METER ALL FLOWS
 NSTR
S 1Dee
                          FOR H20 COLLECTION OUT OF H20 CONDENSER
              12
          17
 KBAS
          17
 KARY
4 KARY
              17.
                   WATER STORAGE TANK SIMULATED BY TANKE SUBROUTINE
  . .
         18 30 17 0 2

18 3100 H20 RESERVOIR

18 54 70.0 AMBIENT GAS TEMPERATURE (DEG.P)

18 55 5.0 THERMAL CONDUCTANCE INSULATION AND AMBIENT (B/HR.F)

18 57 60. AMBIENT WALL TEMP (DEG.P)
 RUAS
LNSTR
 VARY
 VARY
2 VARY
```

```
6.0 THERMAL RADIATION FA FACTOR INSULATION TO WALL (FT2)
60. STRUCTURE TEMP (DEG.F)
5.0 CONDUCTANCE BETHEEN TANK AND STRUCTURE (STU/HR)
 VARY
        18
 VARY
        18
             60
 VARY
                  15.0 CONDUCTANCE BETHEEN TANK AND STRUCTURE (STU/NK)

15.0 CONDUCTANCE BETHEEN OUTER WALL AND INSULAT (S/HR-F)

15.0 TOTAL FLUID WEIGHT IN TANK

(LBS)

70.0 FLUID TEMP, IN TANK

(PT++3)

14.7 FLUID PRESSURE IN TANK

(PSI)

2.5 THERNAL CAPACITANCE OF TANK SHELL

(B/LB-F)
        18
             64
 VARY
             67
        18
VARY
            -68
        18
 VARY
        18
             69
 VARY
        18
             70
 VARY
        18
             92 7.0 MAX ALLOWABLE TEMP CHANGE IN ONE ITERATION (DEG-F)
 VARY
        18
                 DUMMY COMPONENT PROVIDING HEATING FLOW TO THE SUBLIMATOR
 !Da+
        11
KBAS
        11
                45. TOTAL FLOW OF WARM N2

-100, TEMPERATURE OF N2

20. PRESSURE

20. PRESSURE

45. NON-CONDENSABLE FLOW

239 SPECIFIC HEAT

28. MOLECULAR WEIGHT

CO2 PRECIPITATOR/SUBLIMATOR A CYCLIC HX

210010002
 VARY
        11
 VARY
        11
 VARY
        11
              : 4·
 VARY
        11
                                                                             (L9/HR)
 VARY
        11
 VARY
        11
            8 .239
                                                                                         (BTU/LBeF)
               9 28,
 VARY
                                                                                     (L9S/MOLE)
        11
 ID.
         10
 KBAS
         مه
                210010002 I PRECIP HX UA GIVEN PRT OUT THE SIZING CRITERIA
 NSTR.
        10
            66 39.0 OVERALL UA (BTU/HR#DEG#F)
74 3.0 NTU(MAX) (ND)
 VARY
         10
 VARY
        10
                 PUMP FOR EO2 COLLECTION FROM CO2-SUBLIMATION HX TO CO2 RESERVOIR.
 I.D.
         14
                 22 10 2 3 15
0 2 CO2 PUMP
 KBAS
NSTR
                 COS RESERVOIR SIMULATED BY TANKS RECEIVES FLOW FROM COS PUMP,
 10.
        15
                30 14 2 3
1100 CO2 RESERVOIR
   MS
             54 70.0 AMBIENT GAS TEMPERATURE
 VARY
        15
                                                                                         (DEG.F)
                     5.0 THERMAL CONDUCTANCE INSULATION AND AMBIENT (B/HR-F)
 VARY
         15
              55
                                   AMBIENT HALL TEMP
 VARY
                   6.0 THERMAL RADIATION PA FACTOR INSULATION TO WALL (FT2)
60. STRUCTURE TEMP (DEG-F)
5.0 CONDUCTANCE BETWEEN TANK AND STRUCTURE (STU/HR)
 VARY
         15
              58
 VARY
         15
              60
 VARY
        15
             61
                     70.0 FLUID WEIGHT IN TANK (LBS
70.0 FLUID TEMP, IN TANK (DEG-F)
FLUID VOLUME IN TAK (FT-+3)
 VARY
         15
              67
                                                                                               (LBS)
              68
 VARY
        15
 VARY
                  1. FLUID VOLUME IN TAK

(4.7 FLUID PRESSURE IN TANK

(95)

WEIGHT OF NON-CONDENSABLES

17 N-C SPECIFIC HEAT IN TAK

44, MOLECULAR WEIGHT IN TAK

(185/MDLE)

0.5 WEIGHT OF NON-CONDENSABLES

(185)

THERMAL CAPACITANCE OF TANK SHELL

(8/LB-F)
 VARY
        15
              70
 VARY
         15
              71
 VARY 15 74
 VARY
         15
              75
         15
             78
 VARY
 VARY
                               MAX ALLOHABLE TEMP CHANGE IN ONE ITERATION (DEG-F)
              92
 VARY
         15
 KBAS
         19
         19
                                 TOTAL FLOW
 VARY
                                                                                         LB/HR
        19 2 -222, TEMPERATURE
                                                                                         (F) ....
 VARY
                  , 5
         19
 VARY
                                                                                       (PSI)
5 VARY
                     2,0 E=6
 VARY
         19
                                                                                        (LS/HR)
                  152
        19
 VARY
                                                                                        (BTN/LB-F)
               9
LARY
        19
                      28, ...
                                                                                        (L36/MOLE)
        19
              11
 RY
                     2.0 E-6
                                                                                        (L3/HR)
        19
 VARY
             14 16
                                    SUBLIMATE PLOW
                                                                                         LB/HR
                 - 02
                                   100.
                                                 TEMPERATURE OF AIR INTO THE SYSTEM DEG-F
3 PLOT
                                 100. TEMPERATURE OF AIR OUT OF THE SYS
                    2 0,
             9
                                                 TEMPERATURE OF AIR OUT OF THE SYSTEM DEG-F
 PLOT
 PLOT
                   12 0,
             01
                                    , 5
PLOT---- 9 -12---0.
                                                 CO2 IN PROCESS GAS LEAVING LB/HR
```

PLOT PLOT PLOT PLOT PLOT ENDC ENDR	14 01 9 5 6	12 06 6 2 2	0. 0. -200: -220: -220:	2.0	CO2 TO ACCUMULATOR LB/HR WATER VAPOR FLOW INTO THE SYSTEM L3/HR WATER VAPOR FLOW OUT THE SYSTEM L3/HR TEMP, OF PROCESS GAS ENTERING PRECIP, DEG F GAS TEMP OUT OF PRECIP/SUBLIM DEGF GAS TEMP OUT OF SUBLIM/PRECIP DEGF

```
*INSERT.GPOLY1.24
                     EMBRANE DIFFUSION ....
       IF(N NE. 10) GO TO 83
           B(1)86.5-A(1)
    83 CONTINUE
     IF( N .NB. 2 ) GO TO 99
       A(3) #A(3) #2.
       A(4) 5A(3)
       A1218175.
    99 CONTINUE
 *INSERT.GPOLY2.21
      IF(N .NE. 5) GO TO 5
     FIF (NPASS NE. 30) GO TO 15
      CALL SV(2.62 ,1 712)
       CALL SV(185,27,175)
    15 CONTINUE
    B(73)=VV(1,6)
       F(75) EVV(1,12)
       R(76) EVV(1,2)
    5 CONTINUE
       IF(N .NE. 4) GO TO 10
       R(13)#14.7*A(12)*WTMA/(44,0*A(1)) *51,73
       R(14) 814, 7 • R(12) • WTMA/(44, 0 • A(1)) • 51,73
  10 CONTINUE
 TAPE
 BASIC
             MEMBRANE MODULE PERFORMANCE ANALYSIS
 CASE 1
  ECASË1
  PKCHOUT#O, KPRNT#6, KPTINV(1)#10,MAXSLP#4, MINS81#2, KRUN#1, DTIME#30.,
   TIMEMX#1800, MAXSSI#3, TMAX#200, TMINE-450, WTMAX#1, E4 S
  SPROP1
  CP(1)#.230.RHO(1)#.16 .VISC(1)# .036 .WTM(1)#28.0 .XK(1)#.007
                        .VISC(2)# 3,6 .WTM(2)#18.0 .XK(2)#.329
  CP(2)#1.,RHO(2)#62.4
  CP (3) #.175, RHO(3) #.25
                         .VISC(3)8 .036 .WTM(3)844.0
                                                       ,XK(3) # 1007
 CPCONLal., CRCONVEO.44, CPCO280.2, CPDILEO.25, CPOXYEO.22, CPTC80.2,
   GAMGAS#1,4, VISGAS#0,44, WTMCON#18,, WTMDIL#28,, WTMTC#20,,
   CPC02 s .178.
                      WTMCON#18.
   YKGASHO.146 S
            1 DUMMY COMPONENT DEFINING THE INLET CONDITIONS TO THE CO2 REMOVAL
 ID:
 ID.
            2 SYSTEM USING MEMBRANE MODULE
 KBAS.
 NSTR
                                   DUMMY COMPONENT PASSES A, B-ARRAYS TO R-ARRAY
 VARY
                70.0
                             FLUID TEMPERATURE
 VARY
                             TOTAL FLOW INTMEMBRANE DIFFUSIONCONCEPT
               184,64
                                                                           (LB/HR)
                             UPSTREAM DUCT OUTLET PRESSURE
 VÁRY
        1
                14.7
                                                                             (PS1)
        1
                14.7
                             COMPONENT OUTLET PRESSURE
 VARY
                                                                             (PSI)
            5 182,60
VARY
                             NON=CONDENSABLE FLOW
                                                                           (LB/HR)
 VARY
                2,041
                             CONDENSABLE VAPOR FLOW
                                                                           (LB/HR)
 VARY
                0.0 %
                             CONDENSABLE ENTRAINED LIQUID FLOW
                                                                           (LB/HR)
                             NON-CONDENSABLE SPECIFIC HEAT
5 VARY
                                                                        (BTU/LB-F)
```

```
VARY
                 28,97
                               NON-CONDENSABLE MOLECULAR WEIGHT
                                                                             (LBS/MOL8)
 VARY
                 48,96
            10
                               OXYGEN FLOW
                                                                                (LB/HR)
 VARY
                132.54
                               DILUENT (N2) FLOW
                                                                                (LB/HR)
  ARY
                               CO2 FLOW
                                                                                (LB/HR)
 1000
               SYSTEM COMPRESSOR USED FOR PRESSURIZING THE INLET FLOW TO ESTABLISH
1D:
             2 A HIGHER PRESSURE DIFFERENTIAL
 KBAS
               23
        2
 NSTR
        2
              0030
                                      COMPRESSOR REQUIRING Q VS. DELP TABLE
_Dee
               CONDENSING HEAT EXCHANGER PROVIDED FOR HUMIDITY CONTROL
 KBAS
                                                     -23 0
                                                              2
 NSTR
        3
              210001100
                                      HX USINX TRANSIEN NO-SIZING GAS LIQUID
           66 75,
VARY
                               OVERALL UA ....
                                                                             (BTU/HR-F)
 VARY
        3
            67
                  .90
                               HX EFFECTIVENESS
                                                                             (ND)
                                                                             (ND)
 VARY
            74
                 5.0
                               NTU (MAX)
 VARY
                                        OUPLET TEMP PRI SIDE
            75
                               DESIGN-
                   · - 5
 VARY
        3
            76
                               DESIGN
                                        DUTLET TEMP TOLERANCE
               DUMMY COMPONENT PROVIDING COOLANT FLOW TO THE HEAT EXCHANGER
 1D.
       23
 KBAS
       23
                                  ..... 2.....
 NSTR
       23
             ាក
                                      DO NO MODIFY REARRAY
 VARY
                   60.
                               FLOW.
                                                                             (LB/HR)
       23
                                                                             (F)
VARY
       23
                               TEMP.
 VÁRY
       23
                   15.
                               PRESS.
                                                                             (P51)
             3
 VARY
       23
                   15.
                               PRESS.
                                                                             (PSI)
 1.Das
            ----MEMBRANE--MODULE-FOR REMOVAL--OF-CO2 BY SELECTIVE DIFFUSION
                                                     -13 2
 KBAS
                              3 2
 NSTR
                                      NSTR NOT REARD
 KARY
                               NUMBER OF MEMBRANES IN THE MODUL
 VARY
            54
                   70.
                               AMBIENT GAS TEMP.
 MARY
            55
                                                                             (BTU/HR=F)
                    1,3
                               THERMAL CONDUCTANCE BIWN SURFACE
   RY
            57
                               AMBIENT WALL TEMP
                                                                             (F)
                   60.
            58
                               FA FACTOR FOR RADIATION
 VARY
                   6.
                                                                             (FT==2)
            60
 VARY
                   60.
                               STRUCTURE TEMP
                                                                             (F)
 VÁRY
                    12.
                               CONDUCTANCE BETWEEN MODULE AND STRUCTURE
                                                                             (BTU/HROF
 VARY
            65
                                                                             (FT=#2)
                   2.0
                               MEMBRANE AREA
                 .005
 VARY
            66
                               THICKNESS:
                                                                             LINI
                  1.2 E-8
 VARY
            49
                               CO2 PERMEABILITY
                    1,71
 VARY
            91
                               INTERNAL THERMAL CONDUCTANCE . PRI.
                                                                             (BUT/HREF)
 VARY
            92
                                INTERNAL THERMAL CONDUCTANCE . SEC.
                     1.71
                                                                             (BTU/HRef)
            93
 VARY
                               EFFECTIVE THERMAL CONDUCTIVITY THROUGH
                    10.8
                                                                          MEMBRANES
 VARY
           103
                                                                             (FT)
                     2.0
                               MODULE: LENGTH
           104
                                                                             (FT++2)
                                              PRIMARY SIDE
 VARY
                      .1
                               FRONTAL AREA
VARY
           105
                               FRONTAL AREA SECONDARY SIDE
                                                                             (FT==2)
                      .. 1
                  12.0
                                                                             (BTU/F)
 VARY
           106
                               THERMAL CAPACITANCE OF MODULE SHELL
                               MULT, FACTOR USED
                                                    IN COMPUTIN STABILITY CRITERIA
          .107
 VARY
                               MINIMUM TIME INCREMENT IN TRANSIENT SOLUTION
 VARY
               FLOW METER
                           EVALUATING THE AIR FLOW FROM THE CO2 REMOVAL
 ID:
 KBAS
               29 12
 NSTR
                                      METER ALL CONSTITUENTS (FLOWMETER)
        5
 VARY
                               REFERENCE TEMPERATURE FOR ENTHALPY
                                                                             (F)
               CONDENSING HX FOR SEPARATION OF CO2 FROM H20 VAPOR
 1Dee
5 KBAS
 NSTR
        6
              210001100
                                1
                460,
 VARY
                               OVERALL UA
            66
                                                                             (BTU/HROF)
4 VARY
                               HX EFFETIVENESS
            47_
                                                                             (ND)
  NR Y
        6
            74
                               NTU (MAX)
                                                                             (ND)
   AY
        6
            75 40.
                               DESIGN OUTLET TEMP PRI SIDE
                                                                             (F)
3 VARY
                               TOLERANCE FOR DESIGN TEMP
                                                                             (F)
       26
 ID:
               DUMMY
                     COMPONENT PROVIDING COOLANT FLOW TO THE CONDENSOR
               40
 KBAS
       26
                                     2
LNSTR
                                      DO NOT MODIFY REARRY
```

```
270.
                           FLOW
VARY
      26
                                                                     (FLOW)
               35,
VARY
      26
                          - TEMP.
                                                                     (TEMP)
VÄRY
                 15.
                           PRESS.
                                                                     (PSI)
                15.
      26
                          PRESS.
                                                                     (PSI)
      7
            COS PUMP USED TO FORCE COS INTO THE ACCUMULATOR
179
KBAS
           __23___
NSTR
           0030
                                 ADD HEAT SPECIFIED IN R(91) ONLY
             . 01
VARY
                            HEAT ADDED TO GAS STREAM
                                                                     WATTS
lle.
KBAS
       8
            30
            1100
NSTR
              70.
VARY
         54
                           AMBIENT GAS TEMPERATURE
                                                                     (F)
VARY
       8
          55
               5.
                          THERMAL CONDUCTANCE BETHEEN AMBIENT TANK (BIN/HR.F)
              60.
VARY
          57
                            AMBIENT WALL TEMP
                                                                     (E)
VARY
                            RADIATION FA FACTOR SKIN TO HALL
VARY
       8
          60
              60.
                           STRUCTURE: TEMPERATURE
                                                                     (F)
VARY
       8
              12.
                           CONDUCTANCE BETWEEN THE WALL AND STRUCTUR (BTU/HR.F)
          61
              _____5___
                         TOTAL FLUID WEIGHT IN THE
VARY
                                                                    (L35)
              70.
                           FLUID TEMPERATURE IN THE
VARY
          68
                                                                     (F)
                                                                     (FT+#3)
VARY
          69
                           FLUID VOLUME IN TANK.
VARY
          70
                          FLUID PRESS IN THE
                                                                    <del>- (PS1)</del>
                0.5
                           WEIGHT OF NON-CONDENSABLE IN THE
VARY
          71
                                                                     (L95)
                 117
                           NON-CONDENSABLE SPECIFIC HEAT IN THK.
          74
VARY
                                                                     (BTU/LBeF)
VARY.
          75
               44.
                       (LB)
          78
                            WEIGHT OF NON-CONDENSABLE IN THE
VARY
                                                                    (LBS)
             H20 REMOVAL/SEPARATION ACCOMPLISHED BY THIS UNIT
ID.
KBAS
NSTR
                                 NSTR CARDS NOT REGRD
KARY
          16
         17...
KARY
       9
          18
      10
             JUNCTION FOR H20 MIX TO SYSTEM FROM THE WATER STORAGE SYSTEM
ID**
      10
                                            KBAS
                                 LIQUID MIX MIXED FLOW
NSTR
      10
           2.
                                                       PRESS # PRI SOURCE PRESS
ID.
      11
            HZO ACCUMULATOR STORING WATER THAT IS USED BY STEAM GENERATOR
KBAS
                                                                      12
            1100
NSTR
                                GPOLY LOGIC COMPUTES OUTLET FLOW
      11
                                                                   H20 ACCU.
           1 0.5
VARY
      11
                            TOTAL FLOW
                                                                   (LB/HR)
VARY
            70.
                            TEMP
           3 1,
VARY
      11
                            PRESS
                                                                     (PSI)
      11
                           PRESS
VARY
                                                                     (PSI)
               70.
                          AMBIENT GAS TEMPERATURE
VARY
      11
          .54.........
                                                                     (F)
                5.
                           THERMAL CONDUCTANCE INSULATION AND GAS
VARY
      11
          55
                                                                     (BTU/HREF)
                          AMBIENT WALL TEMPERATURE
VARY
      11
          57
                60.
                                                                     (F)
          58
VARY
                           -THERMAL RADIATION FACTOR FA SKIN TO WALL
                                                                     (FT++2)
      11
          60
                60.
                           STRUCTURE: TEMPERATURE
VARY.
               12.
                           CONDUCTANCE BETWEEN THE WALL AND STRUCTUR (BTU/HR=P)
VARY
      11
          61
                _8.....
                         TOTAL FLUID WEIGHT IN TANK
VARY
      11
          67
                                                                     (13)
                70.
VARY
      11
          68
                      FLUID TEMP IN TANK
                                                                     (F)
          69
                , 5
      11
                           FLUID VOLUME IN TANK
VARY
                                                                     (FT++3)
VARY
          70
                           PRESS.
                                                                     (PS1)...
          73
            31,2
VARY
      11
                            WEIGHT OF LIGUID IN THE
                                                                     (Las)
          87 62.4
VARY
      11
                            DENSITY
                                                                     (L3/FTCU)
          89 18,
VARY
      11
             H20 PUMP FO FORCING WATER TO THE STEAM GENERATOR
      12
      12
             22
      12
NSTR
                                 ONLY VEARRY DATA REGRO IS HEAT ADDED TO FLUID
                            HEAT ADDED TO FLUID STREAM
VARY
      12
          85
                                                                     (WATTS)
      13
           1 STEAM GENERATOR PROVIDING THE VAPOR FLOW USED AS SWEEP GAS IN THE
ID:
```

KBAS	13	27	12 2	and the second section of the second section of the second section sec	2
NSTR	13	01		EATNG REGRMNTS TO VAPORIZE LI	QUID ENTERNG
-VARY	13	1 4,5	TOTAL FL	ON OF STEAM	LB/HR
RY	.13	2 120,	TEMP		ř
VARY	13	3 1,0	PRESS		PS1
-VARY	_13	4-1-0	PRESS	· ·	PS1
VARY	13	6 6.5	VAPOR FL		LB/HR
VARY	13	8 .24	SPECIFIC		BTU/HB=F
-VARY	43_	9 28,97	MOLECULA		L'B/MOLE-
VARY	13	66 20,	DESIRED	DEGREES OF SUPERHEAT	(F)
1D**	14			VIDING THE MAKEUP WATER FOR M	EMBRANE MODULE.
KBAS -	14.	± 3 0	0 - 2		•
NSTR	14			ANK SUPPLYING MAKE-UP WATER	
VARY	14	2 70,		TEMP	
VARY-	-34-	3 1.0			
VARY	14	4 1,0	OUTLET F	Control of the contro	PS1
VARY	14	54 70. 55 0.		GAS TEMP	(F)
VARY	14	- · ·		ANCE BETHEEN BURFACE AND AMBN	
VARY VARY	14			WALL TEMP	(F) (FTm+2)
VARY	4.4	58 60,		ON FACTOR FA SURFACE TO WALL	(FIREZ)
VARY	14	61 .		ANCE KAZX TANK TO STRUCTURE	
VARY	14	68 70,		EMP IN TAK	F
VARY	77	70 1.0	PRESS.		PSI
VÄRY	14			CONDUCTANCE INTERNAL FLUID T	. — •
VĂRY	14	92 5	MAY ALL	DWABLE TEMP CHANGE	(F)
PLOT	- (*)	1 12 0,		COS PLOW INTO CONCENTRATOR	
PLOT		4 12 0,		CO2 PLOW OUT OF THE CONCEN	
PLOT		5 76 40	100.	TEMPERATURE OF AIR FLOWING	
		4 2 40		TEMPERATURE OF AIR FLOWING	
PLOT		4 13 0.		PPCO2 OF GAS STREAM FLOWIN	
PLOT		4 14 0,		PPCO2 OF GAS STREAM FLOWIN	
PLOT		5 73 0.		HEO FLOWRATE INTO COS CON.	
PLOT		4 6 0,		HEO FLOWRATE OUT OF COE CO	
ENDC		•			
ENDR	·				

MCDONNELL DOUGLAS ASTRONAUTICS COMPANY 5301 Bolsa Avenue, Huntington Beach, California 92647 (714) 897-0311